

# Inspection Checklist for Permit #000054418

Notes:

Order	Category	Inspection	Requirements
1	Solar	Electrical Rough-In <i>Checks PV wiring, conduit, and grounding. Ref: NEC 690</i>	
2	Electrical	Permanent Power <i>Releases power once service equipment is complete and safe. Ref: NEC Art. 230</i>	
3	Solar	Solar Final <i>Ensures PV system, inverter, and disconnects are safe/approved. Ref: NEC 690</i>	