



Scott E. Wyssling, PE, PP, CME

**Wyssling Consulting**  
76 North Meadowbrook Drive  
Alpine, UT 84004  
office (201) 874-3483  
swyssling@wysslingconsulting.com

September 14, 2021

Jacob Humpherys, COO  
Meraki Solutions  
30700 Wekiva River Road  
Sorrento, FL 32776

Scott E Wyssling, PE

Digitally signed by Scott E Wyssling, PE  
DN: C=US, S=Utah, L=Alpine, O=Wyssling Consulting, CN="Scott E Wyssling,  
PE", E=swyssling@wysslingconsulting.com  
Reason: I am the author of this document  
Location: your signing location here  
Date: 2021.09.14 17:13:00-04'00'  
Foxit PhantomPDF Version: 10.1.3

Re: Engineering Services  
Blake Residence  
571 SW Atlas Drive, Fort White, FL  
10.000 kW System

Dear Mr. Humphreys:

Pursuant to your request, we have reviewed the following information regarding solar panel installation on the roof of the above referenced home:

1. Site Visit/Verification Form prepared by a Meraki Solutions representative identifying specific site information including size and spacing of rafters for the existing roof structure.
2. Design drawings of the proposed system including a site plan, roof plan and connection details for the solar panels. This information was prepared by Meraki Solutions and will be utilized for approval and construction of the proposed system.
3. Photographs of the interior and exterior of the roof system identifying existing structural members and their conditions.

Based on the above information we have evaluated the structural capacity of the existing roof system to support the additional loads imposed by the solar panels and have the following comments related to our review and evaluation:

**Description of Residence:**

The existing residence is typical wood framing construction with the roof system consisting of assumed 2 x 6 dimensional lumber at 24" on center. The attic space is finished and photos indicate that there was no access to visually inspect the size and condition of the roof rafters. All wood material utilized for the roof system is assumed to be Spruce Pine Fir #2 or better with standard construction components. The existing roofing material consists of metal roofing. Photos of the dwelling also indicate that there is a permanent foundation.

**A. Loading Criteria Used**

- 160 MPH wind loading based on ASCE 7-16 Exposure Category "C" at a slope of 22 degrees
- 7 PSF = Dead Load roofing/framing      Live Load = 20 PSF/ 0 PSF (where panels are installed)
- 3 PSF = Dead Load solar panels/mounting hardware

*Total Dead Load = 10 PSF*

*The above values are within acceptable limits of recognized industry standards for similar structures in accordance with the (FBC 2020, 7<sup>th</sup> Edition). Analysis performed of the existing roof structure utilizing the above loading criteria indicates that the existing rafters will support the additional panel loading without damage, if installed correctly.*


**B. Solar Panel Anchorage**

1. The solar panels shall be mounted in accordance with the most recent "*S-5 Installation Manual*", which can be found on the S-5 website (<http://s-5.com/>). If during solar panel installation, the roof framing members appear unstable or deflect non-uniformly, our office should be notified before proceeding with the installation.
2. System will be attached to the metal roofing material utilizing the patented S-5 connection. Installation of the connections shall be in accordance with the manufacturer's recommendations.
3. Considering the roof slopes, the size, spacing, condition of roof, the panel supports shall be placed no greater than 48" o/c.

Based on the above evaluation, it is the opinion of this office that with appropriate panel anchors being utilized the roof system will adequately support the additional loading imposed by the solar panels. This evaluation is in conformance with the FBC 2020, 7<sup>th</sup> Edition, current industry and standards, and based on information supplied to us at the time of this report.

Should you have any questions regarding the above or if you require further information do not hesitate to contact me.

Very truly yours,



Scott E. Wyssling, PE  
Florida License No. 81558



THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE AND DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES



AERIAL VIEW:



STREET VIEW:



CONTRACTOR INFORMATION:

Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044

SITE INFORMATION

**Tyane & Roy Blake**  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative

GENERAL NOTES

1. INSTALLATION OF SOLAR PHOTOVOLTAIC SYSTEM SHALL BE IN ACCORDANCE WITH NEC ARTICLE 690, AND ALL OTHER APPLICABLE NEC CODES WHERE NOTED OR EXISTING.
2. PROPER ACCESS AND WORKING CLEARANCE AROUND EXISTING AND PROPOSED ELECTRICAL EQUIPMENT WILL COMPLY WITH NEC ARTICLE 110.
3. ALL WIRES, INCLUDING THE GROUNDING ELECTRODE CONDUCTOR SHALL BE PROTECTED FROM PHYSICAL DAMAGE IN ACCORDANCE WITH NEC ARTICLE 250
4. THE PV MODULES ARE CONSIDERED NON-COMBUSTIBLE; THIS SYSTEM IS UTILITY INTERACTIVE PER UL 1741 AND DOES NOT INCLUDE STORAGE BATTERIES OR OTHER ALTERNATIVE STORAGE SOURCES.
5. ALL DC WIRES SHALL BE SIZED ACCORDING TO [NEC 690.8]
6. DC CONDUCTORS SHALL BE WITHIN PROTECTED RACEWAYS IN ACCORDANCE WITH [NEC 690.31]
7. ALL SIGNAGE TO BE PLACED IN ACCORDANCE WITH LOCAL JURISDICTIONAL BUILDING CODE.

PHOTOVOLTAIC (PV) SYSTEM SPECIFICATIONS


EQUIPMENT:  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
(30) Trina Solar TSM-DD06M.05(II) 330 PV MODULES  
(1) SolarEdge SE10000H-US (240V) INVERTER(S)  
RACKING: IronRidge 48" O.C.

APPLICABLE GOVERNING CODES

2017 NEC  
2018 IRC  
2020 FBC 7TH EDITION  
2018 IBC  
2018 IEBC

SITE SPECIFICATIONS

OCCUPANCY: R-3  
ZONING: RESIDENTIAL



THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE & DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.



SHEET INDEX:

PV01 COVER PAGE  
PV02 SITE PLAN  
PV03 ROOF ATTACHMENTS  
PV04 MOUNTING DETAIL  
PV05 LINE DIAGRAM  
PV06 LABELS  
PV07 PLACARD  
PV08 SITE PHOTOS

DRAWN BY: SoloCAD

DATE:  
September 13, 2021

COVER PAGE - PV01



**CONTRACTOR INFORMATION:**  
Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044












**SITE INFORMATION**

**Tyane & Roy Blake**  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative



THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED  
BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE & DATE  
PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED  
SIGNED & SEALED AND THE SIGNATURE MUST BE VERIFIED ON  
ANY ELECTRONIC COPIES.

**EQUIPMENT LEGEND:**

 UTILITY METER	 VISIBLE, LOCKABLE, LABELED AC DISCONNECT	 INVERTER	 SUB PANEL	 FIRE ACCESS PATHWAY (3' TYP)	 BATTERY(IES)
 MAIN SERVICE PANEL	 METER SOCKET (FOR UTILITY PV METER)	 COMBINER BOX	 LOAD CENTER	 PROPERTY LINE	


VISIBLE, LOCKABLE,  
LABELED AC DISCONNECT  
LOCATED WITHIN 10'  
OF UTILITY METER

DRAWN BY: SoloCAD

DATE:  
September 13, 2021


SITE PLAN - PV02





**CONTRACTOR INFORMATION:**  
Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044


**SITE INFORMATION**  
**Tyane & Roy Blake**  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative



THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE & DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

EQUIPMENT INFORMATION:		ROOF INFO:		PHOTOVOLTAIC ARRAY STRUCTURAL CRITERIA:	
RAIL MANUFACTURER	IronRidge	ROOF TYPE	trap_metal	PV MODULE COUNT:	30
RAIL PART NUMBER	XR-100	ROOF FRAMING	traditional_framing	ARRAY AREA:	MODULE COUNT * 18.06ft² = 541.8
ATTACHMENTS	S-5I - PROTEA BRACKET	RAFTER/TOP CHORD SIZE	2x6	ROOF AREA:	1978.69 ft²
ATTACHMENT QTY	54	RAFTER/TOP CHORD SPACING	24"	PERCENT OF ROOF COVERED:	27%
SPLICE QTY	12	ATTACHMENT SPACING	48	ARRAY WEIGHT:	MODULE COUNT * 50lbs = 1500
MIDCLAMP QTY	56			DISTRIBUTED LOAD:	ARRAY LBS/ATTACHMENTS = 27.78
ENDCLAMP QTY	8			POINT LOAD: (lbs/ft²)	(ARRAY) WEIGHT/AREA = 2.77 lbs/ft²

**DRAWN BY:** SoloCAD  
**DATE:**  
September 13, 2021  
**ROOF ATTACHMENTS - PV03**



SCREW ATTACHMENT DETAILS FOR PROTEA BRACKET  
1/4" (6.3mm) Diameter  
1" (25mm) Length  
Stainless Steel Self Tapping Screw with Hardened Steel Piercing Point  
5/16" (8mm) Hex Head  
5/8" (16mm) Stainless Steel/EPDM Sealing Washer




CONTRACTOR INFORMATION:

Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044

SITE INFORMATION

**Tyane & Roy Blake**  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV MODULES  
(1) SolarEdge SE10000H-US (240V) INVERTER(S)  
Clay Electric Cooperative



THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT E. WYSSLING, PE USING A DIGITAL SIGNATURE & DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

DRAWN BY: SoloCAD

DATE:  
September 13, 2021


MOUNTING DETAIL - PV04

EQUIPMENT INFORMATION:		ROOF INFO:		PHOTOVOLTAIC ARRAY STRUCTURAL CRITERIA:	
RAIL MANUFACTURER	IronRidge	ROOF TYPE	trap_metal	PV MODULE COUNT:	30
RAIL PART NUMBER	XR-100	ROOF FRAMING	traditional_framing	ARRAY AREA:	MODULE COUNT * 18.06ft <sup>2</sup> = 541.8
ATTACHMENTS	S-5! - PROTEA BRACKET	RAFTER/TOP CHORD SIZE	2x6	ROOF AREA:	1978.69 ft <sup>2</sup>
ATTACHMENT QTY	54	RAFTER/TOP CHORD SPACING	24"	PERCENT OF ROOF COVERED:	27%
SPLICE QTY	12	ATTACHMENT SPACING	48	ARRAY WEIGHT:	MODULE COUNT * 50lbs = 1500
MIDCLAMP QTY	56			DISTRIBUTED LOAD:	ARRAY LBS/ATTACHMENTS = 27.78
ENDCLAMP QTY	8			POINT LOAD: (lbs/ft <sup>2</sup> )	(ARRAY) WEIGHT/AREA = 2.77 lbs/ft <sup>2</sup>

Conduit & Conductor Schedule									
TAG	WIRE GAUGE	DESCRIPTION	QTY	CONDUIT SIZE	CONDUCTOR RATING	# OF CONDUCTORS DERATE	TEMP. DERATE	CONDUCTOR RATING W/DERATES	CONDUIT FILL
1	10 AWG	PV-WIRE , USE-2, COPPER (L 1, L 2)	(2)	N/A - FREE AIR	40A	N/A - FREE AIR	0.96	38.4A	N/A - FREE AIR
	6 AWG	BARE, COPPER (GROUND)	(1)						
2	10 AWG	THWN-2, or THHN, or 10/2 NM-B COPPER - (L 1, L 2)	(2)	3/4" EMT	40A	1	0.96	38.4A	11.9%
	10 AWG	THWN-2, or THHN, or 10/2 NM-B COPPER - (GROUND)	(1)						
3	10 AWG	THHN/THWN-2, COPPER - (L1, L2)	(4)	3/4" EMT	40A	0.8	0.96	30.72A	19.8%
	10 AWG	THHN/THWN-2 - (GROUND)	(1)						
4	6 AWG	THWN-2 COPPER - (L1, L2, NEUTRAL)	(3)	3/4" EMT	65A	1	0.96	62.4A	35.5%
	8 AWG	THWN-2 COPPER - (GROUND)	(1)						

EQUIPMENT SCHEDULE:			
TYPE:	QTY:	DESCRIPTION:	RATING:
MODULES:	(30)	Trina Solar TSM-DD06M.05(II) 330	330 W
INVERTERS:	(1)	SolarEdge SE10000H-US (240V)	10000 W
AC DISCONNECT(S):	(1)	PV AC DISCONNECT, 240V, 2-POLE	60A
DC OPTIMIZERS:	(30)	SolarEdge P340	15 Adc

SUBJECT PV SYSTEMS HAS BEEN DESIGNED TO MEET THE REQUIREMENTS OF THE NEC 2017, AND THOSE SET FORTH BY THE FLORIDA SOLAR ENERGY CENTER CERTIFICATION, INCLUDING- MAXIMUM NUMBER OF MODULE STRINGS. MAXIMUM NUMBER OF MODULES PER STRING, MAXIMUM OUTPUT, MODULE MANUFACTURER AND MODEL NUMBER, INVERTER MANUFACTURER AND MODEL NUMBER.



**GROUNDING & GENERAL NOTES:**

- 1. PV INVERTER IS UNGROUNDED, TRANSFORMER-LESS TYPE.
- 2. DC GEC AND AC EGC TO REMAIN UNSPLICED, OR SPLICED TO EXISTING ELECTRODE
- 3. ANY EXISTING WIRING INVOLVED WITH PV SYSTEM CONNECTION THAT IS FOUND TO BE INADEQUATE PER CODE SHALL BE CORRECTED PRIOR TO FINAL INSPECTION.
- 4. JUNCTION BOX QUANTITIES, AND PLACEMENT SUBJECT TO CHANGE IN THE FIELD - JUNCTION BOXES DEPICTED ON ELECTRICAL DIAGRAM REPRESENT WIRE TYPE TRANSITIONS.
- 5. AC DISCONNECT NOTED IN EQUIPMENT SCHEDULE OPTIONAL IF OTHER AC DISCONNECTING MEANS IS LOCATED WITHIN 10' OF SERVICE DISCONNECT.

**INTERCONNECTION NOTES**

- 1. GROUND FAULT PROTECTION IN ACCORDANCE WITH [NEC 215.9] & [NEC 230.95]
- 2. SUPPLY SIDE INTERCONNECTION ACCORDING TO [NEC705.12(A)] WITH SERVICE ENTRANCE CONDUCTORS IN ACCORDANCE WITH [NEC 240.21(B)]

**DISCONNECT NOTES**

- 1. DISCONNECTING SWITCHES SHALL BE WIRED SUCH THAT WHEN THE SWITCH IS OPENED THE CONDUCTORS REMAINING LIVE ARE CONNECTED TO THE TERMINALS MARKED "LINE SIDE" (TYPICALLY THE UPPER TERMINALS)
- 2. AC DISCONNECT MUST BE ACCESSIBLE TO QUALIFIED UTILITY PERSONNEL, BE LOCKABLE, AND BE A VISIBLE-BREAK SWITCH.
- 3. FUSED AC DISCONNECT TO BE USED.

VISIBLE, LOCKABLE,  
LABELED AC DISCONNECT  
LOCATED WITHIN 10'  
OF UTILITY METER




**CONTRACTOR INFORMATION:**

Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044

**SITE INFORMATION**

**Tyane & Roy Blake**

571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative



THIS PLAN HAS BEEN ELECTRONICALLY SIGNED AND SEALED BY SCOTT WYSSLING, PE USING A DIGITAL SIGNATURE & DATE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED & SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

DRAWN BY: SoloCAD

DATE:  
September 13, 2021

LINE DIAGRAM - PV05

**WARNING**

**ELECTRIC SHOCK HAZARD**

**TERMINALS ON THE LINE AND  
LOAD SIDES MAY BE ENERGIZED  
IN THE OPEN POSITION**

LABEL 1  
FOR PV DISCONNECTING MEANS WHERE THE LINE AND  
LOAD TERMINALS MAY BE ENERGIZED IN THE OPEN  
POSITION.  
[NEC 690.13(B)]

**WARNING**

**THIS EQUIPMENT IS FED BY MULTIPLE  
SOURCES. TOTAL RATING OF ALL  
OVERCURRENT DEVICES, EXCLUDING  
MAIN SUPPLY OVERCURRENT  
DEVICE, SHALL NOT EXCEED  
AMPACITY OF BUSBAR.**

LABEL 2  
PLACED ADJACENT TO THE BACK-FED BREAKER  
FROM THE INVERTER IF TIE IN CONSISTS OF  
LOAD SIDE CONNECTION TO BUSBAR.  
[NEC 705.12(B)(2)(3)(b)]

**WARNING**

**INVERTER OUTPUT CONNECTION**

**DO NOT RELOCATE  
THIS OVERCURRENT  
DEVICE**

LABEL 3  
PLACED ADJACENT TO THE BACK-FED BREAKER  
FROM THE INVERTER IF TIE IN CONSISTS OF  
LOAD SIDE CONNECTION TO BUSBAR.  
[NEC 705.12(B)(2)(3)(c)]

**WARNING**

**DUAL POWER SUPPLY**

**SOURCES: UTILITY GRID AND PV  
SOLAR ELECTRIC SYSTEM**

LABEL 4  
EQUIPMENT CONTAINING OVERCURRENT  
DEVICES IN CIRCUITS SUPPLYING POWER  
TO A BUSBAR OR CONDUCTOR SUPPLIED  
FROM MULTIPLE SOURCES SHALL BE  
MARKED TO INDICATE THE PRESENCE OF  
ALL SOURCES [NEC 705.12(B)(3)]

**PHOTOVOLTAIC AC DISCONNECT**

**RATED AC OUTPUT CURRENT:**

42

**NOMINAL OPERATING AC VOLTAGE:**

240

LABEL 5  
AT POINT OF INTERCONNECTION, MARKED  
AT AC DISCONNECTING MEANS.  
[NEC 690.54, NEC 690.13 (B)]

LABELING NOTES:

- LABELS CALLED OUT ACCORDING TO ALL COMMON CONFIGURATIONS. ELECTRICIAN TO DETERMINE EXACT REQUIREMENTS IN THE FIELD PER CURRENT NEC AND LOCAL CODES AND MAKE APPROPRIATE ADJUSTMENTS.
- LABELING REQUIREMENTS BASED ON THE 2017 NATIONAL ELECTRIC CODE, OSHA STANDARD 19010.145, ANSI Z535.
- MATERIAL BASED ON THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.
- LABELS TO BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT INVOLVED [NEC 110.21(B)(3)]
- LABELS TO BE A MINIMUM LETTER HEIGHT OF 3/8", WHITE ON RED BACKGROUND; REFLECTIVE, AND PERMANENTLY AFFIXED [IFC 605.11.1.1]

**WARNING: PHOTOVOLTAIC  
POWER SOURCE**

**SOLAR PV SYSTEM EQUIPPED  
WITH RAPID SHUTDOWN**

TURN RAPID SHUTDOWN  
SWICH TO THE "OFF"  
POSITION TO SHUT DOWN  
PV SYSTEM AND REDUCE  
SHOCK HAZARD IN ARRAY

LABEL 6  
AT DIRECT-CURRENT EXPOSED RACEWAYS, CABLE TRAYS, COVERS  
AND ENCLOSURES OF JUNCTION BOXES, AND OTHER WIRING METHODS;  
SPACED AT MAXIMUM 10FT SECTION OR WHERE SEPARATED BY  
ENCLOSURES, WALLS, PARTITIONS, CEILINGS, OR FLOORS.  
[NEC 690.31(G)(3&4)]

LABEL 7  
FOR PV SYSTEMS THAT SHUT DOWN THE ARRAY AND CONDUCTORS  
LEAVING THE ARRAY:  
SIGN TO BE LOCATED ON OR NO MORE THAN 3 FT AWAY FROM SERVICE  
DISCONNECTING MEANS TO WHICH THE PV SYSTEMS ARE CONNECTED  
AND SHALL INDICATE THE LOCATION OF ALL IDENTIFIED RAPID  
SHUTDOWN SWITCHES IF NOT AT THE SAME LOCATION.  
[NEC 690.56(C)(1)(A)]


**SOLAR PV SYSTEM EQUIPPED  
WITH RAPID SHUTDOWN**

TURN RAPID SHUTDOWN  
SWITCH TO THE "OFF"  
POSITION TO SHUT DOWN  
CONDUCTORS OUTSIDE  
THE ARRAY. CONDUCTORS  
WITHIN THE ARRAY REMAIN  
ENERGIZED IN SUNLIGHT

LABEL 8  
FOR PV SYSTEMS THAT ONLY SHUT DOWN  
CONDUCTORS LEAVING THE ARRAY:  
SIGN TO BE LOCATED ON OR NO MORE THAN 3 FT  
AWAY FROM SERVICE DISCONNECTING MEANS TO  
WHICH THE PV SYSTEMS ARE CONNECTED AND  
SHALL INDICATE THE LOCATION OF ALL IDENTIFIED  
RAPID SHUTDOWN SWITCHES IF NOT AT THE SAME  
LOCATION.  
[NEC 690.56(C)(1)(b)]

**RAPID SHUTDOWN  
SWITCH FOR  
SOLAR PV SYSTEM**

LABEL 9  
SIGN LOCATED AT RAPID SHUT DOWN  
DISCONNECT SWITCH [NEC 690.56(C)(3)].



\*ELECTRICAL DIAGRAM SHOWN ABOVE IS FOR LABELING PURPOSES ONLY. NOT AN ACTUAL REPRESENTATION OF EQUIPMENT AND CONNECTIONS TO BE INSTALLED. LABEL LOCATIONS PRESENTED MAY VARY DEPENDING ON TYPE OF INTERCONNECTION METHOD AND LOCATION PRESENTED ON THE ELECTRICAL DIAGRAM PAGE.



CONTRACTOR INFORMATION:

Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044

SITE INFORMATION


Tyane & Roy Blake  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative

DRAWN BY: SoloCAD

DATE:  
September 13, 2021

LABELS - PV06





**DIRECTORY**  
PERMANENT PLAQUE OR DIRECTORY PROVIDING THE LOCATION OF THE SERVICE DISCONNECTING MEANS AND THE PHOTOVOLTAIC SYSTEM.

(ALL PLAQUES AND SIGNAGE WILL BE INSTALLED AS OUTLINED WITHIN:  
NEC 690.56(B)&(C), [NEC 705.10])



**CONTRACTOR INFORMATION:**  
Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044

**SITE INFORMATION**  
**Tyane & Roy Blake**  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative



DRAWN BY: SoloCAD

DATE:  
September 13, 2021

PLACARD - PV07

SITE PHOTOS:



CONTRACTOR INFORMATION:

Meraki Installers  
484-663-3792  
21 N New Warrington Rd  
Pensacola, FL 32507  
License # CVC57044

SITE INFORMATION

**Tyane & Roy Blake**  
571 Sw Atlas Dr  
Ft White, FL 32038  
AC SYSTEM SIZE: 10 kW AC  
DC SYSTEM SIZE: 9.9 kW DC  
Lat, 29.8580481  
Long, -82.6525851  
(30) Trina Solar TSM-DD06M.05(II) 330 PV  
MODULES  
(1) SolarEdge SE10000H-US (240V)  
INVERTER(S)  
Clay Electric Cooperative

DRAWN BY: SoloCAD

DATE:  
September 13, 2021

SITE PHOTOS - PV08



THE

# Residential Module

MULTI-BUSBAR120 HALF-CELL BOB MODULE



## 120-Cell MONOCRYSTALLINE MODULE

**330 W**  
POWER OUTPUT RANGE

**19.6%**  
MAXIMUM EFFICIENCY

**-5W+3%**  
POSITIVE POWER TOLERANCE

Founded in 1997, Trina Solar is the world's leading comprehensive solutions provider for solar energy, we believe close cooperation with our partners is critical to success. Trina Solar now distributes its PV products to over 60 countries all over the world. Trina is able to provide exceptional service to each customer in each market and supplement our innovative, reliable products with the backing of Trina as a strong, bankable partner. We are committed to building strategic, mutually beneficial collaboration with installers, developers, distributors and other partners.

### Comprehensive Products And System Certificates

UL 61730  
IEC61215/IEC61730/UL1703/IEC61701/IEC62716  
ISO 9001: Quality Management System  
ISO 14001: Environmental Management System  
ISO14064: Greenhouse gases Emissions Verification  
OHSAS 18001: Occupation Health and Safety Management System



PRODUCTS	BACKSHEET COLOR	POWER RANGE
TSM-DD06M.05(II)	Black	330W
FRAME COLOR: Black		



### High power output

- Reduce BOS cost with high power bin and 1000V system voltage
- New cell string layout and split J-box location reduces the energy loss caused by inter-row shading
- Lower resistance of half-cut cells and increased MBB (Multi Busbar) reflectance ensure higher power



### High energy generation, low LCOE

- Excellent 3rd party validated IAM and low light performance with cell process and module material optimization
- Low Pmax temp coefficient (-0.36%) increases energy production
- Better anti-shading performance and lower operating temperature



### Outstanding visual appearance, easy to install

- Designed for superior rooftop aesthetics
- Thinner wires give an eye catching all black look
- Safe and easy to transport, handle, and install



### Certified to perform in highly challenging environments

- High PID resistance through cell process and module material control
- Resistant to salt, acid, sand, and ammonia
- Over 30 in-house tests (UV, TC, HF etc)
- Certified to 5400 Pa positive load and 2400 Pa negative load

### PERFORMANCE WARRANTY




10 Year Product Warranty · 25 Year Power Warranty




## Residential Module

MULTI-BUSBAR 120 HALF-CELL BOB MODULE


DIMENSIONS OF PV MODULE(mm)



I-V CURVES OF PV MODULE (330W)



P-V CURVES OF PV MODULE (330W)



### ELECTRICAL DATA (STC)

Peak Power Watts-P <sub>MAX</sub> (Wp)*	330
Power Output Tolerance-P <sub>MAX</sub> (W)	-5 + 3%
Maximum Power Voltage-V <sub>MPP</sub> (V)	33.8
Maximum Power Current-I <sub>MPP</sub> (A)	9.76
Open Circuit Voltage-V <sub>OC</sub> (V)	40.6
Short Circuit Current-I <sub>SC</sub> (A)	10.40
Module Efficiency η <sub>m</sub> (%)	19.6

STC: Irradiance 1000W/m², Cell Temperature 25°C, Air Mass AM1.5.  
\*Measuring tolerance: ±3%.

### ELECTRICAL DATA (NMOT)

Maximum Power-P <sub>MAX</sub> (Wp)	250
Maximum Power Voltage-V <sub>MPP</sub> (V)	31.7
Maximum Power Current-I <sub>MPP</sub> (A)	7.86
Open Circuit Voltage-V <sub>OC</sub> (V)	38.3
Short Circuit Current-I <sub>SC</sub> (A)	8.38

NMOT: Irradiance at 800W/m², Ambient Temperature 20°C, Wind Speed 1m/s.

### MECHANICAL DATA

Solar Cells	Monocrystalline
Cell Orientation	120 cells (6 × 20)
Module Dimensions	1690 × 996 × 35 mm (66.54 × 39.21 × 1.38 inches)
Weight	18.0 kg (39.7 lb)
Glass	3.2 mm (0.13 inches), High Transmission, AR Coated Heat Strengthened
Encapsulant Material	Glass EVA
Backsheet	Black [DD06M.05(II)]
Frame	35 mm (1.38 inches) Anodized Aluminium Alloy
J-Box	IP 68 rated
Cables	Photovoltaic Technology Cable 4.0mm² (0.006 inches²) Portrait: N 140mm/P 285mm (5.51/11.22 inches) Landscape: N 1200 mm /P 1200 mm (47.24/47.24 inches)
Connector	MC4

### TEMPERATURE RATINGS

NMOT (Nominal Module Operating Temperature)	41°C (±3°C)
Temperature Coefficient of P <sub>MAX</sub>	-0.36%/°C
Temperature Coefficient of V <sub>OC</sub>	-0.26%/°C
Temperature Coefficient of I <sub>SC</sub>	0.04%/°C

(DO NOT connect Fuse in Combiner Box with two or more strings in parallel connection)

### WARRANTY

- 12 year Product Workmanship Warranty
- 25 year Power Warranty

(Please refer to product warranty for details)

### MAXIMUM RATINGS

Operational Temperature	-40~+85°C
Maximum System Voltage	1000V DC (IEC) 1000V DC (UL)
Max Series Fuse Rating	20A

### PACKAGING CONFIGURATION

- Modules per box: 30 pieces
- Modules per 40' container: 780 pieces



# Single Phase Inverter with HD-Wave Technology

for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US

12-25  
YEAR  
WARRANTY

INVERTERS



## Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking efficiency
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014 and 2017, per article 690.11 and 690.12
- UL1741 SA certified, for CPUC Rule 21 grid compliance
- Extremely small
- Built-in module-level monitoring
- Outdoor and indoor installation
- Optional: Revenue grade data, ANSI C12.20 Class 0.5 (0.5% accuracy)

solaredge.com

**solar**edge

## Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US

SE3000H-US   SE3800H-US   SE5000H-US   SE6000H-US   SE7600H-US   SE10000H-US   SE11400H-US								
OUTPUT								
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA
AC Output Voltage Min.-Nom.-Max. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	✓	Vac
AC Output Voltage Min.-Nom.-Max. (183 - 208 - 229)	-	✓	-	✓	-	-	✓	Vac
AC Frequency (Nominal)	59.3 - 60 - 60.5 <sup>(1)</sup>							Hz
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	A
Maximum Continuous Output Current @208V	-	16	-	24	-	-	48.5	A
GFDI Threshold	1							A
Utility Monitoring, Islanding Protection, Country Configurable Thresholds	Yes							
INPUT								
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W
Transformer-less, Ungrounded	Yes							
Maximum Input Voltage	480							Vdc
Nominal DC Input Voltage	380				400			Vdc
Maximum Input Current @240V <sup>(2)</sup>	8.5	10.5	13.5	16.5	20	27	30.5	Adc
Maximum Input Current @208V <sup>(2)</sup>	-	9	-	13.5	-	-	27	Adc
Max. Input Short Circuit Current	45							Adc
Reverse-Polarity Protection	Yes							
Ground-Fault Isolation Detection	600ka Sensitivity							
Maximum Inverter Efficiency	99	99.2						%
CEC Weighted Efficiency	99						99 @ 240V 98.5 @ 208V	%
Nighttime Power Consumption	< 2.5							W
ADDITIONAL FEATURES								
Supported Communication Interfaces	RS485, Ethernet, ZigBee (optional), Cellular (optional)							
Revenue Grade Data, ANSI C12.20	Optional <sup>(3)</sup>							
Rapid Shutdown - NEC 2014 and 2017 690.12	Automatic Rapid Shutdown upon AC Grid Disconnect							
STANDARD COMPLIANCE								
Safety	UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to T.I.L. M-07							
Grid Connection Standards	IEEE1547, Rule 21, Rule 14 (H)							
Emissions	FCC Part 15 Class B							
INSTALLATION SPECIFICATIONS								
AC Output Conduit Size / AWG Range	1" Maximum / 14-6 AWG					1" Maximum /14-4 AWG		
DC Input Conduit Size / # of Strings / AWG Range	1" Maximum / 1-2 strings / 14-6 AWG					1" Maximum / 1-3 strings / 14-6 AWG		
Dimensions with Safety Switch (HxWxD)	17.7 x 14.6 x 6.8 / 450 x 370 x 174					21.3 x 14.6 x 7.3 / 540 x 370 x 185		in / mm
Weight with Safety Switch	22 / 10		25.1 / 11.4		26.2 / 11.9		38.8 / 17.6	lb / kg
Noise	< 25				<50			dBA
Cooling	Natural Convection							
Operating Temperature Range	-13 to +140 / -25 to +60 <sup>(4)</sup> (-40°F / -40°C option) <sup>(5)</sup>							°F / °C
Protection Rating	NEMA 4X (Inverter with Safety Switch)							

<sup>1)</sup> For other regional settings please contact SolarEdge support.  
<sup>2)</sup> A higher current source may be used; the inverter will limit its input current to the values stated.  
<sup>3)</sup> Revenue grade inverter P/N: SExxxxH-US000NNC2  
<sup>4)</sup> For power de-rating information refer to: <https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf>  
<sup>5)</sup> -40 version P/N: SExxxxH-US000NNU4

# Power Optimizer

For North America

P320 / P340 / P370 / P400 / P405 / P505



POWER OPTIMIZER

## PV power optimization at the module-level

- Specifically designed to work with SolarEdge inverters
- Up to 25% more energy
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch losses, from manufacturing tolerance to partial shading
- Flexible system design for maximum space utilization
- Fast installation with a single bolt
- Next generation maintenance with module-level monitoring
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)
- Module-level voltage shutdown for installer and firefighter safety

[solaredge.com](http://solaredge.com)



## Power Optimizer For North America

P320 / P340 / P370 / P400 / P405 / P505

Optimizer model (typical module compatibility)	P320 (for 60-cell modules)	P340 (for high-power 60-cell modules)	P370 (for higher-power 60 and 72-cell modules)	P400 (for 72 & 96-cell modules)	P405 (for thin film modules)	P505 (for higher current modules)	
INPUT							
Rated Input DC Power <sup>(1)</sup>	320	340	370	400	405	505	W
Absolute Maximum Input Voltage (Voc at lowest temperature)	48		60	80	125 <sup>(2)</sup>	87 <sup>(2)</sup>	Vdc
MPPT Operating Range	8 - 48		8 - 60	8 - 80	12.5 - 105	12.5 - 87	Vdc
Maximum Short Circuit Current (Isc)	11			10.1		14	Adc
Maximum DC Input Current	13.75			12.5		17.5	Adc
Maximum Efficiency	99.5						%
Weighted Efficiency	98.8					98.6	%
Overvoltage Category	II						
OUTPUT DURING OPERATION (POWER OPTIMIZER CONNECTED TO OPERATING SOLAREEDGE INVERTER)							
Maximum Output Current	15						Adc
Maximum Output Voltage	60				85		Vdc
OUTPUT DURING STANDBY (POWER OPTIMIZER DISCONNECTED FROM SOLAREEDGE INVERTER OR SOLAREEDGE INVERTER OFF)							
Safety Output Voltage per Power Optimizer	1 ± 0.1						Vdc
STANDARD COMPLIANCE							
EMC	FCC Part15 Class B, IEC61000-6-2, IEC61000-6-3						
Safety	IEC62109-1 (class II safety), UL1741						
Material	UL94 V-0 , UV Resistant						
RoHS	Yes						
INSTALLATION SPECIFICATIONS							
Maximum Allowed System Voltage	1000						Vdc
Compatible inverters	All SolarEdge Single Phase and Three Phase inverters						
Dimensions (W x L x H)	129 x 153 x 27.5 / 5.1 x 6 x 1.1			129 x 153 x 33.5 / 5.1 x 6 x 1.3	129 x 159 x 49.5 / 5.1 x 6.3 x 1.9	129 x 162 x 59 / 5.1 x 6.4 x 2.3	mm / in
Weight (including cables)	630 / 1.4			750 / 1.7	845 / 1.9	1064 / 2.3	gr / lb
Input Connector	Single or dual MC4 <sup>(3)</sup>						
Input Wire Length	0.16 / 0.52						m / ft
Output Wire Type / Connector	Double Insulated / MC4						
Output Wire Length	0.9 / 2.95		1.2 / 3.9				m / ft
Operating Temperature Range	-40 - +85 / -40 - +185						°C / °F
Protection Rating	IP68 / NEMA6P						
Relative Humidity	0 - 100						%

<sup>(1)</sup> Rated power of the module at STC will not exceed the optimizer "Rated Input DC Power". Modules with up to +5% power tolerance are allowed

<sup>(2)</sup> NEC 2017 requires max input voltage be not more than 80V

<sup>(3)</sup> For other connector types please contact SolarEdge

PV System Design Using a SolarEdge Inverter <sup>(4)(5)</sup>		Single Phase HD-Wave	Single phase	Three Phase 208V	Three Phase 480V	
Minimum String Length (Power Optimizers)	P320, P340, P370, P400	8		10	18	
	P405 / P505	6		13 (12 with SE3K)	14	
Maximum String Length (Power Optimizers)		25		25	50 <sup>(6)</sup>	
Maximum Power per String		5700 (6000 with SE7600-US - SE11400-US)	5250	6000 <sup>(7)</sup>	12750 <sup>(8)</sup>	W
Parallel Strings of Different Lengths or Orientations		Yes				

<sup>(4)</sup> For detailed string sizing information refer to: [http://www.solaredge.com/sites/default/files/string\\_sizing\\_na.pdf](http://www.solaredge.com/sites/default/files/string_sizing_na.pdf)

<sup>(5)</sup> It is not allowed to mix P405/P505 with P320/P340/P370/P400 in one string

<sup>(6)</sup> A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement

<sup>(7)</sup> For SE14.4KUS/SE43.2KUS: It is allowed to install up to 6,500W per string when 3 strings are connected to the inverter (3 strings per unit for SE43.2KUS) and when the maximum power difference between the strings is up to 1,000W

<sup>(8)</sup> For SE30KUS/SE33.3KUS/SE66.6KUS/SE100KUS: It is allowed to install up to 15,000W per string when 3 strings are connected to the inverter (3 strings per unit for SE66.6KUS/SE100KUS) and when the maximum power difference between the strings is up to 2,000W

© SolarEdge Technologies Ltd. All rights reserved. SOLAREEDGE, the SolarEdge logo, OPTIMIZED BY SOLAREEDGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: 07/2019/V01/ENG NAM. Subject to change without notice.



CE RoHS

# XR Rail Family

## Solar Is Not Always Sunny

Over their lifetime, solar panels experience countless extreme weather events. Not just the worst storms in years, but the worst storms in 40 years. High winds capable of ripping panels from a roof, and snowfalls weighing enough to buckle a panel frame.

XR Rails are the structural backbone preventing these results. They resist uplift, protect against buckling and safely and efficiently transfer loads into the building structure. Their superior spanning capability requires fewer roof attachments, reducing the number of roof penetrations and the amount of installation time.



**Force-Stabilizing Curve**  
Sloped roofs generate both vertical and lateral forces on mounting rails which can cause them to bend and twist. The curved shape of XR Rails is specially designed to increase strength in both directions while resisting the twisting. This unique feature ensures greater security during extreme weather and a longer system lifetime.

### Compatible with Flat & Pitched Roofs



XR Rails are compatible with FlashFoot and other pitched roof attachments.



IronRidge offers a range of tilt leg options for flat roof mounting applications.

### Corrosion-Resistant Materials

All XR Rails are made of 6000-series aluminum alloy, then protected with an anodized finish. Anodizing prevents surface and structural corrosion, while also providing a more attractive appearance.



## XR Rail Family

The XR Rail Family offers the strength of a curved rail in three targeted sizes. Each size supports specific design loads, while minimizing material costs. Depending on your location, there is an XR Rail to match.



### XR10

XR10 is a sleek, low-profile mounting rail, designed for regions with light or no snow. It achieves spans up to 6 feet, while remaining light and economical.

- 6' spanning capability
- Moderate load capability
- Clear & black anodized finish
- Internal splices available



### XR100

XR100 is the ultimate residential mounting rail. It supports a range of wind and snow conditions, while also maximizing spans up to 10 feet.

- 10' spanning capability
- Heavy load capability
- Clear & black anodized finish
- Internal splices available



### XR1000

XR1000 is a heavyweight among solar mounting rails. It's built to handle extreme climates and spans up to 12 feet for commercial applications.

- 12' spanning capability
- Extreme load capability
- Clear anodized finish
- Internal splices available

## Rail Selection

The table below was prepared in compliance with applicable engineering codes and standards.\* Values are based on the following criteria: ASCE 7-16, Gable Roof Flush Mount, Roof Zones 1 & 2e, Exposure B, Roof Slope of 8 to 20 degrees and Mean Building Height of 30 ft. Visit [IronRidge.com](http://IronRidge.com) for detailed certification letters.

Load		Rail Span					
Snow (PSF)	Wind (MPH)	4'	5' 4"	6'	8'	10'	12'
None	90	XR10		XR100		XR1000	
	120						
	140						
	160						
20	90						
	120						
	140						
	160						
30	90						
	160						
40	90						
	160						
80	160						
120	160						

\*Table is meant to be a simplified span chart for conveying general rail capabilities. Use approved certification letters for actual design guidance.





The right way to attach almost anything to metal roofs!

# S-5!® The Right Way!

## ProteaBracket™


ProteaBracket™ is the most versatile standing seam metal roof attachment solution on the market, fitting most trapezoidal sheet profiles with and without intermediate insulation. It features an adjustable attachment base and multiple solar module attachment options (illustrated on back) to accommodate varying widths and heights. There are no messy sealants to apply and no chance for leaks; the ProteaBracket comes with factory-applied, adhesive rubber sealant to ensure quick installation and a weather-proof fit.

Installation is simple! The ProteaBracket is mounted directly onto the crown of the panel, straddling the profile. No surface preparation is necessary; simply wipe away excess oil and debris, align, and apply. Secure ProteaBracket through its pre-punched holes, using the hardened drill point S-5!® screws.

ProteaBracket is the perfect match for our S-5-PV Kit and spares you the hassle of cold-bridging! For a solar attachment solution that is both economical and easy to use, choose ProteaBracket.\*

\*When ProteaBracket is used in conjunction with the S-5-PV Kit, an additional nut is required during installation.

S-5!® ProteaBracket™ is a versatile bracket that adjusts easily to most trapezoidal roof profiles.



ProteaBracket™

888-825-3432 | www.S-5.com

# S-5!®

The Right Way!

ProteaBracket™ is the perfect solar attachment solution for most trapezoidal exposed-fastened metal roof profiles! No messy sealants to apply. The factory-applied adhesive rubber sealant weather-proofs and makes installation easy!

Each **ProteaBracket™** comes with a factory-applied, adhesive rubber sealant on the base. A structural A2 stainless steel bimetal attachment bracket, ProteaBracket is compatible with most common metal roofing materials. All four pre-punched holes must be used to achieve tested strength. Mounting hardware is furnished with the ProteaBracket. For design assistance, ask your distributor, or visit [www.S-5.com](http://www.S-5.com) for the independent lab test data that can be used for load-critical designs and applications. Also, please visit our website for more information including metallurgical compatibilities and specifications. S-5!® holding strength is unmatched in the industry.

### Multiple Attachment Options:

Side Rail Option




Top Rail Option



S-5-PV Kit Option




## ProteaBracket™



Please note: All measurements are rounded to the second decimal place.

### Example Applications



S-5-PV Kit demonstrated with a ProteaBracket on a trapezoidal profile.

### Example Profile



### S-5!® Warning! Please use this product responsibly!

Products are protected by multiple U.S. and foreign patents. For published data regarding holding strength, bolt torque, patents, and trademarks, visit the S-5! website at [www.S-5.com](http://www.S-5.com).

Copyright 2013, Metal Roof Innovations, Ltd. S-5! products are patent protected. S-5! aggressively protects its patents, trademarks, and copyrights. Version 112513.

Distributed by