



August 1, 2018

Aaron Simque Homes
Lake City, FL 32025

Subject: Permit # 36824 - Lot 4, Preserve at Laurel Lakes - Elevation Letter

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 4, Preserve at Laurel Lakes, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 116.2'.
- The top of the concrete foundation slab is at 116.7', being 0.5' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM