



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

06/10/2024

L-30469

Permit # 000049820

Re: Lot 20 Woods at Falling Creek

Yasminis Reyes-Jorge

To Whom It May Concern:

The finished floor elevation on Lot 20 is found to be 143.50 feet. The building permit states that the MFE will be above 142' feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

L. Scott Britt
LS 5757