



Columbia County

BUILDING DEPARTMENT

Revised 12/2023

COMMERCIAL MINIMUM PLAN CHECKLIST

MINIMUM PLAN REQUIREMENTS AND CHECKLIST FOR THE 2023 FLORIDA BUILDING CODE ,FLORIDA PLUMBING CODE,FLORIDA MECHANICAL CODE,FLORIDA FUEL AND GAS CODE 2023 EFFECTIVE 1 JAN 2023 AND 2020 NATIONAL ELECTRICAL

ALL REQUIREMENTS ARE SUBJECT TO CHANGE

ALL BUILDING PLANS MUST INDICATE COMPLIANCE WITH THE CURRENT FLORIDA BUILDING CODES. ALL PLANS OR DRAWING SHALL PROVIDED CALCULATIONS AND DETAILS THAT HAVE THE SEAL AND SIGNATURE OF A CERTIFIED ARCHITECT OR ENGINEER REGISTERED IN THE STATE OF FLORIDA, OR ALTERNATE METHODOLOGIES, APPROVED BY THE STATE OF FLORIDA BUILDING COMMISSION.

FOR DESIGN PURPOSES THE FOLLOWING BASIC WIND SPEEDS ARE PER FLORIDA BUILDING CODE FIGURE 1609.3 (1) THROUGH (4) ULTIMATE DESIGN WIND SPEEDS FOR RISK CATEGORY AND BUILDINGS AND OTHER STRUCTURES

GENERAL REQUIREMENTS:		Items to Include Each Box shall be Marked as Applicable		
1	All drawings must be clear, concise and drawn to scale, details that are not used shall be marked void.	<input checked="" type="radio"/> YES	<input type="radio"/> NO	<input type="radio"/> N/A
2	If the design professional is an architect or engineer legally registered under the laws of this state regulating the practice of architecture as provided for in Chapter 481, Florida Statutes, Part I, or engineering as provided for in Chapter 471, Florida Statutes, then he or she shall affix his or her official seal to said drawings, specifications and accompanying data, as required by Florida Statute.	<input checked="" type="radio"/> YES	<input type="radio"/> NO	<input type="radio"/> N/A
3	The design professional signature shall be affixed to the plans	<input checked="" type="radio"/> YES	<input type="radio"/> NO	<input type="radio"/> N/A
4	Two (2) complete sets of plans with the architecture or engineer signature and the date the affix embossed official seal was placed on the plans	<input checked="" type="radio"/> YES	<input type="radio"/> NO	<input type="radio"/> N/A

Two (2) complete sets of plans containing the following information:

Building Site Plan Requirements		Items to Include- Each Box shall be Marked as Applicable		
4	Parking, including provision Florida Building Code Accessibility Code	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
5	Fire access, showing all drive way which will be accessible for emergency vehicles	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
6	Driving/turning radius of parking lots	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
7	Vehicle loading include truck dock loading or rail site loading	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
8	Nearest or number of onsite Fire hydrant/water supply/post indicator valve (PIV)	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A
9	Set back of all existing or proposed structures from each structure and property boundaries, Show all separation including assumed property lines	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A
10	Location of specific tanks(above or under grown ,water lines and sewer lines and septic tank and drain fields	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A

11	All structures exterior views include finished floor elevation						<input checked="" type="radio"/> Yes	No	N/A	-	
12	Total height of structure(s) form established grade						<input checked="" type="radio"/> Yes	No	N/A	-	
<p align="center">Review required by the Columbia County Fire Department Items 13th 43 (We Contact the Fire Inspector For You.)</p>											
Occupancy group use circle all uses:		Group A	Group B	Group E	Group F	Group H	Group I	<input checked="" type="radio"/> Group M	Group R	Group S	Group U D
13	Special occupancy requirements.						Yes	No	<input checked="" type="radio"/> N/A	-	
14	Incidental use areas (total square footage for each room of use area)						Yes	<input checked="" type="radio"/> No	N/A	-	
15	Mixed occupancies						<input checked="" type="radio"/> Yes	No	N/A	-	
16	REQUIRED SEPARATION OF OCCUPANCIES IN HOURS FBC TABLE 707.3.10						<input checked="" type="radio"/> Yes	No	N/A	-	
Minimum type of permitted construction by code for occupancy use circle the construction type FBC 602											
17	Type I (FBC:602.2)	Type II (FBC:602.2)	<input checked="" type="radio"/> Type III (FBC:602.3)	Type IV (FBC:602.4)	Type V (FBC:602.5)						

Fire-resistant construction requirements shall be shown, include the following components										
18	Fire-resistant separations						Yes	No	<input checked="" type="radio"/> N/A	-
19	Fire-resistant protection for type of construction						Yes	No	<input checked="" type="radio"/> N/A	-
20	Protection of openings and penetrations of rated walls						Yes	No	<input checked="" type="radio"/> N/A	-
21	Protection of corridors and penetrations of rated walls						Yes	No	<input checked="" type="radio"/> N/A	-
22	Fire blocking and draftstopping and calculated fire resistance						Yes	No	<input checked="" type="radio"/> N/A	-
Fire suppression systems shall be shown include:										
23	Early warning smoke evacuation systems Schematic fire sprinklers Standpipes						Yes	No	<input checked="" type="radio"/> N/A	-
24	Standpipes						Yes	No	<input checked="" type="radio"/> N/A	-
25	Pre-engineered systems						Yes	No	<input checked="" type="radio"/> N/A	-
26	Riser diagram						Yes	No	<input checked="" type="radio"/> N/A	-
Life safety systems shall be shown include the following requirements:										
27	Occupant load and egress capacities						Yes	No	<input checked="" type="radio"/> N/A	-
28	Early warning						Yes	No	<input checked="" type="radio"/> N/A	-
29	Smoke control						Yes	No	<input checked="" type="radio"/> N/A	-
30	Stair pressurization						Yes	No	<input checked="" type="radio"/> N/A	-
31	Systems schematic						Yes	No	<input checked="" type="radio"/> N/A	-
Occupancy load/egress requirements shall be shown include:										
32	Occupancy load						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
33	Gross occupancy load						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
34	Net occupancy load						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
35	Means of egress						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
36	Exit access						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
37	Exit discharge						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
38	Stairs construction/geometry and protection						Yes	No	<input checked="" type="radio"/> N/A	-
39	Doors						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
40	Emergency lighting and exit signs						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-
41	Specific occupancy requirements						<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	-

42	Construction requirements	Yes	No	N/A	-
43	Horizontal exits/exit passageways	Yes	No	N/A	-

Items to Include
 Each Box shall be
 Marked as
 Applicable

Structural requirements shall be shown include:					
44	Soil conditions/analysis	Yes	No	N/A	-
45	Termite protection	Yes	No	N/A	-
46	Design loads	Yes	No	N/A	-
47	Wind requirements	Yes	No	N/A	-
48	Building envelope	Yes	No	N/A	-
49	Structural calculations (if required)	Yes	No	N/A	-
50	Foundation For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3	Yes	No	N/A	-
51	Wall systems	Yes	No	N/A	-
52	Floor systems	Yes	No	N/A	-
53	Roof systems	Yes	No	N/A	-
54	Threshold inspection plan	Yes	No	N/A	-
55	Stair systems	Yes	No	N/A	-
Materials shall be shown include the following					
56	Wood	Yes	No	N/A	-
57	Steel	Yes	No	N/A	-
58	Aluminum	Yes	No	N/A	-
59	Concrete	Yes	No	N/A	-
60	Plastic	Yes	No	N/A	-
61	Glass	Yes	No	N/A	-
62	Masonry	Yes	No	N/A	-
63	Gypsum board and plaster	Yes	No	N/A	-
64	Insulating (mechanical)	Yes	No	N/A	-
65	Roofing	Yes	No	N/A	-
66	Insulation	Yes	No	N/A	-
Accessibility requirements shall be shown include the following					
67	Site requirements	Yes	No	N/A	-
68	Accessible route	Yes	No	N/A	-
69	Vertical accessibility	Yes	No	N/A	-
70	Toilet and bathing facilities	Yes	No	N/A	-
71	Drinking fountains	Yes	No	N/A	-
72	Equipment	Yes	No	N/A	-
73	Special occupancy requirements	Yes	No	N/A	-
74	Fair housing requirements	Yes	No	N/A	-

Interior requirements shall include the following					
75	Review required by the Columbia County Fire Department Items 75 th 80	Yes	No	N/A	-
	Interior finishes (flame spread/smoke development)				
76	Light and ventilation	Yes	No	N/A	-
77	Sanitation	Yes	No	N/A	-
Special systems					
78	Elevators	Yes	No	N/A	-
79	Escalators	Yes	No	N/A	-
80	Lifts	Yes	No	N/A	-
Swimming pools					
81	Barrier requirements	Yes	No	N/A	-
82	Spas and Wading pools	Yes	No	N/A	-
83	Access required per Florida Building Code 454.1.2.5	Yes	No	N/A	-

Items to Include-Each Box shall be Circled as Applicable					
Electrical					
84	Wiring	Yes	No	N/A	-
85	Services For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3	Yes	No	N/A	-
86	Feeders and branch circuits	Yes	No	N/A	-
87	Overcurrent protection	Yes	No	N/A	-
88	Grounding	Yes	No	N/A	-
89	Wiring methods and materials	Yes	No	N/A	-
90	GFCIs	Yes	No	N/A	-
91	Equipment	Yes	No	N/A	-
92	Special occupancies	Yes	No	N/A	-
93	Emergency systems	Yes	No	N/A	-
94	Communication systems	Yes	No	N/A	-
95	Low voltage	Yes	No	N/A	-
96	Load calculations	Yes	No	N/A	-
Plumbing					
97	Minimum plumbing facilities	Yes	No	N/A	-
98	Fixture requirements	Yes	No	N/A	-
99	Water supply piping	Yes	No	N/A	-
100	Sanitary drainage	Yes	No	N/A	-
101	Water heaters	Yes	No	N/A	-
102	Vents	Yes	No	N/A	-
103	Roof drainage	Yes	No	N/A	-
104	Back flow prevention	Yes	No	N/A	-

105	Irrigation	Yes	No	N/A	-
106	Location of water supply line	Yes	No	N/A	-
107	Grease traps	Yes	No	N/A	-
108	Environmental requirements	Yes	No	N/A	-
109	Plumbing riser	Yes	No	N/A	-
Mechanical					
110	Energy calculations	Yes	No	N/A	-
111	Review required by the Columbia County Fire Department Items 111th 114 Exhaust systems	Yes	No	N/A	-
112	Clothes dryer exhaust	Yes	No	N/A	-
113	Kitchen equipment exhaust	Yes	No	N/A	-
114	Specialty exhaust systems	Yes	No	N/A	-
Equipment location					
115	Make-up air	Yes	No	N/A	-
116	Roof-mounted equipment	Yes	No	N/A	-
117	Duct systems	Yes	No	N/A	-
118	Ventilation	Yes	No	N/A	-
119	Laboratory	Yes	No	N/A	-
120	Combustion air	Yes	No	N/A	-
121	Chimneys, fireplaces and vents	Yes	No	N/A	-
122	Appliances	Yes	No	N/A	-
123	Boilers	Yes	No	N/A	-
124	Refrigeration	Yes	No	N/A	-
125	Bathroom ventilation	Yes	No	N/A	-
Items to Include- Each Box shall be Marked as Applicable					
Gas					
126	Review required by the Columbia County Fire Department Items 126th 134 Gas piping	Yes	No	N/A	-
127	Venting	Yes	No	N/A	-
128	Combustion air	Yes	No	N/A	-
129	Chimneys and vents	Yes	No	N/A	-
130	Appliances	Yes	No	N/A	-
131	Type of gas	Yes	No	N/A	-
132	Fireplaces	Yes	No	N/A	-
133	LP tank location	Yes	No	N/A	-
134	Riser diagram/shutoffs	Yes	No	N/A	-
Notice of Commencement					
135	A recorded (in the Columbia County Clerk Office) notice of commencement is required to be on file with the building department . <i>Before Any Inspections Will Be Done</i>	Yes	No	N/A	-
Disclosure Statement for Owner Builders					
		Yes	No	N/A	-

Private Potable Water						
136	Horse power of pump motor	SEE PAGE 7- ON HOW TO PROVIDE THIS DOCUMENTATION.	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-
137	Capacity of pressure tank		<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-
138	Cycle stop valve if used		<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-
						Items to Include- Each Box shall be Marked as Applicable

THE FOLLOWING ITEMS MUST BE SUBMITTED WITH BUILDING PLANS

139	Building Permit Application	A Building Permit Application is to be completed by following the checklist all supporting documents must be submitted. Completed Applications can be mailed with The \$15.00 application fee.	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-
140	Parcel Number	The parcel number (Tax ID number) from the Property Appraiser is required. A copy of property deed is also required. (386) 758-1084	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-
141	Environmental Health Permit or Sewer Tap Approval	A copy of an approved Environmental Health (386) 758-1058 waste water disposal permit or an approved City of Lake City (386) 752-2031 OR County sewer tap letter is required before a building permit can be issued. Toilet facilities shall be provided for construction workers	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-
142	Driveway Connection	If the property does not have an existing access to a public road, then an application for a culvert permit must be made (\$25.00). County Public Works Dept. determines the size and length of every culvert before installation and completes a final inspection before permanent power is granted. Culvert installation for commercial, industrial and other uses shall conform to the approved site plan or to the specifications of a registered engineer. Use or joint use of driveways will comply with Florida Department of Transportation specifications. If the project is to be located on an F.D.O.T. maintained road, then an F.D.O.T. access permit is required.	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A	-
143	Suwannee River Water Management District Approval	All commercial projects must have an SRWMD permit issued or an exemption letter, before a building permit will be issued.	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A	-
144	Flood Management	All projects within the Floodway of the Suwannee or Santa Fe Rivers shall require permitting through the Suwannee River Water Management District, before submitting application to this office. Any project located within a flood zone where the base flood elevation (100 year flood) has been established shall meet the requirements of section 8.8 of the Columbia County Land Development Regulations. Any project that is located within a flood zone where the base flood elevation (100 year flood) has not been established shall meet the requirements of section 8.7 of Columbia County Land Development Regulations. A development permit will also be required. The development permit cost is \$50.00	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A	-
145	Flood Management	A CERTIFIED FINISHED FLOOR ELEVATIONS WILL BE REQUIRED ON ANY PROJECT WHERE THE BASE FLOOD ELEVATION (100 YEAR FLOOD) HAS BEEN ESTABLISHED OR IT HAS BEEN DETERMINED BY THE PLAT	<input type="radio"/> Yes	<input type="radio"/> No	<input checked="" type="radio"/> N/A	-
146	911 Address	An application for a 911 address must be applied for and received through the Columbia County 911 Addressing Department by applying online.	<input checked="" type="radio"/> Yes	<input type="radio"/> No	<input type="radio"/> N/A	-