



Florida Pest Control

536 SE Baya Dr.

Lake City, FL 32025

800-488-9495

STROUBE LANDER
144 SW BEACON WAY
LAKE CITY, FL 32025

Termite Treatment Certification

☒ Partial

☐ Final

Owner:	Permit Number:
Lot:	Block:
Subdivision:	Street Address: 144 SW BEACON WAY
City: LAKE CITY	County: COLUMBIA
General Contractor: STROUBE LANDER	Area Treated: Exterior Perimeter
Date: 5/12/25	Time: 14:00
Name of Applicator: ROBERT OLSON	Applicator ID Number: JE282681
Product Used / Active Ingredient / % Concentration Premise / Imidacloprid / 0.1%	Number of gallons used: 250
Method of termite prevention treatment: Soil Treatment	

The above noted structure has received the initial required treatment for the prevention of subterranean termites. If a soil treatment was performed, the perimeter of the above structure must be treated after the final grade has been established in accordance with the pesticide label and Florida Statute.

This form should not be accepted as proof of complete treatment for Certificate of Occupancy or Closing.
This form is for inspection, construction, and financial draw purposes only.

Notice to Builder

If a soil treatment was performed, it is the responsibility of the builder to notify Florida Pest Control & Chemical Co. prior to the pouring of any slab that abuts the above structure so that treatment can be completed and the required paperwork for closing be submitted. Such slabs might be, but are not limited to: patios, porches, entryways, A/C pads, stoops, additions, bay windows, driveway aprons, etc.

Other areas that would require treatment would be:

1. Areas within the foundation fill that were disturbed after the initial treatment.
2. The foundation perimeter after final grade has been established.

THIS IS NOT PROOF OF WARRANTY

Warranty and treatment certification will be issued upon completion of final treatment only.

Authorized Signature:

mbacon

Date:

5/13/25