

FIELD DENSITY WORKSHEET

CLIENT Maronda Homes DATE 5-14-25
 PROJECT NAME Forest Cove Lot 5 PROJECT NO. _____
 EARTH CONTRACTOR 282 SW Caydence Glen Lake City PERMIT NO. _____
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor TESTED BY ce
☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 15' NE of SW corner	1130	9.7	F.G	12"	3.9	1155	111.2	98.4
17'2" of Pad	1	1	1	1	4.3	1168	1120	99.1
15' SW of NE corner	1	1	1	1	3.5	104.1	110.3	97.6

REMARKS _____

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.