

FIELD DENSITY WORKSHEET

CLIENT Red Door Homes DATE 3-15-23
 PROJECT NAME 353 SW Gideon Pl. Fort White PROJECT NO. _____
 EARTH CONTRACTOR _____ PERMIT NO. _____
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor TESTED BY ce
☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☒ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
15' PE of SW corner	108.8	9.9	FL	12"	46	1132	1083	995
15' SW of NE corner	1	1	1	1	41	1112	1068	982
12' of EAST Footing	1	1	1	1	43	1122	1076	989

REMARKS _____

- * Density failed to meet minimum project requirement
- ** Retest indicates minimum density requirement was obtained.
- () Client is aware of unsatisfactory test results.