2894

juris luzins architect AR 0007907

Chief Building Official Columbia County

18 Nov., 2009

Sincerely,

RE: New Residence Summer's Acres Lot 2 Permit Number 28947 Sutton Family Homes

To Whom It May Concern,

The following items are submitted to clarify the referenced permit:

2-5/8" dia. bolts required at each LVL to steel beam connection

Anchor bolts to column base plates approved as installed for dead load and uplift combination.

Sheathing can be deleted and dense glass only installed on none shear wall designated walls.

If wall designated as shear wall is modified or deleted, an additional wall for shear resistance must be choosen with equal or greater length. If this cannot be accomplished, contact this office for field directive.

See attached drawing for concrete grade beam at Lania.

9320 nw 13th place • gainesville, fl • 32606 352-224-8673 • jurisluzins@cox.net