



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

09/24/2021

Permit # 000040766

L-27917

D & G Properties of Columbia County

Re: Lot 18 Star Lake

To Whom It May Concern:

The top of the finished slab on said Lot 18 is 164.3 feet. The centerline of NW Mercury Drive in the center of the Cul-De-Sac is found to be 163 feet. The permit shows the minimum required floor elevation to be one foot above the existing road.. The elevations shown hereon are based on assumed datum.

Sincerely,



L. Scott Britt
LS 5757