



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

9/02/2020

Permit # 000039643

Lot 6 Meadow Wood

L-26910

Bryan Zecher Construction

To whom it may concern,

The elevation of the top of the slab on said lot 6 is found to be 8" above the highest adjacent grade. The minimum floor elevation is shown to be 163.0 or 8" above the highest adjacent grade per the permit.

Sincerely,

L. Scott Britt
LS 5757