From:
 Chad Williams

 fo:
 ITOV CZEWS

 cc:
 Melssa Garber; Patrick Weaver

 Subject:
 RE: Agro Liquid - 70517

 Date:
 Tuesday, May 27, 2025 8:40:46 AM

 attachments:
 imaee002.png

 imaep02.png
 imaee002.png

Troy,


I reviewed the application per the portal on 5/1/2025. I approved the 'connection with county roadway' portion of the permit and entered a note.

## Per my entered note:

Please submit site plan information, driveway connection plan, trip generation calculations and other pertinent driveway connection information.

The site plan information was uploaded 5/8/2025 under the mistitled info as "proof of easement documentation" but no trip generation calcs were uploaded. THIS HAS NOT BEEN DONE as of 5/27/2025 at 8:21am


These are the current uploaded documents in the driveway/application portal:



I am ok with getting them their 911 address and building permit so they can start, but I need trip generation calculations to permit the connection.

## I do have one comment on the plans

1. Please relocate the 3000-gallon septic tank from the proposed county right of way and place it on private property. Sheet C-208



Chad

From: Troy Crews <tcrews@columbiacountyfla.com>

Sent: Monday, May 19, 2025 7:29 AM

To: Chad Williams < cwilliams@columbiacountyfla.com>

Cc: Melissa Garber <mgarber@columbiacountyfla.com>

Subject: Agro Liquid

Chad, how are we looking on the access permit for them, I am trying to get this permitted this week thanks.

Troy Crews Building and Zoning Director C.B.O. BU-1766

Please note that electronic mail sent or received by elected officials or staff for Columbia County may be public records in accordance with Chapter 119, Florida Statutes The information contained in this transmission may contain information that is privileged, confidential or otherwise protected under State and Federal law. It is intended only for the use of the person(s) named above. If you have received this communication in error, please delete this email, destroy any hard copies thereof, and notify the sender immediately.

