



Project Summary
Entire House
E-Calcs Plus, Inc

Job: Davis - XXX TBD
 Date: Nov 17, 2025
 By: E-Calcs Plus, Inc

Serving all of Florida Phone 833 322 5271 Email eric@ecalcsplus.com Web www.ecalcsplus.com License HERS Rater ID# 0757810

Project Information

For Davis - XXX TBD
 XXX, Lake Cty, FL 32064

Notes

Design Information

Weather Gainesville Rgnl, FL, US

Winter Design Conditions

Outside db 33 °F
 Inside db 70 °F
 Design TD 37 °F

Ventilation Method ASHRAE 62 2-2010

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 47 gr/lb

Heating Summary

Structure 11395 Btuh
 Ducts 0 Btuh
 Central vent (0 cfm) 0 Btuh
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 11395 Btuh

Infiltration

Method Simplified
 Construction quality Semi-tight
 Fireplaces 0

	Heating	Cooling
Area (ft²)	660	660
Volume (ft³)	6600	6600
Air changes/hour	0.41	0.22
Equiv AVF (cfm)	45	24

Heating Equipment Summary

Make Daikin
 Trade DAIKIN
 Model 2MX18AXVU
 AHRI ref 207216088
 Efficiency 9 HSPF2
 Heating input 17000 Btuh @ 47°F
 Heating output 33 °F
 Temperature rise 467 cfm
 Actual air flow 0.041 cfm/Btuh
 Air flow factor 0.50 in H2O
 Static pressure
 Space thermostat
 Capacity balance point = 20 °F

Sensible Cooling Equipment Load Sizing

Structure 12257 Btuh
 Ducts 0 Btuh
 Central vent (0 cfm) 0 Btuh
 Blower 0 Btuh
 Use manufacturer's data y
 Rate/swing multiplier 1.00
 Equipment sensible load 12257 Btuh

Latent Cooling Equipment Load Sizing

Structure 1168 Btuh
 Ducts 0 Btuh
 Central vent (0 cfm) 0 Btuh
 Equipment latent load 1168 Btuh
Equipment Total Load (Sen+Lat) 13424 Btuh
 Req total capacity at 0.80 SHR 1.3 ton

Cooling Equipment Summary

Make Daikin
 Trade DAIKIN
 Cond 2MX18AXVU
 Coil 2 ea CTX07AXVJU
 AHRI ref 207216088
 Efficiency 10.0 EER2, 17 SEER2
 Sensible cooling 13600 Btuh
 Latent cooling 3400 Btuh
 Total cooling 17000 Btuh
 Actual air flow 467 cfm
 Air flow factor 0.038 cfm/Btuh
 Static pressure 0.50 in H2O
 Load sensible heat ratio 0.91

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed




wrightsoft

Right-Suite® Universal 2025 25 0 03 RSU63879


Davis - XXX TBD\Davis XXX TBD 11 20 2025 rup Calc = MJ8 Front Door faces E

2025-Nov-21 12:40:13

Page 1



First Floor



Job #: Davis - XXX TBD
Performed by E-Calcs Plus, Inc for:
Davis - XXX TBD
XXX
Lake City FL 32064

E-Calcs Plus, Inc
Serving all of Florida
Phone 833 322 5271 License HERS Rater ID# 07
www.ecalcsplus.com eric@ecalcsplus.com

Scale 1 : 45
Page 1
Right-S uite® Universal 2025
25 0 03 RSU63879
2025-Nov-21 12 40 22
D:\Davis - XXX TBD 11 20 2025



Static Pressure and Friction Rate
Entire House
E-Calcs Plus, Inc

Job: Davis - XXX TBD
 Date: Nov 17, 2026
 By: E-Calcs Plus, Inc

Serving all of Florida Phone 833 322 5271 Email eric@ecalcsplus.com Web www.ecalcsplus.com License HERS Rater ID# 0757810

Project Information

For Davis - XXX TBD
 XXX, Lake City, FL 32064

Available Static Pressure

	Heating (in H2O)	Cooling (in H2O)
External static pressure	0 50	0 50
Pressure losses		
Coil	0	0
Heat exchanger	0	0
Supply diffusers	0 03	0 03
Return grilles	0 03	0 03
Filter	0 10	0 10
Humidifier	0	0
Balancing damper	0	0
Other device	0	0
Available static pressure	0 34	0 34

Total Effective Length

	Supply (ft)	Return (ft)
Measured length of run-out	0	0
Measured length of trunk	0	0
Equivalent length of fittings	0	0
Total length	0	0
Total effective length	0	0

Friction Rate

	Heating (in/100ft)	Cooling (in/100ft)
Supply Ducts	0 < 0 06	0 < 0 06
Return Ducts	0 < 0 06	0 < 0 06

Fitting Equivalent Length Details

Supply TotalEL=0
 Return TotalEL=0



Manual S Compliance Report
Entire House
E-Calcs Plus, Inc

Job: Davis - XXX TBD
 Date: Nov 17, 2025
 By: E-Calcs Plus, Inc

Serving all of Florida Phone 833 322 5271 Email eric@ecalcsplus.com Web www.ecalcsplus.com License HERS Rater ID# 0757810

Project Information

For Davis - XXX TBD
 XXX, Lake City, FL 32064

Cooling Equipment

Design Conditions

Outdoor design DB	91 9°F	Sensible gain	12257	Btuh	Entering coil DB	75 0°F
Outdoor design WB	76 2°F	Latent gain	1168	Btuh	Entering coil WB	62 5°F
Indoor design DB	75 0°F	Total gain	13424	Btuh		
Indoor RH	50%	Estimated airflow	467	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type	Split ASHP			
Manufacturer	Daikin	Model	2MX18AXVU+2 ea CTX07AXVJU	
Actual airflow	467	cfm		
Sensible capacity	13877	Btuh	113% of load	
Latent capacity	1334	Btuh	114% of load	
Total capacity	15211	Btuh	113% of load SHR 91%	

Heating Equipment

Design Conditions

Outdoor design DB	33 0°F	Heat loss	11395	Btuh	Entering coil DB	70 0°F
Indoor design DB	70 0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type	Split ASHP			
Manufacturer	Daikin	Model	2MX18AXVU+2 ea CTX07AXVJU	
Actual airflow	467	cfm		
Output capacity	17000	Btuh	149% of load	
Supplemental heat required	0	Btuh		
			Capacity balance	20 °F
			Economic balance	-99 °F

Meets all requirements of ACCA Manual S

