



ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
7540 103rd St Suite 215 • Jacksonville, FL 32210

Lake City • (386) 755-3633

Fax • (386) 752-5456

Jacksonville • (904) 381-8901

Fax • (904) 381-8902

JOB NO.:
DATE TESTED: / /

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: _____ (D-2922) Nuclear _____ (D-2937) Drive Cylinder _____ Other

PROJECT _____

CLIENT _____

GENERAL CONTRACTOR _____ EARTHWORK CONTRACTOR _____

SOIL USE (SEE NOTE) _____ SPECIFICATION REQUIREMENTS _____

TECHNICIAN _____

MODIFIED (ASTM D-1557) _____ STANDARD (ASTM D-698) _____

TEST NO.	TEST LOCATION	TEST	PROCTOR NO.	WET DENS LBS. CU. FT.	DRY DENS LBS. CU. FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH ELEV LIFT					
		1	1	1	1	1	1
		1	1	1	1	1	1
		1	1	1	1	1	1

REMARKS _____

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
		1	

NOTE 1 Building Fill 2 Trench Backfill 3 Base Course 4 Subbase/Stabilized Subgrade 5 Embankment 6 Subgrade/Natural Soil 7 Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.