

November 18th, 2025

Columbia County Building & Zoning Department
135 NE Hernando Ave
Lake City, FL 32055

**RE: Hill & Smith Inc. Building Addition – Parcel #13-3S-16-02097-000
Stormwater/Drainage Analysis**

To whom it may concern,

I have reviewed the building addition plans provided by Reed McDaniel Construction, Inc. for the 624sf addition to an existing metal building located at 2118 NW County Road 25A, Lake City, FL 32055 for compliance with the County's stormwater management requirements. My findings are summarized below.

The new addition will be constructed over an existing concrete slab. The new building addition will not increase the amount of impervious surfaces on site and therefore will have no effect on current drainage patterns, nor cause an increase in surface runoff following storm events. There will be no adverse flooding effects created due to construction of this building addition.

I find this building addition construction, as presented, to be in conformance with Columbia County's stormwater management requirements.

Respectfully,

Travis Covington, P.E.
License No. 89637



THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED
BY TRAVIS COVINGTON, P.E. ON THE DATE ADJACENT
TO THE SEAL.

PRINTED COPIES OF THIS DOCUMENT ARE NOT
CONSIDERED SIGNED AND SEALED AND THE SIGNATURE
MUST BE VERIFIED ON ANY ELECTRONIC COPIES.