



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

06/09/2022

Permit # 000042482

L-28595

Rebecca Prior

Re: Lot 44 Parker Woods

To Whom It May Concern:

The finished floor elevation is determined to be 104.06 feet. The minimum floor elevation as per the building permit is shown to be 103.39 feet. The elevations as shown hereon are based on NAVD 88 datum.

Sincerely,

*L. Scott Britt*  
L. Scott Britt  
LS 5757

