3634

NORTH FLORIDA PROFESSIONAL SERVICES, INC.

Experience. Quality. Commitment.



April 17, 2018

Russell and Jerilyn Guiss 236 S.W. Quail Place Fort White, FL 32038

RE: Proposal to Prepare an Elevation Letter for the Property at 236 S.W. Quail Place, Fort White, Florida

SUBJECT: ELEVATION LETTER 236 S.W. Quail Place, Fort White, Florida

To Whom It May Concern:

236 S.W. Quail Place, Fort White, Florida is not located in a Special Flood Hazard Area, Flood Zone, or Floodway. The proposed home occupies a high point on the property which naturally slopes toward the north, south, east, and west.

Requirements:

The finished floor elevation for any habitable structure shall be a minimum of 12" above the highest adjacent natural grade at the proposed building site. There is no garage and the car port is located on the west side of the house and is elevated above the surrounding natural grade. The front door will be the only opening on the front elevation of the proposed home. The ground around the proposed home shall be graded to direct all runoff away from the home.

Sincerely,

Terry R. White, Jr., P.E. Water Resouces Engineer

No. 37390 STATE OF

Terry R. White, Jr., P.E.

Date