

D
G **Daniel & Gore, LLC**
Professional Surveying and Mapping

P.O. Box 1501
Lake City, Florida 32056

April 8, 2021

Margaret McKenzie
451 NW Country Lake Drive
Lake City, FL 32055

Subject: Permit # 40759 - Lot 32, Country Lake in Woodborough, Phase 4

Dear Margaret:

Daniel & Gore, LLC has performed a vertical survey on Lot 32, Country Lake in Woodborough, Phase 4, Columbia County, Florida from a benchmark being a FDOT concrete monument (2918010 BM4) on the Easterly right of way of I-75 (elevation – 138.98', NAVD 1988) and have determined the following:

- The Elevation Letter by Carol Chadwick, P.E. requires the minimum finish floor elevation to be 135.16'
- Per the Elevation Letter from Carol Chadwick, the existing road centerline is 135'+/-. We have measured said centerline to be 137.84'.
- The top of the concrete foundation of the residence is at 138.03', being 2.87' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

Scott Daniel, PSM • Cell: (386) 208-4176 • E-mail: sdaniel@dgsurveying.com

David Gore • Cell: (386) 365-0298 • E-mail: dgore@dgsurveying.com

Fax: (904) 339-9229