

April 12, 2018

David Simque
PO Box 2962
Lake City, FL 32025

Subject: Permit # 35618 – Parcel # 03117-008 – Skinner Utility Equipment Buildings

Dear David:

Daniel & Gore, LLC has performed a vertical survey on Parcel # 03117-008, Columbia County, Florida from a benchmark being a 60d nail in a power pole on the East lot line, being the same as the West right of way line of SW Arrowhead Terrace (elevation – 98.43', NAVD 1988) and have determined the following:

- The Construction plans require the minimum finish floor elevation to be 97.5'.
- The finish floor elevation of the 9,600 Sq. Ft. building is at 97.9', being 0.4' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM