-

00

JOB NUMBER 20230620

SHEET NUMBER

NOTE: ALL DRAWINGS NOT TO BE SCALED, WRITTEN DIMENSIONS TAKE PRECEDENCE OVER SCALED DIMENSIONS

FLORIDA BUILDING CODE

Compliance Summary

TYPE OF CONSTRUCTION

Roof: Gable & Hip Construction, Wood Trusses @ 24" O.C.

Walls: 2x 4 or 2x 6 Wood Studs @ 16" O.C. Floor: 4" This Concrete Slab, Reinf'd W/ 6x6/10:10 WWM ON CHAIRS @ 36" O.C., Foundation: Continuous monolithic footing or /Stem Wall foundation system

ROOF DECKING

Material: 19/32" CDX Plywood or 7/16" O.S.B.

48"x96" Sheets Perpendicular to Roof Framing 10d Ring-Shank nails per schedule on sheet S.4 Fasteners:

SHEARWALLS 1/2" CD Plywood or 7/16" O.S.B.

48"x96" Sheets Placed Vertical, stagger each sheet. 3d Common Nails @ 4" O.C. Edges & 8" O.C. Interior Fasteners: Double Top Plate (S.Y.P.) W/16d Nails @ 12" O.C. Dragstrut:

2x4 Wood Studs (11 16" O.C. Wall Studs:

HURRICANE UPLIFT CONNECTORS SIMPSON H2.5A (OR EQUIVALENT), W/ 6 - 10d NAILS

Truss Anchors: Wall Tension: Wall Sheathing Nailing is Adequate - 8d @ 4" O.C. Top & Bot. 1/2" A307 Bolts @ 48" O.C. - 1st Bolt 6" from corner Anchor Bolts: (1) DTT2Z (or equiv.) @ each corner Corner Hold-down Device:

Simpson AE U44/ABU66 @ each column Porch Column Base Connector: Simpson EPC44/PC44 @ each column Porch Column to Beam Connector:

FOOTINGS AND FOUNDATIONS

Footing: 18" < 16" Cont. W/ (2) #5 Bars Cont. on chairs or (1) #3 Transverse @ 24" O.C. Stemwall: (optional) 8" C.M.U. W 1-#5 Vertical Dowel @ 48" O.C.

STRUCTURAL DESIGN CRITERIA:

THE DESIGN COMPLIES WITH THE REQUIREMENTS OF THE 2023 FLORIDA BUILDING CODE (8TH EDITION AND OTHER REFERENCED CODES AND SPECIFICATIONS. ALL CODES AND SPECIFICATIONS SHALL BE LATEST EDITION

AT TIME OF PERMIT. 2. WIND LOAD CRITERIA: RISK CATAGORY: 2, EXPOSURE: B"

BASED ON ANBIJASCE 7-16. 2023 FBC 1609- WIND VELOCITY: VULT = 130 MPH

3. ROOF DE GN LOADS:

SUPERIMPOSED DEAD LOADS 20 PSF SUPERIMPOSED LIVE LOADS: 20 P3F

4. FLOOR DESIGN LOADS: SUPERIMPOSED DEAD LOADS 25 PSF

SUPERIMPOSED LIVE LOADS: 40 PSF RESIDENTIAL 60 PSF BALCONIES

5. WIND NET UPLIFT: ARE AS INDICATED ON PLANS

TERMITE PROTECTION NOTES:

SOIL CHEMICAL BARRIER METHOD:

1. A PERMANENT SIGN WHICH IDENTIFIES THE TERMITE TREATMENT PROVIDER AND NEED FOR REINSPECTION AND TREATMENT CONTRACT RENEWAL SHALL BE PROVIDED. THE SIGN SHALL BE POSTED NEAR THE WATER HEATER OR

ELECTRIC PANEL. FBC 104.2.6

2. CONDENSATE AND ROOF DOWNSPOUTS SHALL DISCHARGE AT LEAST 1'-0" AWAY FROM BUILDING SIDE WALLS. FBC 1503.4.4

3. IRRIGATION/SPRINKLER SYSTEMS INCLUDING ALL RISERS AND SPRAY HEADS SHALL NOT BE INSTALLED WITHIN 1'-0" FROM BUILDING SIDE WALLS. FBC 1503.4.4

4. TO PROVIDE FOR INSPECTION FOR TERMITE INFESTATION, BETWEEN WALL

COVERINGS AND FINAL EARTH GRADE SHALL NOT BE LESS THAN 6". EXCEPTION: PAINT AND DECORATIVE CEMENTIOUS FINISH LESS THAN 5/8"

THICK ADHERED DIRECTLY TO THE FOUNDATION WALL, FBC 1403.1.6

5. INITIAL TREATMENT SHALL BE DONE AFTER ALL EXCAVATION AND BACKFILL IS COMPLETE. FBC 1816.1

6. SOIL DISTURBED AFTER THE INITIAL TREATMENT SHALL BE RETREATED INCLUDING SPACES BOXED OR FORMED. FBC 1816.1.

7. BOXED AREAS IN CONCRETE FLOOR FOR SUBSEQUENT INSTALLATION OF TRAPS, ETC., SHALL BE MADE WITH PERMANENT METAL OR PLASTIC

FORMS. PERMANENT FORMS MUST BE OF A SIZE AND DEPTH THAT WILL ELIMINATE THE DISTURBANCE OF SOIL AFTER THE INITIAL TREATMENT.

FBC 1816.1.3

8. MINIMUM 6 MIL VAPOR RETARDER MUST BE INSTALLED TO PROTECT

AGAINST RAINFALL DILUTION. IF RAINFALL OCCURS BEFORE VAPOR RET-ARDER PLACEMENT, RETREATMENT IS REQUIRED. FBC 1816.1.4

9. CONCRETE OVERPOUR AND MORTAR ALONG THE FOUNDATION PERIMETER MUST BE REMOVED BEFORE EXTERIOR SOIL TREATMENT. FBC 1816.1.5

10. SOIL TREATMENT MUST BE APPLIED UNDER ALL EXTERIOR CONCRETE OR GRADE WITHIN 1'-0" OF THE STRUCTURE SIDEWALLS. FBC 1816.1.6

11. AN EXTERIOR VERTICAL CHEMICAL BARRIER MUST BE INSTALLED AFTER

CONSTRUCTION IS COMPLETE INCLUDING LANDSCAPING AND IRRIGATION.

ANY SOIL DISTURBED AFTER THE VERTICAL BARRIER IS APPLIED, SHALL BE RETREATED. FBC 1816.1.6

12. ALL BUILDINGS ARE REQUIRED TO HAVE PER-CONSTRUCTION TREATMENT. FBC 1816.1.7

13. A CERTIFICATE OF COMPLIANCE MUST BE ISSUED TO THE BUILDING DEPART-

MENT BY # LICENSED PEST CONTROL COMPANY BEFORE A CERTIFICATE OF OCCUPANCY WILL BE ISSUED. THE CERTIFICATE OF COMPLIANCE SHALL STATE:

THE BUILDING HAS RECEIVED A COMPLETE TREATMENT FOR THE PREVENTION OF SUBTERRANEAN TERMITES. THE TREATMENT IS IN ACCORDANCE WITH THE

RULES AND LAWS OF THE FLORIDA DEPARTMENT OF AGRICULTURE AND CONS-

UMER SERVICES". FBC 1816.1.7

14. AFTER ALL WORK IS COMPLETED. LOOSE WOOD AND FILL MUST BE REMOVIED FROM BELOW AND WITHIN 1'-0" OF THE BUILDING. THIS INCLUDES ALL GRADE

STAKES, TUB TRAF BOXES, FORMS, SHORING OR OTHER CELLULOSE CONTAINING MATERIAL. FBC 2303.1.3

15. NO WOOD, VEGETATION, STUMPS, CARDBOARD, TRASH, ETC., SHALL BE BUIRIED WITHIN 15'-0" OF ANY BUILDING OR PROPOSED BUILDING. FBC 2303.1.4

FRAMING ANCHOR SCHEDULE

MANUF'R/MODEL APPLICATION SIMPSON H2.5A (OR EQUIVALENT), W/ 6 - 10d NAILS TRUSS TO WALL: GIRDER TRUSS TO POST/HEADER: SIMPSON LGT, W/ 28 - 16d NAILS 1785# 1370# SIMPSON ST22 HEADER TO KING STUD(S): 1065# SIMPSON SP2 PLATE TO STUD: 585# SIMPSON SP1 STUD TO SILL: 1700# SIMPSON PC44/EPC44 PORCH BEAM TO POST: 2200# SIMPSON ABU44 PORCH POST TO FND.: 315#/240# SIMPSON A34 MISC. JOINTS

ALL ANCHORS SHALL BE SECURED W/ NAILS AS PRESCRIBED BY THE

MANUFACTURER FOR MAXIMUM JOINT STRENGTH, UNLESS NOTED OTHERWISE. REFER TO THE INCLUDED STRUCTURAL DETAILS FOR ADDITIONAL ANCHORS/


JOINT REINFORCEMENT AND FASTENERS.


ALL UNLISTED JOINTS IN THE LOAD PATH SHALL BE REINFORCED WITH

SIMPSON A34 FRAMING ANCHORS, TYPICAL T.O.

"SEMCO" PRODUCT APPROVAL: MIAMI/DADE COUNTY REPORT #95-0818.15

"SIMPSON" PRODUCT APPROVALS: MIAMI/DADE COUNTY REPORT #97-0107.05, #96-1126.11, #99-0623.04





SOFFIT/DROPPED CLG.

PENETRATIONS

FIREBLOCKING NOTES

REDUCE OPENING

FIREBLOCKING SHALL BE INSTALLED IN WOOD FRAME CONSTRUCTION IN THE

SCALE: NONE

FOLLOWING LOCATIONS:

1. IN CONCEALED SPACES OF STUD WALLS AND PARTITIONS INCLUDING FURRED SPACES AT CEILING AND FLOOR LEVELS.

2. AT ALL INTERCONNECTIONS BETWEEN CONCEALED VERTICAL AND HORIZONTAL

SPACES SUCH AS OCCUR AT SOFFITS, DROP CEILINGS, COVE CEILINGS, ETC. 3. AT OPENINGS AROUND VENTS, PIPES, DUCTS, CHIMNEYS AND FIREPLACES AT

CEILING AND FLOOR LEVELS WITH "PYROPANEL MULTIFLEX SEALANT"

4. AT ALL INTERCONNECTIONS BETWEEN CONCEALED VERTICAL STUD WALL OR PARTITION SPACES AND CONCEALED SPACES CREATED BY AN ASSEMBLY OF FLOOR JOISTS, FIREBLOCKING SHALL BE PROVIDED FOR THE FULL DEPTH OF THE JOISTS AT THE ENDS AND OVER THE SUPPORTS.

Fire Stopping DETAILS



BUILDING COMPONENTS & CLADDING LOADS MEAN BUILDING HEIGHT = 30.0', EXPOSURE "B" ROOF ANGLE 2T' TO 45" 130 MPH 120 MFH
 (ft²)
 Pos
 Neg
 Pos
 Neg
 Pos
 Neg
 Pos
 Neg

 10
 10.2
 -20.3
 11.1
 -22.1
 13
 -26
 15.1
 -30.1

 20
 10
 -18
 10
 -19.6
 11.3
 -23
 13.1
 -26.7

 50
 10
 -15
 10
 -16.3
 10
 -19.2
 10.5
 -22.2

 100
 10
 -12.7
 10
 -13.8
 10
 -16.2
 10
 -18.8

 10
 10.2
 -24.2
 11.1
 -26.3
 13
 -30.9
 15.1
 -35.9

		DJUSTMENT CO NENTS & CLAD	
BLDG HEIGHT (f:)	EXPOSURE	EXPOSURE	EXPOSURE
5	.82	1.21	1.47
20	.89	1.29	1.55
25	.94	1.35	1.61
30	1.00	1.40	1.66

4			EAN B	LILDIN	1PONE IG HEI 2T° TO	SHT =				
	ZONE	AREA	Yult 115 11 ⊃H		Vult 120 MF H		Vult 130 MPH		Vult 140 MPH	
ı		(ft²)	Pos	Neg	Pos	eg	P06	No 3	Pos	Ne
ROOF 1 TO 21	1, 2e	10	10.6	-26.4	11.6	28.7	13.6	-33.7	15.8	-39.
	1, 2e	20	10	-26.4	10	-28.7	11.7	-33.7	13.6	-39
	1, 2e	50	10	-16.1	10	17,5	10	-20.6	10.8	-23
	1, 2e	100	10	-8.2	10	-9	10	-10.5	10	-12
	2n, 2r, 3e	10	10.6	-38.5	11.6	41.9	13.6	-49.2	15.8	-57
	2n, 2r, 3e	20	10	-33.2	10	36.2	11.7	-42.4	13.6	-49.
	2n, 2r, 3e	50	10	-26.2	10	-28.5	10	-33.5	10.8	-38
	2n, 2r, 3e	100	10	-20.9	10	-72.8	10	-26.7	10	-31
	3r	10	10.6	-45.7	11.6	49.8	13.6	-58.4	15.8	-67
	3r	20	10	-39.2	10	-42.7	11.7	-50.1	13.6	-68
	3r	50	10	-30.5	10	33.2	10	-39	10.8	-45
	31	100	10	-24	10	-26.1	10	-30.6	10	-35

General Roofing NOTES: DECK REQUIREMENTS:

ASPHALT SHINGLES SHALL BE FASTENED TO SOLIDLY SHEATHED DECKS.

ASPHALT SHINGLES SHALL BE USED ONLY ON ROOF SLOPES OF 2:12 OR GREATER. PER R905, DOUBLE UNDERLAYMENT IS REQUIRED ON ROOF SOPES GREATER THAN 4/12.

UNDERLAYMENT: UNLESS OTHERWISE NOTED, UNDERLAYMENT SHALL CONFORM W/ ASTM D 226, TYPE 1, OR ASTM D 4869, TYPE 1

SELF-ADHERING POLYMER MODIFIED BITUMEN SHEET: SELF ADHERING POLYMER MODIFIED BITUMEN SHALL COMPLY W/ ASTM D 1970.

ASPHALT SHINGLES: ASPHALT SHINGLES SHALL HAVE SELF SEAL STRIPS OR BE INTERLOCKING, AND COMPLY WITH ASTM D 225 OR ASTM D 3462.

FASTENERS FOR ASPHALT SHINGLES SHALL BE GALVANIZED, STAINLESS STEEL, ALUMINUM OR COPPER ROOFING NAILS, MINIMUM 12 GAUGE SHANK WITH A MINIMUM 3/8 INCH DIAMETER HEAD, OF A LENGTH TO PENETRATE THROUGH THE ROOFING MATERIAL AND A MINIMUM 3/4" INTO THE ROOF SHEATHING. WHERE THE SHEATHING IS LESS THAN 3/4" THICK, THE NAILS SHALL PENETRATE THROUGH THE SHEATHING.

ASPHALT SHINGLES SHALL BE SECURED TO THE ROOF WITH NOT LESS THAN FOUR FASTENERS PER STRIP SHINGLE OR TWO FASTENERS PER INDIVIDUAL SHINGLE. WHERE ROOFS LOCATED IN BASIC WIND SPEED OF 110 MPH OR GREATER, SPECIAL METHODS OF FASTENING ARE REQUIRED. UNLESS OTHERWISE NOTED, ATTACHMENT OF ASPHALT SHINGLES SHALL CONFORM WITH ASTM D 3161 OR M-DC PA 107-95.

UNDERLAYMENT APPLICATION:

FOR ROOF SLOPES FROM 2:12 TO 4:12 AND GREATER, UNDERLAYMENT SHALL BE A MINIMUM OF TWO LAYERS APPLIED AS FOLLOWS: 1. STARTING AT THE EAVE, A 19 INCH STRIP OF UNDERLAYMENT SHALL BE APPLIED PARALLEL WITH THE EAVE AND FASTENED SUFFICIENTLY TO STAY IN PLACE.

2. STARTING AT THE EAVE, 36 INCH WIDE STRIPS OF UNDERLAYMENT FELT SHALL BE APPLIED OVERLAPPING SUCCESSIVE SHEETS 19 INCHES AND FASTENED SUFFICIENTLY TO STAY IN PLACE.

FOR ROOF SLOPED 4:12 AND GREATER, UNDERLAYMENT SHALL BE A MINIMUM OF TWO LAYERS OF UNDERLAYMENT FELT APPLIED AS FOLLOWS: STARTING AT THE EAVE, UNDERLAYMENT SHALL BE APPLIED SHINGLE FASHION PAPALLEL TO THE EAVE, LAPPED 2 INCHES, AND FASTENED SUFFICIENTLY TO STAY IN PLACE.

BASE AND CAP FLASHINGS:

BASE AND CAP FLASHING SHALL BE INSTALLED IN ACCORDANCE W/ MFGR'S INSTALLATION INSTRUCTIONS. BASE FLASHING SHALL BE OF EITHER CORROSION RESISTANT METAL OF MINIMUM NOMINAL THICKNESS 0.019 INCH OR MINERAL SURFACE ROLL ROOFING WEIGHING A MINIMUM OF 77 LBS PER 100 SQUARE FEET. CAP FLASHING SHALL BE CORROSION RESISTANT METAL OF MINIMUM NOMINAL THICKNESS OF 0.019 INCH.

VALLEYS: VALLEY LINING'S SHALL BE INSTALLED IN ACCORDANCE W/ MANUFACTURER'S INSTALLATION INSTRUCTIONS BEFORE APPLYING ASPHALT SHINGLES. VALLEY LININGS OF THE FOLLOWING TYPES SHALL BE PERMITTED.

1. FOR OPEN VALLEYS LINED WITH METAL, THE VALLEY LINING SHALL BE AT LEAST 16" WIDE AND OF ANY OF THE CORROSION RESISTANT METALS IN FBC TABLE 1507.3.9.2. 2. FOR OPEN VALLEYS, VALLEY LINING OF TWO PLIES OF MINERAL SURFACE

ROLL ROOFING SHALL BE PERMITTED. THE BOTTOM LAYER SHALL BE 18 INCHES AND THE TOP LAYER A MINIMUM OF 36 INCHES WIDE. 3. FOR CLOSED VALLEYS VALLEY LINING SHALL BE ONE OF THE FOLLOWING: 1. BOTH TYPES 1 AND 2 ABOVE, COMBINED. 2. ONE PLY OF SMOOTH ROLL ROOFING AT LEAST 36 INCHES WIDE AND

3. SPECIALTY UNDERLAYMENT AT LEAST 36 INCHES WIDE AND COMPLYING WITH ASTM D 1970.

NOTE!!! ROOFSHINGLES SHALL BE AS MANUFACTURED BY "TAMKO ROOFING PRODUCTS" OF THE FOLLOWING MODELS:

> GLASS-SEAL AR ELITE GLASS-SEAL AR HERITAGE 30 AR HERITAGE 40 AR HERITAGE 50 AR

COMPLYING WITH ASTM D 224

THESE SHINGLES MEET THE REQUIREMENTS OF ASTM D-3161 TYPE 1 MODIFIED TO 110 MPH WINDS & FBC TAS 100, USING 4 NAILS/SHINGLE

OF 4 SHEETS