

GEO-TECH, INC.

Engineering Consultants in Geotechnical • Environmental • Construction Materials Testing

FIELD DENSITY WORKSHEET

CLIENT Flynn LLC DATE 4-7-22
PROJECT NO. _____
PROJECT NAME 183 SW Blue Jay Ct. Fort White PERMIT NO. _____
EARTH CONTRACTOR _____ TESTED BY CO
COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor
☒ Modified Proctor FIELD CONTACT _____
TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☒ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 15' NE of SW corner	108.8	9.9	F.6-	12"	33	109.8	105.9	97.3
Approx 15' SW of NE corner	()	()	()	()	37	111.4	107.4	98.7
Approx 10' of East Footing	()	()	()	()	35	110.4	106.6	98.0

REMARKS _____

* Density failed to meet minimum project requirement
** Retest indicates minimum density requirement was obtained.
() Client is aware of unsatisfactory test results.