

Brinkley # 38313

CAROL CHADWICK, P.E.

*Civil Engineer*

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

July 29, 2019

Trent Giebeig

Trent Giebeig Construction, Inc.

trentgiebeigconstruction@gmail.com

re: ELEVATION LETTER – 261 SW DEANNA TERRACE, LAKE CITY, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. The foundation had been constructed at the time of the inspection. The elevation of the foundation is 146.45. The elevation of the adjacent road varies from 151 +/- to 146+/- . The finished floor of the home will be below the nearest adjacent street.

A swale will be graded between the street and the home to prevent direct precipitation runoff from impacting the home or the home to the south. Please see the approximate swale location shown on a survey completed by Britt Surveying and Mapping, LLC dated July 23, 2019. The topography of the lot naturally slopes to the southeast corner behind the existing downhill home.

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,

Carol Chadwick, P.E.

