

51645

Notice of Prevention for Subterranean Termites
(As required by Florida Building Code (FBC) 104.2.6)



Live Oak
PEST CONTROL
A PROFESSIONAL COMPANY

A local company
serving you
since 1972

17856 U.S. 129 • McALPIN, FLORIDA 32062
(386) 362-3887 • 1-800-771-3887 • Fax: (386) 364-3529

487 SL Madison Court Lake City FL
Address of Treatment or Lot/Block of Treatment

9-24-25 7:30 am LLC
Date Time Applicator

ProMix Imidacloprid 260
Product Used Chemical used (active ingredient) Number of gallons applied

0.5% 2,204 192
Percent Concentration Area treated (square feet) Linear feet treated

Horizontal
Stage of treatment (Horizontal, Vertical, Adjoining Slab, retreat of disturbed area)

As per 104.2.6 - If soil chemical barrier method for Subterranean termite prevention is used, final exterior treatment shall be completed prior to final building approval.

The building has received a complete treatment for the prevention of subterranean termites. Treatment is in accordance with rules & laws established by the Florida Department of Agriculture & Consumer Services. Initial and date this line.

If this notice is for the final exterior treatment initial and date this line. _____