



## Project Summary

### Entire House

### Bounds Heating and Air

Job:  
 Date: Oct 24, 2025  
 By:

Email: jlegler@boundshvac.com

## Project Information

For: Caruthers, CoreyAmira

Notes:

## Design Information

Weather: Gainesville Regional, FL, US

### Winter Design Conditions

Outside db 33 °F  
 Inside db 68 °F  
 Design TD 35 °F

Ventilation Method MJ8

### Heating Summary

Structure 25692 Btuh  
 Ducts (R-6.0) 10757 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Humidification 0 Btuh  
 Piping 0 Btuh  
 Equipment load 36448 Btuh

### Infiltration

Method Simplified  
 Construction quality Average  
 Fireplaces 0

	Heating	Cooling
Area (ft <sup>2</sup> )	2673	2673
Volume (ft <sup>3</sup> )	27992	27992
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	149	75

### Heating Equipment Summary

Make Carrier  
 Trade 15 SEER2 HP  
 Model GH5SAN54800AA0  
 AHRI ref 214101900  
 Efficiency 7.5 HSPF2  
 Heating input  
 Heating output 47500 Btuh @ 47°F  
 Temperature rise 28 °F  
 Actual air flow 1567 cfm  
 Air flow factor 0.043 cfm/Btuh  
 Static pressure 0.50 in H2O  
 Space thermostat  
 Capacity balance point = 27 °F  
 Backup: n/a n/a  
 Input = 0 kW, Output = 0 Btuh, 100 AFUE

*Bold/italic values have been manually overridden*

### Summer Design Conditions

Outside db 92 °F  
 Inside db 75 °F  
 Design TD 17 °F  
 Daily range M  
 Relative humidity 50 %  
 Moisture difference 44 gr/lb

### Sensible Cooling Equipment Load Sizing

Structure 20067 Btuh  
 Ducts (R-6.0) 13354 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Blower 0 Btuh  
 Use manufacturer's data n  
 Rate/swing multiplier 0.97  
 Equipment sensible load 32486 Btuh

### Latent Cooling Equipment Load Sizing

Structure 2413 Btuh  
 Ducts 2686 Btuh  
 Central vent (0 cfm) 0 Btuh  
 Equipment latent load 5099 Btuh  
**Equipment Total Load (Sen+Lat)** 37584 Btuh  
 Req. total capacity at 0.70 SHR 3.9 ton

### Cooling Equipment Summary

Make Carrier  
 Trade 15 SEER2 HP  
 Cond GH5SAN54800AA0  
 Coil FJ5ANXC48L00  
 AHRI ref 214101900  
 Efficiency 12.0 EER2, 15 SEER2  
 Sensible cooling 32900 Btuh  
 Latent cooling 14100 Btuh  
 Total cooling 47000 Btuh  
 Actual air flow 1567 cfm  
 Air flow factor 0.047 cfm/Btuh  
 Static pressure 0.50 in H2O  
 Load sensible heat ratio 0.87

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



## Load Short Form Entire House Bounds Heating and Air

Job:  
Date: Oct 24, 2025  
By:

Email: jlegler@boundshvac.com

### Project Information

For: Caruthers, CoreyAmira

### Design Information

	Htg	Clg	Method	Infiltration	Simplified Average
Outside db (°F)	33	92			
Inside db (°F)	68	75	Construction quality		
Design TD (°F)	35	17	Fireplaces		0
Daily range	-	M			
Inside humidity (%)	50	50			
Moisture difference (gr/lb)	29	44			

#### HEATING EQUIPMENT

Make	Carrier
Trade	15 SEER2 HP
Model	GH5SAN54800AA0
AHRI ref	214101900
Efficiency	7.5 HSPF2
Heating input	
Heating output	47500 Btuh @ 47°F
Temperature rise	28 °F
Actual air flow	1567 cfm
Air flow factor	0.043 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 27 °F	

#### COOLING EQUIPMENT

Make	Carrier
Trade	15 SEER2 HP
Cond	GH5SAN54800AA0
Coil	FJ5ANXC48L00
AHRI ref	214101900
Efficiency	12.0 EER2, 15 SEER2
Sensible cooling	32900 Btuh
Latent cooling	14100 Btuh
Total cooling	47000 Btuh
Actual air flow	1567 cfm
Air flow factor	0.047 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.87

Backup: n/a n/a  
Input = 0 kW, Output = 0 Btuh, 100 AFUE

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
bath 2	75	1582	1817	68	85
wic 2	35	857	455	37	21
bedroom 2	175	1473	1435	63	67
pantry	33	405	237	17	11
kitchen	503	6551	6575	282	308
closet	30	114	95	5	4
foyer	209	3163	4033	136	189
1/2	23	88	73	4	3
great room	583	8958	8007	385	375
bedroom 3	193	1964	1530	84	72
wic 3	33	811	430	35	20
bath 3	71	1548	1796	67	84
ah	20	0	0	0	0
laundry	106	1103	787	47	37

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

# APPROVED

wic	82	939	670	40	31
wc	27	590	382	25	18
master bath	124	969	659	42	31
master bedroom	272	5336	4439	229	208
hall	80	0	0	0	0
<hr/>					
Entire House	2674	36448	33421	1567	1567
Other equip loads		0	0		
Equip. @ 0.97 RSM			32486		
Latent cooling			5099		
<hr/>					
TOTALS	2674	36448	37584	1567	1567

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.





## Manual S Compliance Report Entire House Bounds Heating and Air

Job:  
Date: Oct 24, 2025  
By:

Email: jlegler@boundshvac.com

### Project Information

For: Caruthers, CoreyAmira

### Cooling Equipment

#### Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	33421 Btuh	Entering coil DB:	77.6°F
Outdoor design WB:	75.8°F	Latent gain:	5099 Btuh	Entering coil WB:	63.7°F
Indoor design DB:	75.0°F	Total gain:	38520 Btuh		
Indoor RH:	50%	Estimated airflow:	1567 cfm		

#### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Carrier	Model:	GH5SAN54800AA0+FJ5ANXC48L00		
Actual airflow:	1567 cfm				
Sensible capacity:	37061 Btuh		111% of load		
Latent capacity:	7732 Btuh		152% of load		
Total capacity:	44793 Btuh		116% of load	SHR:	83%

### Heating Equipment

#### Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	36448 Btuh	Entering coil DB:	66.8°F
Indoor design DB:	68.0°F				


#### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Carrier	Model:	GH5SAN54800AA0+FJ5ANXC48L00		
Actual airflow:	1567 cfm				
Output capacity:	47500 Btuh		130% of load	Capacity balance:	27 °F
Supplemental heat required:	0 Btuh			Economic balance:	-99 °F

Backup equipment type:	Elec strip				
Manufacturer:	n/a	Model:	n/a+n/a		
Actual airflow:	1567 cfm				
Output capacity:	0 kW		0% of load	Temp. rise:	0 °F

Meets all requirements of ACCA Manual S.





**Job #:**  
**Performed for:**  
Caruthers

**Bounds Heating and Air**

jlegler@boundshvac.com

**Scale: 1 : 131**  
Page 2  
Right-Suite® Universal 2025  
25.0.01 RSU57217  
2025-Oct-28 08:41:33  
...a, Corey\Caruthers\Caruthers.rup



## Duct System Summary

Entire House  
Bounds Heating and Air

Job:  
Date: Oct 24, 2025  
By:

Email: jlegler@boundshvac.com

### Project Information

For: Caruthers, CoreyAmira

	<b>Heating</b>	<b>Cooling</b>
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.50 in H2O	0.50 in H2O
Supply / return available pressure	0.357 / 0.143 in H2O	0.357 / 0.143 in H2O
Lowest friction rate	0.227 in/100ft	0.227 in/100ft
Actual air flow	1567 cfm	1567 cfm
Total effective length (TEL)		220 ft

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
1/2	h 88	4	3	0.362	4.0	0x0	VIFx	8.4	90.0	st2
bath 2	c 1817	68	85	0.229	5.0	0x0	VIFx	46.0	110.0	st3
bath 3	c 1796	67	84	0.315	5.0	0x0	VIFx	18.2	95.0	st2
bedroom 2	c 1435	63	67	0.246	6.0	0x0	VIFx	35.1	110.0	st3
bedroom 3	h 1964	84	72	0.362	6.0	0x0	VIFx	8.4	90.0	st2
closet	h 114	5	4	0.254	4.0	0x0	VIFx	30.7	110.0	st3
foyer-A	c 4033	136	189	0.337	8.0	0x0	VIFx	15.9	90.0	st2
great room	h 2987	128	125	0.258	7.0	0x0	VIFx	28.3	110.0	st3
great room-A	h 2986	128	125	0.333	7.0	0x0	VIFx	17.2	90.0	st2
great room-B	h 2986	128	125	0.352	7.0	0x0	VIFx	11.4	90.0	st2
kitchen	c 3288	141	154	0.245	7.0	0x0	VIFx	35.7	110.0	st3
kitchen-A	c 3288	141	154	0.227	7.0	0x0	VIFx	47.1	110.0	st3
laundry	h 1103	47	37	0.331	4.0	0x0	VIFx	17.8	90.0	st1
master bath	h 969	42	31	0.313	4.0	0x0	VIFx	24.1	90.0	st1
master bedroom	h 2668	115	104	0.298	6.0	0x0	VIFx	29.7	90.0	st1
master bedroom-A	h 2668	115	104	0.295	6.0	0x0	VIFx	30.8	90.0	st1
pantry	h 405	17	11	0.242	4.0	0x0	VIFx	37.5	110.0	st3
wc	h 590	25	18	0.320	4.0	0x0	VIFx	21.6	90.0	st1
wic	h 939	40	31	0.344	4.0	0x0	VIFx	13.6	90.0	st1
wic 2	h 857	37	21	0.236	4.0	0x0	VIFx	41.5	110.0	st3
wic 3	h 811	35	20	0.338	4.0	0x0	VIFx	15.6	90.0	st2

*Bold/italic values have been manually overridden*

## Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	601	623	0.227	583	14.0	0 x 0	VinIFlx	st2
st2	Peak AVF	1183	1242	0.227	889	16.0	0 x 0	VinIFlx	
st1	Peak AVF	384	325	0.295	489	12.0	0 x 0	VinIFlx	

## Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x0	1567	1567	63.1	0.227	594	22.0	0x 0		VIFx	rst1

## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rst1	Peak AVF	1567	1567	0.227	1122	16.0	0 x 0	VinIFlx	

*Bold/italic values have been manually overridden*

