



Freedom Forever
Planset Revision Letter

9/22/2023
REV #1

Attn. County of Columbia (FL):

The changes outlined in Revision Details have been applied to the plans corresponding to the following customer:

SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE CITY, FL 32024

Revision Details:

1. Per ahj request, 25ft setback provided on side property



All corresponding changes are notated on the plans by revision clouds.

Thank you for your time in reviewing these plans. Please reach out if you have any additional questions or concerns.

Construction Engineering
Freedom Forever
engineering@freedomforever.com

1/0/1900 PHOTOVOLTAIC SYSTEM

CODES:

THIS PROJECT COMPLIES WITH THE FOLLOWING:
2020 7TH EDITION FLORIDA BUILDING CODE: BUILDING
2020 7TH EDITION FLORIDA BUILDING CODE: RESIDENTIAL
2020 7TH EDITION FLORIDA BUILDING CODE: MECHANICAL
2020 7TH EDITION FLORIDA BUILDING CODE: PLUMBING
2020 7TH EDITION FLORIDA BUILDING CODE: FUEL GAS
2020 7TH EDITION FLORIDA BUILDING CODE: ENERGY CONSERVATION
2020 7TH EDITION FLORIDA BUILDING CODE: EXISTING BUILDING
2020 7TH EDITION FLORIDA BUILDING CODE: ACCESSIBILITY
2020 7TH EDITION FLORIDA FIRE PREVENTION CODE
2017 NATIONAL ELECTRIC CODE
AS ADOPTED BY COUNTY OF COLUMBIA (FL)

CONSTRUCTION NOTES:

CONDUIT AND CONDUCTOR SPECIFICATIONS ARE BASED ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT TO LIMIT UP-SIZING AS REQUIRED BY FIELD CONDITIONS.

ALL SOLAR ENERGY SYSTEM EQUIPMENT SHALL BE SCREENED TO THE MAXIMUM EXTENT POSSIBLE AND SHALL BE PAINTED A COLOR SIMILAR TO THE SURFACE UPON WHICH THEY ARE MOUNTED.

MODULES SHALL BE TESTED, LISTED AND IDENTIFIED WITH FIRE CLASSIFICATION IN ACCORDANCE WITH UL 2703. SMOKE AND CARBON MONOXIDE ALARMS ARE REQUIRED PER SECTION R314 AND 315 TO BE VERIFIED AND INSPECTED BY INSPECTOR IN THE FIELD.

DIG ALERT (811) TO BE CONTACTED AND COMPLIANCE WITH EXCAVATION SAFETY PRIOR TO ANY EXCAVATION TAKING PLACE



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Date. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally
signed by
Methode
Maniraguha
Date:
2023.09.26
12:34:12
+05'30'

VICINITY MAP:



TABLE OF CONTENTS:

PV-1	SITE LOCATION
PV-2	SITE PLAN
PV-2B	ROOF AND STRUCTURAL TABLES
PV-2AG	ARRAY PLAN WITH MODULES LAYOUT
PV-3G	GROUND MOUNT ATTACHMENT DETAILS
PV-3AG	GROUND MOUNT ATTACHMENT DETAILS
PV-4	THREE LINE DIAGRAM
PV-5	CONDUCTOR CALCULATIONS
PV-6	EQUIPMENT & SERVICE LIST
PV-7	LABELS
PV-7A	SITE PLACARD
PV-8	OPTIMIZER CHART
PV-9	SAFETY PLAN
PV-10	SAFETY PLAN
APPENDIX	MANUFACTURER SPECIFICATION SHEETS

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 KW
SYSTEM SIZE (AC): 11,400 KW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREEDGE S440
INVERTER: SOLAREEDGE SE11400H-USRGM
(S11)











NO.	REVISIONS	
	REVISED BY	DATE
-	-	-
-	-	-
-	-	-

FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO,
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT



CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

SITE LOCATION			
JOB NO: 339145	DATE: 9/12/2023	DESIGNED BY: J.M.	SHEET: PV-1

LEGEND:

-  OBSTRUCTION
-  PIPE VENT
-  43 FREEDOM FOREVER: FF-MP-BBB-400
-  CONDUIT
-  SETBACK
-  UTILITY METER
-  MSP
-  INVERTER
-  VISIBLE LOCKABLE LABELED AC DISCONNECT
-  JUNCTION BOX


MESH/SCRIM REQUIRED ON GROUND MOUNT



SITE PLAN
SCALE: 1/64" = 1'-0"

1

PROPERTY LINE
SEPTIC



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:34:41 +05'30'

#N/A: 2500 SQ FT

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 KW
SYSTEM SIZE (AC): 11,400 KW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM
[S11]

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-



FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO,
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

SITE PLAN

JOB NO:	DATE:	DESIGNED BY:	SHEET:
339145	9/12/2023	J.M.	PV-2

MESH/SCRIM REQUIRED ON GROUND MOUNT



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Date. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:35:02 +05'30'

#N/A : 2500 SQ FT

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 KW
SYSTEM SIZE (AC): 11,400 KW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREEDGE S440
INVERTER: SOLAREEDGE SE11400H-USRGM
[SI1]

NO.	REVISIONS		DATE
	REVISED BY		
-	-	-	-
-	-	-	-
-	-	-	-



FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO,
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

ARRAY PLAN WITH MODULES LAYOUT

JOB NO:	DATE:	DESIGNED BY:	SHEET:
339145	9/12/2023	J.M.	PV-2AG

ROOF LINE
(E) MAIN SERVICE PANEL
(E) UTILITY METER
(E) MAIN BREAKER ENCLOSURE
(N)EATON_DG222NRB
(OR EQUIVALENT) AC
DISCONNECT

ROOF LINE
(E) MAIN SERVICE PANEL
(E) UTILITY METER
(E) MAIN BREAKER ENCLOSURE
(N)EATON_DG222NRB
(OR EQUIVALENT) AC
DISCONNECT

(N) 1-1/4" PVC UNDER GROUND
CONDUIT @ 18" BELOW
GRADE ~215' (TRENCHED)

(N) 1-1/4" PVC UNDER
GROUND CONDUIT @ 18"
BELOW GRADE ~215'
(TRENCHED)

(N) SOLAREEDGE SE11400H-USRGM
[SI1] INVERTER
(N) JUNCTION BOX
(N) 43 FREEDOM FOREVER:
FF-MP-BBB-400

(N) SOLAREEDGE SE11400H-USRGM
[SI1] INVERTER
(N) JUNCTION BOX
(N) 43 FREEDOM FOREVER:
FF-MP-BBB-400

LEGEND:

- OBSTRUCTION
- PIPE VENT
- 43 FREEDOM FOREVER:
FF-MP-BBB-400
- CONDUIT
- SETBACK
- UTILITY METER
- MSP
- INVERTER
- VISIBLE
LOCKABLE
LABELED AC
DISCONNECT
- JUNCTION
BOX

NOTES:

- ATTACHED CLAMPS AT 25% FROM THE EDGE AND 50% FROM THE CENTER OF THE MODULES
- JUNCTION BOX IS MOUNTED TO THE RAIL.

FLOOR PLAN
SCALE: 1/24" = 1'-0"

1



Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:35:19 +05'30'

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER


SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-8BB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM
[SI]

REVISIONS		
NO.	REVISED BY	DATE
"	"	"
"	"	"
"	"	"

 **freedom**
FOREVER
FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO
FL 32819
Tel: (800) 385-1075

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

GROUT MOUNT MOUNTING DETAILS			
JOB NO: 339145	DATE: 9/12/2023	DESIGNED BY: J.M.	SHEET: PV-3A





CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER


SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-8BB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM
[SI1]

REVISIONS		
NO.	REVISED BY	DATE
"	"	"
"	"	"
"	"	"



CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

GROUND MOUNT ATTACHMENT DETAILS			
JOB NO: 339145	DATE: 9/12/2023	DESIGNED BY: J.M.	SHEET: PV-3G



BACKFEED FUSE SIZING					
MAX. CONTINUOUS OUTPUT 47.50A @ 240V					
47.50	X	1.25	=	59.38AMPS	60A FUSES - OK
SEE 705.12 OF 2017 NEC					
200	X	1.20	=	240	
240	-	200	=	40A ALLOWABLE BACKFEED	



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Date. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:36:55 +05'30'

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREEDGE S440
INVERTER: SOLAREEDGE SE11400H-USRGM
(SH1)

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-
-	-	-




FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO,
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT


CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

THREE LINE DIAGRAM

JOB NO:	DATE:	DESIGNED BY:	SHEET:
339145	9/12/2023	J.M.	PV-4



NOTE:
CONDUIT AND CONDUCTORS SPECIFICATIONS ARE BASED
ON MINIMUM CODE REQUIREMENTS AND ARE NOT MEANT
TO LIMIT UP-SIZING AS REQUIRED BY FIELD CONDITIONS



Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:37:22 +05'30'

[illegible]

CONDUCTOR AMPACITY CALCULATIONS IN ACCORDANCE WITH NEC 690.8.

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
 FF-MP-8BB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM
[S1]

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-



CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
 EC13008056

CONDUCTOR CALCULATIONS

JOB NO:	DATE:	DESIGNED BY:	SHEET
339145	9/12/2023	J.M.	PV-5

[illegible][illegible][illegible]

OPR MAX -30° 4X6 - 5	Quantity ea.	Total Qty.
OPR RAIL KIT MAX	6	6
OPR FOUNDATION KIT	5	5
OPR BEAM KIT	5	5
OPR CABLE KIT	4	4
OPR LANDSCAPE CLAMP KIT	6	6
OPR OVERAGE KIT	0	0

<i>OPR MAX -30° 4X5 - 4</i>	<i>Quantity ea.</i>	<i>Total Qty.</i>
<i>OPR RAIL KIT MAX</i>	5	5
<i>OPR FOUNDATION KIT</i>	4	4
<i>OPR BEAM KIT</i>	4	4
<i>OPR CABLE KIT</i>	3	3
<i>OPR LANDSCAPE CLAMP KIT</i>	5	5
<i>OPR OVERAGE KIT</i>	1	1




Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:37:40 +05'30'

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-8BB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM
[SI1]

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-



2819 CONSULATE DR SUITE 800, ORLANDO
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

EQUIPMENT & SERVICE LIST


JOB NO:	DATE:	DESIGNED BY:	SHEET
339145	9/12/2023	J.M.	PV-1

WARNING:
POWER SOURCE OUTPUT
CONNECTION
DO NOT RELOCATE THIS
OVERCURRENT DEVICE.


705.12(B)(2)(3)(b)

**SOLAR PV SYSTEM EQUIPPED
WITH RAPID SHUTDOWN**

**TURN RAPID
SHUTDOWN SWITCH TO
THE "OFF" POSITION TO
SHUT DOWN PV SYSTEM
AND REDUCE SHOCK
HAZARD IN THE ARRAY**



690.56(C)(1)(A)




"WARNING"
DUAL POWER SOURCES
SECOND SOURCE IS PHOTOVOLTAIC SYSTEM
RATED AC OUTPUT CURRENT - 47.50 AMPS
AC NORMAL OPERATING VOLTAGE - 240 VOLTS

690.54

**EMERGENCY RESPONDER
THIS SOLAR PV SYSTEM EQUIPPED
WITH RAPID SHUTDOWN**

**TURN RAPID SHUTDOWN
SWITCH TO THE "OFF"
POSITION TO SHUT DOWN
ENTIRE PV SYSTEM**



NFPA 11.12.2.1.1.1.1

**PV SYSTEM AC DISCONNECT
RATED AC OUTPUT CURRENT - 47.50 AMPS
AC NORMAL OPERATING VOLTAGE - 240 VOLTS**

690.15, 690.54

**RAPID SHUTDOWN SWITCH FOR
SOLAR PV SYSTEM**

690.56(C)(3)

INVERTER

AC

If you have any questions about your system, please call
our Customer Support Team at
888.557.6431
or visit freedomforever.com/customer-service

This solar PV system was installed by



Freedom Forever is a trademark of Freedom Forever LLC. All rights reserved. No part of this document may be reproduced without written permission.

NOTES:

1. NEC ARTICLES 690 AND 705 AND IRC SECTION R324 MARKINGS SHOWN HEREON.
2. ALL MARKING SHALL CONSIST OF THE FOLLOWING:
 - A. UV RESISTANT SIGN MATERIAL WITH ENGRAVED OR MACHINE PRINTED LETTERS OR ELECTRO-PLATING.
 - B. RED BACKGROUND COLOR WHITE TEXT AND LINE WORK.
 - C. ARIAL FONT.
3. ALL SIGNS SHALL BE SIZED APPROPRIATELY AND PLACED IN THE LOCATIONS SPECIFIED. SIGNAGE CANNOT BE HAND-WRITTEN.
4. SIGNS SHALL BE ATTACHED TO THE SERVICE EQUIPMENT WITH POP-RIVETS OR SCREWS


"WARNING"
ELECTRICAL SHOCK HAZARD.
TERMINALS ON BOTH LINE AND LOAD SIDES
MAY BE ENERGIZED IN THE OPEN POSITION.

690.13 (B)

**MAXIMUM POWER
POINT CURRENT (Imp):** 43A or 30.5A
**MAXIMUM POWER
POINT VOLTAGE (Vmp):** 400V
**MAXIMUM SYSTEM
VOLTAGE (Vmax):** 480V
**SHORT-CIRCUIT
CURRENT (Isc):** 30.5A

690.53

ARRAY



NEC 690.31(G)(3) & (4)

"WARNING"
PHOTOVOLTAIC POWER SOURCE

EVERY 10' ON CONDUIT AND ENCLOSURES



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Date. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

**Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:38:10 +05'30'**

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM
(S11)

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-



FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO,
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

LABELS			
JOB NO:	DATE:	DESIGNED BY:	SHEET:
339145	9/12/2023	J.M.	PV-7



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally signed by
Methode Maniraguha
Date: 2023.09.26
12:38:30 +05'30'



CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 KW
SYSTEM SIZE (AC): 11,400 KW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRCM
(S11)

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-

FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO,
FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

SITE PLACARD			
JOB NO: 339145	DATE: 9/12/2023	DESIGNED BY: J.M.	SHEET: PV-7A


NOTES:

1. NEC ARTICLES 690 AND 705 AND IRC SECTION R324 MARKINGS SHOWN HEREON.
2. ALL MARKING SHALL CONSIST OF THE FOLLOWING:
 - A. UV RESISTANT SIGN MATERIAL WITH ENGRAVED OR MACHINE PRINTED LETTERS OR ELECTRO-PLATING.
 - B. RED BACKGROUND COLOR WHITE TEXT AND LINE WORK.
 - C. AERIAL FONT.
3. ALL SIGNS SHALL BE SIZED APPROPRIATELY AND PLACED IN THE LOCATIONS SPECIFIED. SIGNAGE CANNOT BE HAND-WRITTEN.
4. SIGNS SHALL BE ATTACHED TO THE SERVICE EQUIPMENT WITH POP-RIVETS OR SCREWS.

SOLAREEDGE OPTIMIZER CHART

1-10 11-20 21-30 31-40 41-50 51-60

1
2
3
4
5
6
7
8
9
10



CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE
CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 kW
SYSTEM SIZE (AC): 11,400 kW @ 240V
MODULES: 43 X FREEDOM FOREVER:
FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREEDGE S440
INVERTER: SOLAREEDGE SE11400H-USRGM
(SH1)

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-


FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO, FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

OPTIMIZER CHART			
JOB NO: 339145	DATE: 9/12/2023	DESIGNED BY: J.M.	SHEET: PV-8

JOB HAZARD ANALYSIS

Crew leader to fill out all sections below, hold a pre-job safety meeting with all personnel, and upload this completed document and the Safety Plan to Site Capture

Ladder Access

- Ladders must be inspected before each use.
- Extension ladders must be set up on a firm and level surface at a 4-to-1 rise to run angle (or 75 degrees) and the top must be secured to the structure. Extension style ladders placed on uneven, loose or slippery surfaces must additionally have the base firmly anchored or lashed so the base will not slip out.
- Extension ladders must be used with walk-through devices or the ladder must extend 36" above the stepping off point.
- A-frame ladders must only be climbed with the ladder spreader bars locked in the open position; A-frame ladders shall not be climbed while in the closed position (ex, closed and used while leaned against a structure).

Additional notes:

Mobile Equipment

- Only Qualified operators will operate equipment; operators must maintain a certification on their person for the equipment being operated.
- Type(s) of mobile equipment (Type/Make/Model):
- Qualified operator(s):

Material Handling and Storage

- Materials will be staged/stored in a way that does not present a hazard to client, personnel or public. Materials stored on the roof will be physically protect from failing or sliding off.

Fall Protection

- A site-specific plan for fall prevention and protection is required prior to starting work and must remain onsite at all times until work is complete; a fall rescue plan must be outlined and discussed among the crew prior to work start.
- First-person-Up (FPU) must install their anchor and connect before any other task, including installing other anchors. The Last-Person-Down (LPD) must be the only person on a roof uninstalling fall protection.

FPCP (name and title):

FPU and LPD (name and title):

Electrical Safety

- The Electrical Qualified Person (EQP) is required onsite to perform electrical work.
- All electrical work will be performed with equipment in an electrically safe condition (de-energized) unless approval has been granted prior to work.
- Service drops and overhead electrical hazards will be identified and protected from contact, as neccessary.
- EQP (name and tile):

Public Protection

- The safety of the Client and Public must be maintained at all times.
- The Client and the Public shall be prevented from entering the work zone through the use of barriers and/or signage, as required.
- Company, Client and Public property shall be protected from falling objects.
- Pets (including dogs) shall be secured by their owners prior to work start.
- The Client should not leave pets, family members, or others in charge or care of Employees, Contractors, or Temporary Workers.

- Crew leader responsible for communication with the client:

Client and public is excluded from work area by barricades (N/A, Yes, No):

Training and Pre-Job Safety Briefing

- All employees onsite shall be made aware of the specific hazards of this project and review this HJA during a pre-job briefing, and their signature indicates awareness of site conditions and the plan to eliminate any hazards identified prior to and during the project.

Crew leader (name/title):

Crew member (name/title):

Crew member (name/title):

Crew member (name/title):

Crew member (name/title):

Crew member (name/title):

Airborne Contaminants:

- Asbestos-containing (Transite) piping (ACP) - Do not disturb (move, drill, cut fracture, etc.)
- Asbestos-containing thermal insulation (ACI) and Asbestos-containing duct wrapping (ACV) - do not disturb, no attic or crawlspace access is allowed if work to be performed could cause exposure to personnel, client or public.

- If yes, list specific tasks and protection in place:

Weather and Environment

- The site supervisor shall forecast the weather conditions at the job site, prior to crew arrival, in order to mitigate any hazards associated with inclement weather (heat, cold, wind, rain, etc.)
- The site supervisor will utilized a portable wind meter (anemometer) to verify actual onsite wind conditions, by checking at the ground and on any elevated work surface (ex, rooftop) prior to work start, at midday and prior to solar panel staging on a roof.
- Elevated work involving the moving or maneuvering of solar panels shall cease at 25mph (sustained wind) until wind subsides.
- Forecasted weather maximum temp (degrees f):

Heat Related Illness Prevention

- Employees shall have access to potable drinking water that is fresh, pure, and suitably cool. The water shall be located as close as practicable to the areas where employees are working. Water shall be supplied in sufficient quantity at the beginning of the work shift to provide at least one quart per employee per hour for drinking for the entire shift. Employees may begin the shift with smaller quantities of water if they identify the location and have effective means for replenishment during the shift to allow employees to drink on quart or more per hour. The frequent drinking of water shall be encouraged.
- Shade shall be present when temperature exceeds 80 degrees Fahrenheit. When the outdoor temperature in the work exceeds 80 degrees Fahrenheit, employees shall have and maintain one or more areas with shade at all times.
- New employees must be acclimatized. New employees will be monitored by their Crew Leader (site supervisor) for the first two (2) weeks of employment or longer when necessary.
- Employees will be allowed and encouraged to implement scheduled breaks during each shift. Employees must take cool-down breaks in the shade any time they feel the need to do so to protect them from overheating. Supervisors are REQUIRED to allow employees any break period they need during high heat conditions.
- Cool Vests are encouraged for all employees at all times during periods of high heat.
- Identify the location of the closet Occupational/Industrial Clinic or Hospital in case a crew member becomes ill.

What is the specific plan to provide and replenish sufficient water for all employees on site?

- If offsite replenish is necessary, where will you go to replenish water (location/address):

- Who will replenish the drinking water (name):

Restroom facilities

- Employees shall have access to restroom facilities with hand-washing stations, Use of onsite restroom is at the client's discretion (location is annotated below). If client does not give permission, location of suitable restroom facilities with hand-washing stations offsite will be provided. The onsite supervisor will identify location and make arrangements to ensure all employees have access at any point.

- Restroom facilities will be (circle one): Onsite - Offsite
- If Offsite, add location name and address:

Incident Reporting Procedure

Contact your Site Supervisor

Name:

Phone:

Contact your Manager

Name:

Phone:

Contact your Site Supervisor

Name:

Phone:

With: Your full name, phone number, office location, brief description of what happen and when.

NOTE ADDITIONAL HAZARDS NOT ADDRESSED ABOVE

(add as many as necessary by using additional sheets)

Define the Hazard:	Method/steps to prevent incident:
Define the Hazard:	Method/steps to prevent incident:
Define the Hazard:	Method/steps to prevent incident:
Define the Hazard:	Method/steps to prevent incident:

CLIENT:
SUNIL PATEL
518 SOUTHWEST WINDSOR DRIVE, LAKE CITY, FL 32024
AHJ: COUNTY OF COLUMBIA (FL)
UTILITY: FPL - FLORIDA POWER & LIGHT
PHONE: (386) 208-2467
EMAIL: SNP8991@GMAIL.COM
FINANCE: OTHER

SYSTEM:
SYSTEM SIZE (DC): 43 X 400 = 17,200 KW
SYSTEM SIZE (AC): 11,400 KW @ 240V
MODULES: 43 X FREEDOM FOREVER: FF-MP-BBB-400
OPTIMIZERS: 43 X SOLAREDGE S440
INVERTER: SOLAREDGE SE11400H-USRGM (SH)

REVISIONS		
NO.	REVISED BY	DATE
-	-	-
-	-	-
-	-	-


FREEDOM FOREVER LLC
2619 CONSULATE DR SUITE 800, ORLANDO, FL 32819
Tel: (800) 385-1075
GREG ALBRIGHT

CONTRACTOR LICENSE:
CERTIFIED ELECTRICAL CONTRACTOR
EC13008056

SAFETY PLAN			
JOB NO:	DATE:	DESIGNED BY:	SHEET:
339145	9/12/2023	J.M.	PV-10

FOR INSTALLATION REFERENCE ONLY

SCAN QR CODE TO ACCESS REFERENCE LINK

FREEDOM REFERENCES



INSTALL HOTLINE

PV INSTALLATION REFERENCES



ENPHASE IQ8



SOLAREEDGE HD WAVE



TESLA INVERTER

BATTERY INSTALLATION REFERENCES



TESLA POWERWALL 2



SHIFT/SELF CONSUMPTION



SOLAREEDGE ENERGY BANK





SOLAREEDGE LG RESU (BACKUP)



TESLA POWERWALL+ (BACKUP)



400W MODULE



MODULE SPECIFICATIONS

ELECTRICAL CHARACTERISTICS

Characteristics	FF-MP-BBB-400
Maximum Power (P _{max})	400W
Maximum Power Voltage (V _{mp})	31,01V
Maximum Power Current (I _{mp})[A]	12,90A
Open Circuit Voltage (V _{oc})[V]	37,04V
Short Circuit Current (I _{sc})[A]	13,79A
Module Efficiency	20,49%
Power Tolerance	0/+5W
STC	Irradiance of 1000W/m ² , AM1.5, Cell Temperature 25°C

MECHANICAL CHARACTERISTICS

Cell Type	Mono perc, 182 mm-half cells, 108 (6x9+6x9)
Weight	22,1 kgs (48,7 lbs)
Dimension	1722 x 1134 x 35 mm (67,80 x 44,65 x 1,38 in)
Front Glass	3,2 mm (1,3 in)
Junction Box	IP68 (3 Bypass Diodes)
Output Cables	1200 mm (47,24 in)
Connector	Staubli MC4
Frame & Installation	Anodized aluminum profile

OPERATIONS CHARACTERISTICS

Operational Temperature	-40°C~+85°
Max System Voltage	1500V
Max Series Fuse Rating	25A
Safety Class	Class II
Fire Rating	Type 1

MECHANICAL LOADING

Snow Load	5,400Pa (113lb/ft ²)
Rear Side Design Load	2,400Pa (50lb/ft ²)

PACKAGING INFORMATION




Container	20' GP	40' HC
Pallets per Container	6	26
Panels per Container	186	806
Panels per Pallet	31	31
Packaging Box Weight	679 kg (1497 lbs)	
Panels per Pallet	1785 x 1130 x 1180 mm (70,28 x 44,49 x 46,46 in)	

TEMPERATURE RATINGS


Temperature Coefficient of P _{max}	-0,350%/°C
Temperature Coefficient of V _{oc}	-0,275%/°C
Temperature Coefficient of I _{sc}	+0,045%/°C
Nominal Operating cell Temperature (NOCT)	42°C±2°C



UL 61730 | UL 61215 | ISO 9001 | ISO 14001



CURRENT-VOLTAGE CURVE



Freedom 400W Module Datasheet | Version No: FF-MP-BBB-400

CERTIFICATE OF COMPLIANCE



This certificate confirms the model(s) for the product listed are in compliance and authorized to bear the Certification Mark(s) shown below when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This document is for use with the Design Light Consortium or California Energy Commission application only.

Basic Listee: PT IDN SOLAR TECH
KOMPLEK KABIL INDONUSA ESTATE,
BLOK A NOMOR 19B, BATU BESAR,
Batam
Country: Indonesia

Multiple Listee: Freedom Forever Procurement LLC
43445 Business Park Drive, Suite 110,
Temecula, CA 92590
Country: USA

Party Authorized to Apply Label: PT IDN SOLAR TECH
Report Issuing Office: Intertek Testing Services Shanghai Limited

Control Number: 5019087 **Authorized by:** *for L. Matthew Snyder, Certification Manager*

VALID LISTING MARKS



This Certificate of Compliance is for the exclusive use of Intertek's Client and is provided pursuant to the Certification Agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the Agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the Agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the Agreement and in this Certificate. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the Agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667

Standard(s):	Photovoltaic (PV) Module Safety Qualification - Part 1: Requirements for Construction [UL 61730-1:2017 Ed.1+R:30Apr2020]
	Photovoltaic (PV) Module Safety Qualification - Part 1: Requirements for Construction [CSA C22.2#61730-1:2019 Ed.2]
	Photovoltaic (PV) Module Safety Qualification - Part 2: Requirements for Testing [UL 61730-2:2017 Ed.1+R:30Apr2020]

CERTIFICATE OF COMPLIANCE



Models:	Photovoltaic (PV) Module Safety Qualification - Part 2: Requirements for Testing [CSA C22.2#61730-2:2019 Ed.2]	
	Terrestrial Photovoltaic (Pv) Modules - Design Qualification And Type Approval - Part 1: Test Requirements [UL 61215-1:2017 Ed.1]	
	Terrestrial Photovoltaic (PV) Modules - Design Qualification And Type Approval - Part 1-1: Special Requirements For Testing of Crystalline Silicon Photovoltaic (PV) Modules [UL 61215-1-1:2017 Ed.1]	
	Terrestrial Photovoltaic (Pv) Modules - Design Qualification And Type Approval - Part 2: Test Procedures[UL 61215-2:2017 Ed.1]	
Product:	Crystalline Silicon Photovoltaic (PV) Modules	
Brand Name:	Freedom Forever	
Models:	MULTIPLE LISTEE 12 MODELS	BASIC LISTEE MODELS
	FF-MP-BBB- followed by 365, 370, 375 or 380. FF-MP-BBB- followed by 395, 400, 405 or 410.	NUSA120H- followed by 365, 370, 375 or 380; followed by MB. NUSA100H- followed by 395, 400, 405 or 410; followed by MB.

Power Optimizer For North America

S440, S500



POWER OPTIMIZER

PV power optimization at the module level

- Specifically designed to work with SolarEdge residential inverters
- Detected abnormal PV connector behavior, preventing potential safety issues*
- Module-level voltage shutdown for installer and firefighter safety
- Superior efficiency (99.5%)
- Mitigates all types of module mismatch loss, from manufacturing tolerance to partial shading
- Faster installations with simplified cable management and easy assembly using a single bolt
- Flexible system design for maximum space utilization
- Compatible with bifacial PV modules
- Meets NEC requirements for arc fault protection (AFCI) and Photovoltaic Rapid Shutdown System (PVRSS)

* Expected availability in 2022

solaredge.com

solaredge


/ Power Optimizer For North America S440, S500

	S440	S500	Unit
INPUT			
Rated Input DC Power ⁽¹⁾	440	500	W
Absolute Maximum Input Voltage (V _{oc})	60	60	V _{dc}
MPP Operating Range	8 - 60	8 - 60	V _{dc}
Maximum Short Circuit Current (I _{sc}) of Connected PV Module	14.5	15	A _{dc}
Maximum Efficiency	99.5	99.5	%
Weighted Efficiency	98.6	98.6	%
Overvoltage Category	II	II	
OUTPUT DURING OPERATION			
Maximum Output Current	15	15	A _{dc}
Maximum Output Voltage	60	60	V _{dc}
OUTPUT DURING STANDBY (POWER OPTIMIZER DISCONNECTED FROM INVERTER OR INVERTER OFF)			
Safety Output Voltage per Power Optimizer	1 ± 0.1	1 ± 0.1	V _{dc}
STANDARD COMPLIANCE			
Photovoltaic Rapid Shutdown System ⁽²⁾	NEC 2014, 2017 & 2020	NEC 2014, 2017 & 2020	
BMC	FCC Part 15 Class B, IEC61000-6-2, IEC61000-6-3	FCC Part 15 Class B, IEC61000-6-2, IEC61000-6-3	
Safety	IEC62109-1 (class II safety), UL1741	IEC62109-1 (class II safety), UL1741	
Material	UL94 V-0, UV Resistant	UL94 V-0, UV Resistant	
RnHS	Yes	Yes	
Fire Safety	VDE-AR-E 2100-712-2013-01	VDE-AR-E 2100-712-2013-01	
INSTALLATION SPECIFICATIONS			
Maximum Allowed System Voltage	100V	100V	V _{dc}
Dimensions (W x L x H)	129 x 153 x 30 / 5.07 x 6.02 x 1.18	129 x 153 x 30 / 5.07 x 6.02 x 1.18	mm / in
Weight (including cables)	655 / 1.4	655 / 1.4	g / lb
Input Connector	MC4	MC4	
Input Wire Length	0.1 / 0.32	0.1 / 0.32	m / ft
Output Connector	MC4	MC4	
Output Wire Length	(+) 2.3, (-) 0.10 / (+) 7.54, (-) 0.32	(+) 2.3, (-) 0.10 / (+) 7.54, (-) 0.32	m / ft
Operating Temperature Range ⁽³⁾	-40 to +40	-40 to +40	°C
Protection Rating	IP68 / Type EB	IP68 / Type EB	
Relative Humidity	0 - 100	0 - 100	%

(1) Rated power of the module at STC will not exceed the power optimizer Rated Input DC Power. Modules with up to +2% power tolerance are allowed.
(2) For other connector types please contact SolarEdge.
(3) For ambient temperature above +70°C / +158°F power de-rating is applied. Refer to Power Optimizer Temperature De-Rating Technical Note for more details.

PV System Design Using a SolarEdge Inverter	Single Phase HD-Wave	Three Phase for 208V grid	Three Phase for 277/480V grid	
Minimum String Length (Power Optimizers)	S440, S500	8	4	18
Maximum String Length (Power Optimizers)		25	25	50
Maximum Nominal Power per String	5700 (6000 with SE7600-US-SE1400-U)	600V	2750	W
Maximum Allowed Connected Power per String ⁽¹⁾	Refer to Footnote 5	One String 7200W	15,000W	
Maximum Allowed Connected Power per String ⁽²⁾	Refer to Footnote 5	Two strings or more 7800W	15,000W	
Parallel Strings of Different Lengths or Orientations		Yes	Yes	

(1) A string with more than 30 optimizers does not meet NEC rapid shutdown requirements; safety voltage will be above the 30V requirement.
(2) If the inverter's rated AC power is within its nominal power per string, then the maximum power per string will be able to reach up to the inverter's maximum input DC power. Refer to <https://www.solaredge.com/v>
also see SolarEdge power optimizer single string design application note.pdf
(3) It is not allowed to mix S-series and P-series Power Optimizers in new installations.



© SolarEdge Technologies, Inc. All rights reserved. SOLAREGE, the SolarEdge logo, OPTIMIZED BY SOLAREGE and trademarks or registered trademarks of SolarEdge Technologies Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: February 8, 2022 CS-000020-NA. Subject to change without notice.



Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US

12-25
YEAR
WARRANTY



INVERTERS

Optimized installation with HD-Wave technology

- Specifically designed to work with power optimizers
- Record-breaking 99% weighted efficiency
- Quick and easy inverter commissioning directly from a smartphone using the SolarEdge SetApp
- Fixed voltage inverter for longer strings
- Integrated arc fault protection and rapid shutdown for NEC 2014, NEC 2017 and NEC 2020 per article 690.11 and 690.12
- UL1741 SA certified, for CPUC Rule 21 grid compliance
- Small, lightweight, and easy to install both outdoors or indoors
- Built-in module-level monitoring
- Optional: Faster installations with built-in consumption metering (1% accuracy) and production revenue grade metering (0.5% accuracy, ANSI C12.20)

solaredge.com

solaredge

Single Phase Inverter with HD-Wave Technology for North America

SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US / SE7600H-US / SE10000H-US / SE11400H-US

MODEL NUMBER	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US		
APPLICABLE TO INVERTERS WITH PART NUMBER	SEXXXXH-XXXXXBXX4								
OUTPUT									
Rated AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA	
Maximum AC Power Output	3000	3800 @ 240V 3300 @ 208V	5000	6000 @ 240V 5000 @ 208V	7600	10000	11400 @ 240V 10000 @ 208V	VA	
AC Output Voltage Min.-Nom.-Max. (211 - 240 - 264)	✓	✓	✓	✓	✓	✓	✓	Va	
AC Output Voltage Min.-Nom.-Max. (183 - 208 - 229)	-	✓	-	✓	-	-	✓	Va	
AC Frequency (Nominal)	59.3 - 60 - 60.5 ⁽¹⁾								Hz
Maximum Continuous Output Current @240V	12.5	16	21	25	32	42	47.5	A	
Maximum Continuous Output Current @208V	-	16	-	24	-	-	48.5	A	
Power Factor	1, Adjustable - 0.85 to 0.85								
GFDI Threshold	1								A
Utility Monitoring, Islanding Protection, Country Configurable Thresholds	Yes								
INPUT									
Maximum DC Power @240V	4650	5900	7750	9300	11800	15500	17650	W	
Maximum DC Power @208V	-	5100	-	7750	-	-	15500	W	
Transformer-less, Ungrounded	Yes								
Maximum Input Voltage	480								Vd
Nominal DC Input Voltage	380				400				Vd
Maximum Input Current @240V ⁽²⁾	8.5	10.5	13.5	16.5	20	27	30.5	Ad	
Maximum Input Current @208V ⁽²⁾	-	9	-	13.5	-	-	27	Ad	
Max. Input Short Circuit Current	45								Ad
Reverse-Polarity Protection	Yes								
Ground-Fault Isolation Detection	600k Ω Sensitivity								
Maximum Inverter Efficiency	99	99.2						%	
CEC Weighted Efficiency	99						99 @ 240V 98.5 @ 208V	%	
Nighttime Power Consumption	< 2.5								W

(1) For other regional settings please contact SolarEdge support

(2) A higher current source may be used; the inverter will limit its input current to the values stated

/ Single Phase Inverter with HD-Wave Technology for North America


SE3000H-US / SE3800H-US / SE5000H-US / SE6000H-US/
SE7600H-US / SE10000H-US / SE11400H-US

MODEL NUMBER	SE3000H-US	SE3800H-US	SE5000H-US	SE6000H-US	SE7600H-US	SE10000H-US	SE11400H-US	
ADDITIONAL FEATURES								
Supported Communication Interfaces	RS485, Ethernet, ZigBee (optional), Cellular (optional)							
Revenue Grade Metering, ANSI C12.20	Optional ⁽³⁾							
Consumption metering								
Inverter Commissioning	With the SetApp mobile application using Built-in Wi-Fi Access Point for Local Connection							
Rapid Shutdown - NEC 2014, NEC 2017 and NEC 2020, 690.12	Automatic Rapid Shutdown upon AC Grid Disconnect							
STANDARD COMPLIANCE								
Safety	UL1741, UL1741 SA, UL1699B, CSA C22.2, Canadian AFCI according to TLL M-07							
Grid Connection Standards	IEEE1547, Rule 21, Rule 14 (H)							
Emissions	FCC Part 15 Class B							
INSTALLATION SPECIFICATIONS								
AC Output Conduit Size / AWG Range	1" Maximum / 14-6 AWG				1" Maximum /14-4 AWG			
DC Input Conduit Size / # of Strings / AWG Range	1" Maximum / 1-2 strings / 14-6 AWG				1" Maximum / 1-3 strings / 14-6 AWG			
Dimensions with Safety Switch (HxWxD)	17.7 x 14.6 x 6.8 / 450 x 370 x 174				21.3 x 14.6 x 7.3 / 540 x 370 x 185			in / mm
Weight with Safety Switch	22 / 10	25.1 / 11.4		26.2 / 11.9		38.8 / 17.6		lb / kg
Noise	< 25					<50		dBA
Cooling	Natural Convection							
Operating Temperature Range	-40 to +140 / -40 to +60°							°F / °C
Protection Rating	NEMA 4X (Inverter with Safety Switch)							

(3) Inverter with Revenue Grade Meter P/N: SExxxx-H-US000BNC4; Inverter with Revenue Grade Production and Consumption Meter P/N: SExxxx-H-US000BNH. For consumption metering, current transformers should be ordered separately. SEACT0750-200NA-20 or SEACT0750-400NA-20, 20 units per box.
(4) Full power up to at least 50°C / 122°F; for power derating information refer to: <https://www.solaredge.com/sites/default/files/se-temperature-derating-note-na.pdf>

How to Enable Consumption Monitoring

By simply wiring current transformers through the inverter's existing AC conduits and connecting them to the service panel, homeowners will gain full insight into their household energy usage helping them to avoid high electricity bills



Product specifications

Eaton DG222NRB

Catalog Number: DG222NRB

Eaton General duty cartridge fuse safety switch, 60 A, NEMA 3R, Painted galvanized steel, Class H fuses, Fusible with neutral, Two-pole, Three-wire, Category: general duty safety switch, 240 V

General specifications

Product Name	Catalog Number
Eaton general duty cartridge fuse safety switch	DG222NRB
	UPC
	782113144221
Product Length/Depth	Product Height
7.35 in	14.37 in
Product Width	Product Weight
8.4 in	10 lb
Warranty	Certifications
Eaton Selling Policy 25-000, one (1) year from the date of installation of the Product or eighteen (18) months from the date of shipment of the Product, whichever occurs first.	UL Listed
	Catalog Notes
	Maximum hp ratings apply only when dual element fuses are used. 3-Phase hp rating shown is a grounded B phase rating. UL Listed.



Physical Attributes

Enclosure
NEMA 3R

Enclosure material
Painted galvanized steel

Fuse configuration
Fusible with neutral

Number Of Poles
Two-pole

Number of wires
3

Type
General duty, cartridge fused

Performance Ratings

Amperage Rating
60A

Fuse class provision
Class H fuses

Voltage rating
240V

Miscellaneous

Product Category
General duty safety switch

Resources

Catalogs
Eaton's Volume 2—Commercial Distribution

Multimedia
Double Up on Safety
Switching Devices Flex Center

Specifications and datasheets
Eaton Specification Sheet - DG222NRB



Eaton Corporation plc
Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com
© 2023 Eaton. All Rights Reserved.

Eaton is a registered trademark.
All other trademarks are property of their respective owners.




Eaton.com/socialmedia




INSULATION-PIERCING TAP CONNECTORS CONECTORES DE DERIVACIÓN QUE PERFORAN EL AISLAMIENTO

Installation Instructions:



Warning

Improperly installed electrical wiring can be dangerous and cause electrical fires. The connector chosen must be sized to the wires being used. Consult local building code before doing any electrical work. For assistance, refer to an instructional book or consult a qualified electrician.



Warning

Contact with electricity can cause serious injury or death. Use on insulated cable only. (RHH, RHW(-2), THHN, THHW, THW, THWN, USE, XHHW(-2)). Consult factory for other insulation types). If the installation is to be made on an energized run, the tap conductor must be under no load and must not be grounded. Use electrically insulated gloves. De-energize the run cable if there are any questions of these conditions being met.

- Determine the direction for the tap conductor to exit and discard one end cap. **See figure 1.**
- Position the main (or feeder) side of the connector around the run cable and tighten the bolt finger tight. **See figure 2.** If required, loosen the bolt slightly to allow the connector to open completely. **DISASSEMBLY NOT RECOMMENDED.** The plastic "Turbo" spacer holds the connector open which eases installation and ensures proper connections.
- Cut the end of the tap cable squarely. **DO NOT STRIP CABLE INSULATION.**
- Insert the tap cable into the tap side of the connector until it is seated in the remaining end cap. **See figure 3.**
- Continue tightening the torque regulating bolt with a standard box or socket wrench until the torque regulating piece breaks away. If the connector has two (2) assembly bolts, alternately tighten until the hexagonal torque devices break away. **See figures 4a & 4b.** Note that the plastic "turbo" spacer on the side will also break. To make the installation even easier and to relieve torque from the cables, a second wrench can be used on the hexagonal piece on the bottom of the connector.

DO NOT use gripping type pliers, pipe, open ended or adjustable wrenches as these may damage the hexagonal torque regulating device. A torque wrench is not required.

MAKE SURE ONLY THE TOP HEXAGONAL TORQUE DEVICE OF THE BOLT HEAD IS USED FOR ASSEMBLY. THE SECOND HEX PIECE [CLOSER TO THE BODY OF THE CONNECTOR] IS USED FOR DISASSEMBLY.

Note: The torque regulating bolt ensures the correct torque is applied to the conductors without using a torque wrench. Important information such as run and tap ranges, voltage ratings and material/temperature ratings is marked on the connector.




figure 1




figure 2




figure 3




figure 4a

figure 4b

Instalación Instrucciones:



Advertencia

Los cables eléctricos mal instalados pueden ser peligrosos y provocar incendios. El conector escogido debe ser de un tamaño adecuado para los cables que se utilicen. Consulte los códigos de construcción locales antes de efectuar trabajos eléctricos. Si necesita ayuda, consulte un libro de instrucciones o consulte con un electricista capacitado.



Advertencia

Use sólo en cable aislado. (RHH, RHW(-2), THHN, THHW, THW, THWN, USE, XHHW(-2)). Consulte con la fábrica para obtener información sobre otros tipos de aislamiento). Si se va a hacer la instalación sobre un cable con corriente el conductor derivado debe estar libre de carga y no debe estar aterado. Use guantes con aislamiento eléctrico. Quite la corriente al cable del cual se hace la derivación si no se pueden cumplir estas condiciones. El contacto con electricidad puede producir lesiones graves o mortales.

- Determine la dirección en la que el conductor derivado saldrá y deseché la tapa terminal sobrante. **Vea la ilustración 1.**
- Coloque el lado principal (o de alimentación) del conector alrededor del cual se hace la derivación y apriete firmemente el dedo del perno. **Vea la ilustración 2.** Si hace falta, afloje el perno ligeramente para permitir que el conector se abra completamente. **NO ES RECOMENDABLE DESARMAR EL CONECTOR.** El espaciador "turbo" de plástico mantiene al conector abierto, lo cual facilita la instalación y asegura que las conexiones se hagan correctamente.
- Corte el extremo del cable de derivación perpendicularmente a su eje. **NO PELE EL AISLAMIENTO DEL CABLE.**
- Inserte el cable de derivación en el lado de derivación del conector hasta que tope contra la tapa terminal que queda. **Vea la ilustración 3.**
- Continúe apretando este perno que regula la torsión con una llave estándar o de cubo hasta que la pieza que regula la torsión se parta y se separe. Si el conector tiene dos (2) pernos de ensamblaje, apriételos alternativamente hasta que el dispositivo de regulación de torció se parta. **Vea la ilustración 4a y 4b.** Observe que el espaciador "turbo" de plástico en el costado también se fracturará. Para hacer esta instalación aún más fácil y para aliviar la torsión de los cables, se puede usar una segunda llave sobre la pieza hexagonal al fondo del conector.

NO USE alicates de presión, llaves de turbo, llaves comunes o ajustables ya que éstas pueden dañar el dispositivo hexagonal que regula la torsión. No se requiere una llave de torsión.

ASEGÚRESE QUE SE USE, PARA EL ENSAMBLADO, SOLO EL DISPOSITIVO SUPERIOR DE REGULACIÓN DE TORSIÓN DE LA CABEZA DEL PERNO. LA SEGUNDA PIEZA HEXAGONAL (LA MÁS CERCAÑA AL CUERPO DEL CONECTOR) SE USA SOLO PARA DESARMAR EL CONECTOR.

Nota: El perno regulador de torsión garantiza la aplicación de la torsión correcta a los conductores sin usar una llave de torsión. La información importante de longitud de cable pelado y de toma, las clasificaciones de materiales y temperatura está marcada en el conector.

B-TAP® INSULATION PIERCING TAP CONNECTORS TORQUE AND CURRENT RATINGS

(Solid and/or Stranded)

CATALOG#	MAIN	TAP	NOMINAL TORQUE	TAP CURRENT RATING (IN AMPS)*
BTC2/0-14	2/0-4	10-14*	80 IN. LBS.	40
BTC1/0-10	1/0-8	2-10**	80 IN. LBS.	130
BTC4/0-10	4/0-3	2-10***	125 IN. LBS.	130
BTC4/0-6	4/0-2	1/0-6	160 IN. LBS.	170
BTC4/0-2	4/0-2	4/0-2	160 IN. LBS.	260
BTC250-6	250-4	4/0-6	160 IN. LBS.	260
BTC250-4	250-1	3/0-4	160 IN. LBS.	225
BTC250-2	250-1/0	4/0-2	160 IN. LBS.	260
BTC350-1/0	350-1/0	350-1/0	330 IN. LBS.	350
BTC500-4	500-2/0	4/0-4	330 IN. LBS.	260
BTC500-1/0	500-4/0	350-1/0	330 IN. LBS.	350
BTC500-14	750-3/0	10-14****	80 IN. LBS.	40
BTC750-250	750-250	500-250	330 IN. LBS.	430

+10-14 Cu SOLID/STRANDED; 10-12 Al SOLID/STRANDED

**2-10 Cu SOLID/STRANDED; 2-10 Al STRANDED

***2-10 Cu SOLID/STRANDED; 2-8 Al STRANDED

****10-14 Cu SOLID/STRANDED; 10-12 Al STRANDED

Full line is 600V dual-rated, 194°F(90°C)

* Based on NEC Table 310-16 1996 (Not more than 3 insulated conductors in a raceway at ambient temperature of 30° C) for the largest tap wire size.



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov.



ADVERTENCIA: Cáncer y Daño Reproductivo - www.P65Warnings.ca.gov.

One year limited warranty. See idealind.com for more information.

Garantía limitada de un año. Visite www.idealind.com para obtener detalles de la garantía.



1800 S. Prairie Drive
Sycamore, IL, U.S.A.
800-435-0705 • www.idealind.com



IDEAL INDUSTRIES, INC.

1375 Park Avenue • Sycamore, Illinois 60178 • 815.895.5181 • www.idealind.com

ALL IDEAL Customers

2/9/23

Subject: **The Buchanan B-TAP® splice/tap connectors meet the 2020 NEC article 230.46 requirement for “line side applications”**

The Buchanan B-TAP® brand of insulation piercing connectors which correspond to part numbers beginning with “BTC” meet the requirements of article 230.46 of the 2020 NEC. These products have already been tested to the newer requirements. The installation instructions are in the process of being updated to show the required notation: “suitable for use on the line side of the service equipment”. This change will take a few weeks to get into our production.

In addition, the marking “SR” will be added to the product. That addition is in process and will take a few months to complete.

This notice will provide confirmation to the inspectors that B-TAP® products meet the requirements of the 2020 and 2023 NEC article 230.46 “Spliced and Tapped Conductors”.

Sushil Keswani

A handwritten signature in black ink, appearing to read "Sushil Keswani".

Director of Engineering
IDEAL Industries, Inc.,

ZMVB.E5238 - Wire Connectors and Soldering Lugs

Note: We are enhancing our systems and you may notice duplicate entries/missing/outdated data. During this interim period, please contact our Customer Service at <https://www.ul.com/about/locations>

Wire Connectors and Soldering Lugs

IDEAL INDUSTRIES INC

1375 Park Ave
SYCAMORE, IL 60178 United States

F5238

[View model for additional information](#)

Insulated butt splice crimp type connectors, Model(s): [BVS1](#), [BVS2](#), [BVS5](#)

Insulated flange spade type crimp connectors, Model(s): [SV5-3.7](#), [SVL5-4](#), [SVL5-6](#)

Insulated flange spade type crimp connectors, Model(s): [FSNYD1-3.7](#), [FSNYD1-4](#), [FSNYD1-5](#), [FSNYD2-3.7](#), [FSNYD2-4](#), [FSNYD2-5](#), [FSNYD5-3.7](#), [FSNYD5-4](#), [FSNYD5-5](#)

Insulated hook type crimp connectors, Model(s): [HNYD1-3.7](#), [HNYD1-4](#), [HNYD1-5](#), [HNYD2-3.7](#), [HNYD2-4](#), [HNYD2-5](#), [HNYD5-3.7](#), [HNYD5-4](#), [HNYD5-5](#), [HNY1-3.7](#), [HNY1-4](#), [HNY1-5](#), [HNY2-4](#), [HNY2-5](#), [HNY5-3.7](#), [HNY5-4](#), [HNY5-5](#)

Insulated locking spade crimp connectors, Model(s): [LSNYD1-3.7](#), [LSNYD2-3.7](#), [LSNYD5-3.7](#), [LSNYD5-4](#), [LSNYD5-5](#), [LSNYD1-4](#), [LSNYD1-5](#), [LSNYD1-6](#), [LSNYD1-7](#)

Insulated multiple stud ring type crimp connectors, Model(s): [MSRNYD1-3753](#), [MSRNYD2-3753](#), [MSRNYD5-3753](#)

Insulated parallel connectors, Model(s): [PVT1](#), [PVT14](#), [PVT2](#), [PVT22](#), [PVT5](#), [PVT8](#)

Insulated pin type connectors, Model(s): [PTNYD1-12](#), [PTNYD2-12](#), [PTNYD5-12](#)

Insulated ring type crimp connectors, Model(s): [RNYB14-11](#), [RNYB22-11](#), [RNYD1-10](#), [RNYD1-3.7](#), [RNYD1-5](#), [RNYD1-6](#), [RNYD1-8](#), [RNYD2-10](#), [RNYD2-2](#), [RNYD2-3.7](#), [RNYD2-6](#), [RNYD2-8](#), [RNYD5-10](#), [RNYD5-12](#), [RNYD5-3.7](#), [RNYD5-5](#), [RNYD5-6](#), [RNYD5-8](#), [RNYD1-1-3.7](#), [RNYD1-1-4](#), [RNYD1-2-3.7](#), [RNYD1-2-4](#), [RNYD1-5-3.7](#), [RNYD1-5-4](#), [RNYD1-5-5](#), [RNYD1-5-6](#), [RNYD1-5-8](#), [RNYD1-5-10](#), [RNYD1-5-12](#), [RNYD1-5-14](#), [RNYD1-5-16](#), [RNYD1-5-18](#), [RNYD1-5-20](#), [RNYD1-5-22](#), [RNYD1-5-24](#), [RNYD1-5-26](#), [RNYD1-5-28](#), [RNYD1-5-30](#), [RNYD1-5-32](#), [RNYD1-5-34](#), [RNYD1-5-36](#), [RNYD1-5-38](#), [RNYD1-5-40](#), [RNYD1-5-42](#), [RNYD1-5-44](#), [RNYD1-5-46](#), [RNYD1-5-48](#), [RNYD1-5-50](#), [RNYD1-5-52](#), [RNYD1-5-54](#), [RNYD1-5-56](#), [RNYD1-5-58](#), [RNYD1-5-60](#), [RNYD1-5-62](#), [RNYD1-5-64](#), [RNYD1-5-66](#), [RNYD1-5-68](#), [RNYD1-5-70](#), [RNYD1-5-72](#), [RNYD1-5-74](#), [RNYD1-5-76](#), [RNYD1-5-78](#), [RNYD1-5-80](#), [RNYD1-5-82](#), [RNYD1-5-84](#), [RNYD1-5-86](#), [RNYD1-5-88](#), [RNYD1-5-90](#), [RNYD1-5-92](#), [RNYD1-5-94](#), [RNYD1-5-96](#), [RNYD1-5-98](#), [RNYD1-5-100](#), [RNYD1-5-102](#), [RNYD1-5-104](#), [RNYD1-5-106](#), [RNYD1-5-108](#), [RNYD1-5-110](#), [RNYD1-5-112](#), [RNYD1-5-114](#), [RNYD1-5-116](#), [RNYD1-5-118](#), [RNYD1-5-120](#), [RNYD1-5-122](#), [RNYD1-5-124](#), [RNYD1-5-126](#), [RNYD1-5-128](#), [RNYD1-5-130](#), [RNYD1-5-132](#), [RNYD1-5-134](#), [RNYD1-5-136](#), [RNYD1-5-138](#), [RNYD1-5-140](#), [RNYD1-5-142](#), [RNYD1-5-144](#), [RNYD1-5-146](#), [RNYD1-5-148](#), [RNYD1-5-150](#), [RNYD1-5-152](#), [RNYD1-5-154](#), [RNYD1-5-156](#), [RNYD1-5-158](#), [RNYD1-5-160](#), [RNYD1-5-162](#), [RNYD1-5-164](#), [RNYD1-5-166](#), [RNYD1-5-168](#), [RNYD1-5-170](#), [RNYD1-5-172](#), [RNYD1-5-174](#), [RNYD1-5-176](#), [RNYD1-5-178](#), [RNYD1-5-180](#), [RNYD1-5-182](#), [RNYD1-5-184](#), [RNYD1-5-186](#), [RNYD1-5-188](#), [RNYD1-5-190](#), [RNYD1-5-192](#), [RNYD1-5-194](#), [RNYD1-5-196](#), [RNYD1-5-198](#), [RNYD1-5-200](#), [RNYD1-5-202](#), [RNYD1-5-204](#), [RNYD1-5-206](#), [RNYD1-5-208](#), [RNYD1-5-210](#), [RNYD1-5-212](#), [RNYD1-5-214](#), [RNYD1-5-216](#), [RNYD1-5-218](#), [RNYD1-5-220](#), [RNYD1-5-222](#), [RNYD1-5-224](#), [RNYD1-5-226](#), [RNYD1-5-228](#), [RNYD1-5-230](#), [RNYD1-5-232](#), [RNYD1-5-234](#), [RNYD1-5-236](#), [RNYD1-5-238](#), [RNYD1-5-240](#), [RNYD1-5-242](#), [RNYD1-5-244](#), [RNYD1-5-246](#), [RNYD1-5-248](#), [RNYD1-5-250](#), [RNYD1-5-252](#), [RNYD1-5-254](#), [RNYD1-5-256](#), [RNYD1-5-258](#), [RNYD1-5-260](#), [RNYD1-5-262](#), [RNYD1-5-264](#), [RNYD1-5-266](#), [RNYD1-5-268](#), [RNYD1-5-270](#), [RNYD1-5-272](#), [RNYD1-5-274](#), [RNYD1-5-276](#), [RNYD1-5-278](#), [RNYD1-5-280](#), [RNYD1-5-282](#), [RNYD1-5-284](#), [RNYD1-5-286](#), [RNYD1-5-288](#), [RNYD1-5-290](#), [RNYD1-5-292](#), [RNYD1-5-294](#), [RNYD1-5-296](#), [RNYD1-5-298](#), [RNYD1-5-300](#), [RNYD1-5-302](#), [RNYD1-5-304](#), [RNYD1-5-306](#), [RNYD1-5-308](#), [RNYD1-5-310](#), [RNYD1-5-312](#), [RNYD1-5-314](#), [RNYD1-5-316](#), [RNYD1-5-318](#), [RNYD1-5-320](#), [RNYD1-5-322](#), [RNYD1-5-324](#), [RNYD1-5-326](#), [RNYD1-5-328](#), [RNYD1-5-330](#), [RNYD1-5-332](#), [RNYD1-5-334](#), [RNYD1-5-336](#), [RNYD1-5-338](#), [RNYD1-5-340](#), [RNYD1-5-342](#), [RNYD1-5-344](#), [RNYD1-5-346](#), [RNYD1-5-348](#), [RNYD1-5-350](#), [RNYD1-5-352](#), [RNYD1-5-354](#), [RNYD1-5-356](#), [RNYD1-5-358](#), [RNYD1-5-360](#), [RNYD1-5-362](#), [RNYD1-5-364](#), [RNYD1-5-366](#), [RNYD1-5-368](#), [RNYD1-5-370](#), [RNYD1-5-372](#), [RNYD1-5-374](#), [RNYD1-5-376](#), [RNYD1-5-378](#), [RNYD1-5-380](#), [RNYD1-5-382](#), [RNYD1-5-384](#), [RNYD1-5-386](#), [RNYD1-5-388](#), [RNYD1-5-390](#), [RNYD1-5-392](#), [RNYD1-5-394](#), [RNYD1-5-396](#), [RNYD1-5-398](#), [RNYD1-5-400](#), [RNYD1-5-402](#), [RNYD1-5-404](#), [RNYD1-5-406](#), [RNYD1-5-408](#), [RNYD1-5-410](#), [RNYD1-5-412](#), [RNYD1-5-414](#), [RNYD1-5-416](#), [RNYD1-5-418](#), [RNYD1-5-420](#), [RNYD1-5-422](#), [RNYD1-5-424](#), [RNYD1-5-426](#), [RNYD1-5-428](#), [RNYD1-5-430](#), [RNYD1-5-432](#), [RNYD1-5-434](#), [RNYD1-5-436](#), [RNYD1-5-438](#), [RNYD1-5-440](#), [RNYD1-5-442](#), [RNYD1-5-444](#), [RNYD1-5-446](#), [RNYD1-5-448](#), [RNYD1-5-450](#), [RNYD1-5-452](#), [RNYD1-5-454](#), [RNYD1-5-456](#), [RNYD1-5-458](#), [RNYD1-5-460](#), [RNYD1-5-462](#), [RNYD1-5-464](#), [RNYD1-5-466](#), [RNYD1-5-468](#), [RNYD1-5-470](#), [RNYD1-5-472](#), [RNYD1-5-474](#), [RNYD1-5-476](#), [RNYD1-5-478](#), [RNYD1-5-480](#), [RNYD1-5-482](#), [RNYD1-5-484](#), [RNYD1-5-486](#), [RNYD1-5-488](#), [RNYD1-5-490](#), [RNYD1-5-492](#), [RNYD1-5-494](#), [RNYD1-5-496](#), [RNYD1-5-498](#), [RNYD1-5-500](#), [RNYD1-5-502](#), [RNYD1-5-504](#), [RNYD1-5-506](#), [RNYD1-5-508](#), [RNYD1-5-510](#), [RNYD1-5-512](#), [RNYD1-5-514](#), [RNYD1-5-516](#), [RNYD1-5-518](#), [RNYD1-5-520](#), [RNYD1-5-522](#), [RNYD1-5-524](#), [RNYD1-5-526](#), [RNYD1-5-528](#), [RNYD1-5-530](#), [RNYD1-5-532](#), [RNYD1-5-534](#), [RNYD1-5-536](#), [RNYD1-5-538](#), [RNYD1-5-540](#), [RNYD1-5-542](#), [RNYD1-5-544](#), [RNYD1-5-546](#), [RNYD1-5-548](#), [RNYD1-5-550](#), [RNYD1-5-552](#), [RNYD1-5-554](#), [RNYD1-5-556](#), [RNYD1-5-558](#), [RNYD1-5-560](#), [RNYD1-5-562](#), [RNYD1-5-564](#), [RNYD1-5-566](#), [RNYD1-5-568](#), [RNYD1-5-570](#), [RNYD1-5-572](#), [RNYD1-5-574](#), [RNYD1-5-576](#), [RNYD1-5-578](#), [RNYD1-5-580](#), [RNYD1-5-582](#), [RNYD1-5-584](#), [RNYD1-5-586](#), [RNYD1-5-588](#), [RNYD1-5-590](#), [RNYD1-5-592](#), [RNYD1-5-594](#), [RNYD1-5-596](#), [RNYD1-5-598](#), [RNYD1-5-600](#), [RNYD1-5-602](#), [RNYD1-5-604](#), [RNYD1-5-606](#), [RNYD1-5-608](#), [RNYD1-5-610](#), [RNYD1-5-612](#), [RNYD1-5-614](#), [RNYD1-5-616](#), [RNYD1-5-618](#), [RNYD1-5-620](#), [RNYD1-5-622](#), [RNYD1-5-624](#), [RNYD1-5-626](#), [RNYD1-5-628](#), [RNYD1-5-630](#), [RNYD1-5-632](#), [RNYD1-5-634](#), [RNYD1-5-636](#), [RNYD1-5-638](#), [RNYD1-5-640](#), [RNYD1-5-642](#), [RNYD1-5-644](#), [RNYD1-5-646](#), [RNYD1-5-648](#), [RNYD1-5-650](#), [RNYD1-5-652](#), [RNYD1-5-654](#), [RNYD1-5-656](#), [RNYD1-5-658](#), [RNYD1-5-660](#), [RNYD1-5-662](#), [RNYD1-5-664](#), [RNYD1-5-666](#), [RNYD1-5-668](#), [RNYD1-5-670](#), [RNYD1-5-672](#), [RNYD1-5-674](#), [RNYD1-5-676](#), [RNYD1-5-678](#), [RNYD1-5-680](#), [RNYD1-5-682](#), [RNYD1-5-684](#), [RNYD1-5-686](#), [RNYD1-5-688](#), [RNYD1-5-690](#), [RNYD1-5-692](#), [RNYD1-5-694](#), [RNYD1-5-696](#), [RNYD1-5-698](#), [RNYD1-5-700](#), [RNYD1-5-702](#), [RNYD1-5-704](#), [RNYD1-5-706](#), [RNYD1-5-708](#), [RNYD1-5-710](#), [RNYD1-5-712](#), [RNYD1-5-714](#), [RNYD1-5-716](#), [RNYD1-5-718](#), [RNYD1-5-720](#), [RNYD1-5-722](#), [RNYD1-5-724](#), [RNYD1-5-726](#), [RNYD1-5-728](#), [RNYD1-5-730](#), [RNYD1-5-732](#), [RNYD1-5-734](#), [RNYD1-5-736](#), [RNYD1-5-738](#), [RNYD1-5-740](#), [RNYD1-5-742](#), [RNYD1-5-744](#), [RNYD1-5-746](#), [RNYD1-5-748](#), [RNYD1-5-750](#), [RNYD1-5-752](#), [RNYD1-5-754](#), [RNYD1-5-756](#), [RNYD1-5-758](#), [RNYD1-5-760](#), [RNYD1-5-762](#), [RNYD1-5-764](#), [RNYD1-5-766](#), [RNYD1-5-768](#), [RNYD1-5-770](#), [RNYD1-5-772](#), [RNYD1-5-774](#), [RNYD1-5-776](#), [RNYD1-5-778](#), [RNYD1-5-780](#), [RNYD1-5-782](#), [RNYD1-5-784](#), [RNYD1-5-786](#), [RNYD1-5-788](#), [RNYD1-5-790](#), [RNYD1-5-792](#), [RNYD1-5-794](#), [RNYD1-5-796](#), [RNYD1-5-798](#), [RNYD1-5-800](#), [RNYD1-5-802](#), [RNYD1-5-804](#), [RNYD1-5-806](#), [RNYD1-5-808](#), [RNYD1-5-810](#), [RNYD1-5-812](#), [RNYD1-5-814](#), [RNYD1-5-816](#), [RNYD1-5-818](#), [RNYD1-5-820](#), [RNYD1-5-822](#), [RNYD1-5-824](#), [RNYD1-5-826](#), [RNYD1-5-828](#), [RNYD1-5-830](#), [RNYD1-5-832](#), [RNYD1-5-834](#), [RNYD1-5-836](#), [RNYD1-5-838](#), [RNYD1-5-840](#), [RNYD1-5-842](#), [RNYD1-5-844](#), [RNYD1-5-846](#), [RNYD1-5-848](#), [RNYD1-5-850](#), [RNYD1-5-852](#), [RNYD1-5-854](#), [RNYD1-5-856](#), [RNYD1-5-858](#), [RNYD1-5-860](#), [RNYD1-5-862](#), [RNYD1-5-864](#), [RNYD1-5-866](#), [RNYD1-5-868](#), [RNYD1-5-870](#), [RNYD1-5-872](#), [RNYD1-5-874](#), [RNYD1-5-876](#), [RNYD1-5-878](#), [RNYD1-5-880](#), [RNYD1-5-882](#), [RNYD1-5-884](#), [RNYD1-5-886](#), [RNYD1-5-888](#), [RNYD1-5-890](#), [RNYD1-5-892](#), [RNYD1-5-894](#), [RNYD1-5-896](#), [RNYD1-5-898](#), [RNYD1-5-900](#), [RNYD1-5-902](#), [RNYD1-5-904](#), [RNYD1-5-906](#), [RNYD1-5-908](#), [RNYD1-5-910](#), [RNYD1-5-912](#), [RNYD1-5-914](#), [RNYD1-5-916](#), [RNYD1-5-918](#), [RNYD1-5-920](#), [RNYD1-5-922](#), [RNYD1-5-924](#), [RNYD1-5-926](#), [RNYD1-5-928](#), [RNYD1-5-930](#), [RNYD1-5-932](#), [RNYD1-5-934](#), [RNYD1-5-936](#), [RNYD1-5-938](#), [RNYD1-5-940](#), [RNYD1-5-942](#), [RNYD1-5-944](#), [RNYD1-5-946](#), [RNYD1-5-948](#), [RNYD1-5-950](#), [RNYD1-5-952](#), [RNYD1-5-954](#), [RNYD1-5-956](#), [RNYD1-5-958](#), [RNYD1-5-960](#), [RNYD1-5-962](#), [RNYD1-5-964](#), [RNYD1-5-966](#), [RNYD1-5-968](#), [RNYD1-5-970](#), [RNYD1-5-972](#), [RNYD1-5-974](#), [RNYD1-5-976](#), [RNYD1-5-978](#), [RNYD1-5-980](#), [RNYD1-5-982](#), [RNYD1-5-984](#), [RNYD1-5-986](#), [RNYD1-5-988](#), [RNYD1-5-990](#), [RNYD1-5-992](#), [RNYD1-5-994](#), [RNYD1-5-996](#), [RNYD1-5-998](#), [RNYD1-5-1000](#), [RNYD1-5-1002](#), [RNYD1-5-1004](#), [RNYD1-5-1006](#), [RNYD1-5-1008](#), [RNYD1-5-1010](#), [RNYD1-5-1012](#), [RNYD1-5-1014](#), [RNYD1-5-1016](#), [RNYD1-5-1018](#), [RNYD1-5-1020](#), [RNYD1-5-1022](#), [RNYD1-5-1024](#), [RNYD1-5-1026](#), [RNYD1-5-1028](#), [RNYD1-5-1030](#), [RNYD1-5-1032](#), [RNYD1-5-1034](#), [RNYD1-5-1036](#), [RNYD1-5-1038](#), [RNYD1-5-1040](#), [RNYD1-5-1042](#), [RNYD1-5-1044](#), [RNYD1-5-1046](#), [RNYD1-5-1048](#), [RNYD1-5-1050](#), [RNYD1-5-1052](#), [RNYD1-5-1054](#), [RNYD1-5-1056](#), [RNYD1-5-1058](#), [RNYD1-5-1060](#), [RNYD1-5-1062](#), [RNYD1-5-1064](#), [RNYD1-5-1066](#), [RNYD1-5-1068](#), [RNYD1-5-1070](#), [RNYD1-5-1072](#), [RNYD1-5-1074](#), [RNYD1-5-1076](#), [RNYD1-5-1078](#), [RNYD1-5-1080](#), [RNYD1-5-1082](#), [RNYD1-5-1084](#), [RNYD1-5-1086](#), [RNYD1-5-1088](#), [RNYD1-5-1090](#), [RNYD1-5-1092](#), [RNYD1-5-1094](#), [RNYD1-5-1096](#), [RNYD1-5-1098](#), [RNYD1-5-1100](#), [RNYD1-5-1102](#), [RNYD1-5-1104](#), [RNYD1-5-1106](#), [RNYD1-5-1108](#), [RNYD1-5-1110](#), [RNYD1-5-1112](#), [RNYD1-5-1114](#), [RNYD1-5-1116](#), [RNYD1-5-1118](#), [RNYD1-5-1120](#), [RNYD1-5-1122](#), [RNYD1-5-1124](#), [RNYD1-5-1126](#), [RNYD1-5-1128](#), [RNYD1-5-1130](#), [RNYD1-5-1132](#), [RNYD1-5-1134](#), [RNYD1-5-1136](#), [RNYD1-5-1138](#), [RNYD1-5-1140](#), [RNYD1-5-1142](#), [RNYD1-5-1144](#), [RNYD1-5-1146](#), [RNYD1-5-1148](#), [RNYD1-5-1150](#), [RNYD1-5-1152](#), [RNYD1-5-1154](#), [RNYD1-5-1156](#), [RNYD1-5-1158](#), [RNYD1-5-1160](#), [RNYD1-5-1162](#), [RNYD1-5-1164](#), [RNYD1-5-1166](#), [RNYD1-5-1168](#), [RNYD1-5-1170](#), [RNYD1-5-1172](#), [RNYD1-5-1174](#), [RNYD1-5-1176](#), [RNYD1-5-1178](#), [RNYD1-5-1180](#), [RNYD1-5-1182](#), [RNYD1-5-1184](#), [RNYD1-5-1186](#), [RNYD1-5-1188](#), [RNYD1-5-1190](#), [RNYD1-5-1192](#), [RNYD1-5-1194](#), [RNYD1-5-1196](#), [RNYD1-5-1198](#), [RNYD1-5-1200](#), [RNYD1-5-1202](#), [RNYD1-5-1204](#), [RNYD1-5-1206](#), [RNYD1-5-1208](#), [RNYD1-5-1210](#), [RNYD1-5-1212](#), [RNYD1-5-1214](#), [RNYD1-5-1216](#), [RNYD1-5-1218](#), [RNYD1-5-1220](#), [RNYD1-5-12](#)

Splicing wire connectors, Model(s): [H-1566](#) [H-1567](#) [H-1570](#) [H-1571](#) [H-1572](#) [H-1591](#) [H-1592](#) [H-1594](#)

Terminal connectors, Model(s): [10](#) [11](#) [22](#) [250](#) [300](#) [341](#) [342](#) [410 with insulating cap No. 415](#) [411 with insulating cap No. 417](#) [412 with insulating cap No. 417](#) [451](#) [452](#) [454](#) [48](#) [49](#) [49 Black](#) [53-B](#) [59B](#) [600](#) [71B#](#) [72B#](#) [73B#](#) [73B+](#) [74B](#) [76B](#) [76B+](#) [78B+](#) [82](#) [K-5504](#) [LSN12-4](#) [M-3](#) [PV3-750](#) [PV3-750](#) [PV3-750](#) [PV4-750](#) [PV4-750](#) [PV4-750](#) [RNBI2-4](#) [RNBS14-6](#) [RNBS38-6](#) [RNBS38-8](#) [RNYB22-10](#) [RNYBS8-6](#) [RV2-6](#) [RVL2-5](#) [SV5-5](#) [WT1](#) [WT2](#) [WT3](#) [WT4](#) [WT41](#) [WT51](#) [WT52](#) [WT53](#) [WT54](#) [WT6](#)

Terminal Connectors, Model(s): [RNB22-11](#)

Wire Connectors, Model(s): [65](#) [653](#)

Wire Connectors and Soldering Lugs, Model(s): [L22](#) [L23](#) [L25](#) [PS10](#) [PS12](#) [PS2](#) [PS3](#) [PS4](#) [PS4S](#) [PS5](#) [PS6](#) [PS8](#)

- The equipment (71B, 72B and 73B) were also evaluated to the requirements of UL 2043 and are suitable for use in air handling spaces.

* - May be followed by suffix B, J, T or X.

NOTE - All models may be provided with or without prefix "V" or suffix "MP" or "V" and prefix "BP". All models may be followed by suffixes BT, UB or UF with or without a two or four digit number, with or without suffixes B, LP, NP, PF, PH, SP and/or T. Die Series terminals may be followed by Suffixes UI, UT, UF, US, or UB, with or without a two to four digit number, with or without Suffix T or B, followed by Suffixes SP, LP, NP, PF, or and/or NM, by PH or BE, with or without Suffixes NT, BS, and /or G.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."



NUANCE ENERGY
Revolutionary Solar Racking Structures

ANCHOR LOADING REFERENCE TABLE

Western F170				
SSM Load	Anchors	Load Per Anchor	1 Additional Anchor Load	2 Additional Anchor Load
700	1	700	400	300
800	1	800	500	300
900	1	900	500	300
1000	1	1000	600	400
1100	1	1100	700	400
1200	1	1200	700	500
1300	1	1300	800	500
1400	1	1400	800	500
1500	1	1500	900	600
1600	1	1600	1000	600
1700	1	1700	1000	600
1800	1	1800	1100	700
1900	1	1900	1100	700
2000	1	2000	1200	800
2100	1	2100	1300	800
2200	1	2200	1300	800
2300	1	2300	1400	900
2400	1	2400	1400	900
2500	1	2500	1500	1000
2600	1	2600	1600	1000
2700	1	2700	1600	1000
2800	1	2800	1700	1100
2900	1	2900	1700	1100
3000	1	3000	1800	1100
3100	1	3100	1900	1200
3200	1	3200	1900	1200
3300	2	2200	2000	1300
3400	2	2300	2000	1300
3500	2	2300	2100	1300
3600	2	2400	2200	1400
3700	2	2500	2200	1400
3800	2	2500	2300	1400
3900	2	2600	2300	1500
4000	2	2700	2400	1500
4100	2	2700	2500	1600
4200	2	2800	2500	1600
4300	2	2900	2600	1600
4400	2	2900	2600	1700
4500	2	3000	2700	1700
4600	2	3100	2800	1700
4700	2	3100	2800	1800
4800	2	3200	2900	1800
4900	2	3300	2900	1900
5000	3	2300	3000	1200
5100	3	2300	1900	1200
5200	3	2300	2000	1200
5300	3	2400	2000	1300
5400	3	2400	2100	1300
5500	3	2500	2100	1300
5600	3	2500	2100	1300
5700	3	2600	2200	1400
5800	3	2600	2200	1400
5900	3	2700	2200	1400
6000	3	2700	2300	1400

Western F120				
SSM Load	Anchors	Load Per Anchor	1 Additional Anchor Load	2 Additional Anchor Load
700	1	700	400	300
800	1	800	500	300
900	1	900	500	300
1000	1	1000	600	400
1100	1	1100	700	400
1200	1	1200	700	500
1300	1	1300	800	500
1400	1	1400	800	500
1500	1	1500	900	600
1600	1	1600	1000	600
1700	1	1700	1000	600
1800	1	1800	1100	700
1900	1	1900	1100	700
2000	1	2000	1200	800
2100	1	2100	1300	800
2200	1	2200	1300	800
2300	1	2300	1400	900
2400	1	2400	1400	900
2500	1	2500	1500	1000
2600	1	2600	1600	1000
2700	2	1800	1600	1000
2800	2	1900	1700	1100
2900	2	1900	1700	1100
3000	2	2000	1800	1100
3100	2	2100	1900	1200
3200	2	2100	1900	1200
3300	2	2200	2000	1300
3400	2	2300	2000	1300
3500	2	2300	2100	1300
3600	2	2400	2200	1400
3700	2	2500	2200	1400
3800	2	2500	2300	1400
3900	2	2600	2300	1500
4000	3	1800	1500	1000
4100	3	1800	1600	1000
4200	3	1900	1600	1000
4300	3	1900	1600	1000
4400	3	2000	1700	1100
4500	3	2000	1700	1100
4600	3	2100	1700	1100
4700	3	2100	1800	1100
4800	3	2200	1800	1200
4900	3	2200	1900	1200
5000	3	2300	1900	1200
5100	3	2300	1900	1200
5200	3	2300	2000	1200
5300	3	2400	2000	1300
5400	3	2400	2100	1300
5500	3	2500	2100	1300
5600	3	2500	2100	1300
5700	3	2600	2200	1400
5800	3	2600	2200	1400
5900	3	2700	2200	1400
6000	3	2700	2300	1400

Structural Rack & Components Calculation Package

Components & Racking System:

Osprey PowerRack & Structural/Light Gauge Steel
Components Structural Analysis

Client:

Nuance Energy, Inc
2450 Colorado Avenue
Santa Monica, CA 90404

Prepared By:

Joshua M. Bice, PE
Valkyrie Engineering & Design, LLC



Table of Contents:

Page 3 – Scope of Analysis
Page 3 – Design Criteria
Page 3 – Racking Description
Page 3 – Site Specific Design Requirements
Page 6 – Scope of Work Achieved by this Report
Page 6 – Conclusion
Page 7 – Exclusions and Limitations
Page 7 – Notes and Material Specifications
Page 9 – 4x3 Racking Assembly Parts BOM
Page 10 – 4x3 Racking Assembly Parts BOM
Page 11 – 4x3 Racking Assembly Parts BOM
Page 12 – Unit Types
Page 12 – 4x3 Racking Assembly Model
Page 13 – 4x4 Racking Assembly Model
Page 14 – 4x5 Racking Assembly Model
Page 15 – Vertical & Lateral Load Calculations
Page 16 – Open Wind C&C Ultimate Pressure Table
Page 17 – 4x3 Osprey PowerRack Assembly Analysis
Page 47 – 4x4 Osprey PowerRack Assembly Member Design Check Diagram
Page 48 – 4x4 Osprey PowerRack Assembly Member Shear Check Diagram
Page 49 – 4x5 Osprey PowerRack Assembly Member Design Check Diagram
Page 50 – 4x5 Osprey PowerRack Assembly Member Shear Check Diagram
Page 51 – Bolted Connection Capacity Equations and Results
Appendix A – Ground Anchor Product Data Sheets

Scope of Analysis

Design Criteria:

ASCE 7-16, Minimum Design Loads and Associated Criteria for Buildings and Other Structures.

Based on International Building Code (IBC) 2018. Superseded editions 2015, 2012, & 2009.

Max wind: 110 mph (Ultimate), 85 mph (Factored)

Max Snow, Pg: 30 psf

Racking Description:

The calculation package consists of analyzing the individual components that when assembled create the Osprey PowerRack, a ground mount photovoltaic (PV) racking structure. This analysis addresses the assembled rack. The rack sizes analyzed are the following: 4x3 table (12 PV Panels), 4x4 table (16 PV Panels) & 4x5 table (20 PV Panels). It shall be noted that the addition of a column of panels constituted an addition of one leg set to extend the table. The primary 4x3 rack will demonstrate the worst case analysis of the three systems. The component materials used are either structural steel, light gauge steel, or stainless steel. Once the rack is installed it is anchored to the ground utilizing earth anchors (analyzed by others) to resist the applied vertical loading.

Nuance energy has provided the structural results of all components and assembled racks. The purpose of this packet is to define and review the structural calculations with the associated data, each part shall be analyzed individually.

Site Specific Design Requirements

It is recommended that each project shall have site specific engineering, provided as an SSM (Site Specific Memo) signed and sealed by the Engineer of Record (EOR) for the specific site. This process ensures that the Osprey PowerRack will be an acceptable solution to the site specific conditions. The site conditions per site shall fall into the range of the stated structural design parameters outlined in this package. This package shall not be used if those parameters are outside the range of what is listed in this package. For sites that fall outside the scope of this report, individual analysis shall be performed on the racking system to ensure

Valkyrie Engineering & Design, LLC

structural stability. A signed and sealed approval letter shall be obtained from the EOR for each project prior to the installation of the racking systems. If no approval letter is supplied this package shall not be referenced or used in any way.

This package can be supplemented by analysis signed and sealed by Valkyrie Engineering & Design that may include loading conditions and racking geometry outside the scope of this package.

This analysis was performed utilizing a standard PV module consisting of an aluminum frame hosting the PV cells. The size of the module provided measured approximately 95" x 45" and weighs 69lbs see appendix for module spec sheet. The mounting locations of the module are based on manufacturing specifications of the module manufacturer. This package covers module mounting spacings up to 55". It shall be noted that similar size panels are acceptable to use in lieu of the tested module. The SSM must include the desired panel, this panel must be smaller than or equal to, but not greater than the parameters stated above.

Geotechnical reports, if obtained, shall be referred to in the evaluation of any and all site specific approval letters. However, Nuance Energy requires real-time load testing for each foundation as they are being installed. Thus, a Geotechnical report is not required. It is the owner's responsibility to supply Nuance Energy with the tested values as a form provided by Nuance Energy. Failure to provide testing results voids this package.

The earth anchors must be tested and recorded individually at the time of installation. The SSM shall provide a required anchor count and factored load required to be met by the earth anchors for each foundation. When one (1) earth anchor is required by the SSM, the earth anchor must be installed at 0° vertical (+/- 5°). When two (2) earth anchors are required by the SSM the earth anchors shall each be installed at 10° from vertical and opposite of each other on the North-South plane. When three (3) earth anchors are required by the SSM, each earth anchor shall be installed at 10° from vertical rotated 120° from each other about the center of the baseplate. If the earth anchor load testing results are not sufficient an additional earth anchor shall be installed 20° from vertical. The placement of the additional anchor in respect to the required earth anchors shall be the following:

- (1) required earth anchor – Install additional (2nd) earth anchor on N-S plane at 20° from vertical away from the structure.
- (2) required earth anchors – Install additional (3rd) earth anchor on east-west plane away from the structure at 20° from vertical.
- (3) required earth anchors – Install additional (4th) earth anchor at 0° from vertical.

Valkyrie Engineering & Design, LLC

Earth Anchors work on the principal that the soil above them create the capacity of the foundation. Thus, a reduction in capacity must be accounted for as the cone of influence will overlap depending on the soil conditions, anchor angle, anchor depth, and relative location. See table below for specific reductions based on the number of anchors installed.

Anchor Reduction Table		
Required Anchors per SSM		(1) Additional Anchor
Anchors Required	Revised Capacity Factor	Reduced Value
1	100%	60%
2	67%	40%
3	42%	30%
4	32%	N/A

The load stated in the SSM is factored by the table above. For Example : if the SSM load requirement is 1,000lbs and requires one anchor, that anchor must be tested and recorded to 1,000lbs. If an additional anchor is needed based on the 1,000lb load the reduction is 60% therefore the capacity of both anchors is 600lbs each. In the case that the SSM states 2 anchors at 1,000lbs each anchor must be installed and must reach a load of 670lbs as stated in the table above.

The bearing capacity of the soil shall be reviewed in the selection of a sufficient base plate. The earth anchors shall be tested per the requirements of Nuance Energy and supplied to the EOR for review and submittal of a signed and sealed (S&S) earth anchor approval letter.

Valkyrie Engineering & Design, LLC

Scope of Work achieved by this report:

Valkyrie Engineering & Design has been hired by Nuance Energy to address the following items:

- The initial design criteria of those found in ASCE 7-16 along with a range of acceptable variations for the racking system including the following: table tilt, leg heights, spacing, and base plate evaluation.
 - Maximum wind speed of 110 mph
 - Maximum ground snow load, P_g , of 30 psf
 - Risk Category I
 - Exposure Category C
 - Panel table tilt angle of 15° to 30°
 - Front leg range of 26.8" to 52.0"
 - Rear leg range of 48.9" to 105.0"
 - North-South leg spacing of 82.5"
 - Seismic S_{DS} factor equal to .0577 g or less
- Structural analysis of each member supplied by Nuance Energy
- Structural analysis of hardware for each connection supplied by Nuance Energy
- Structural analysis of the rack assembly supplied by Nuance Energy

Conclusion:

Valkyrie Engineering & Design has evaluated the design results provided by Nuance Energy in addition to the models and provided installation documentation and has determined that if the racking systems are built per the installation manual and design criteria falls inside this structural analysis the racking system shall be structural sufficient to support the imposed lateral and vertical loads.

An approved SSM shall be supplied by the project EOR for each project in addition to an signed and sealed earth anchor approval letter. Unless both sign and sealed site specific documents are provided, this calculation package shall not be utilized for the installation of the racking system included in this package.

Valkyrie Engineering & Design, LLC

Exclusions and Limitations:

Site specific calculations and/or analysis shall be completed by an EOR for any project found to have design conditions outside the scope of this package. Any changes to the racking system after issuance of this package but prior to the expiration shall be sent to Valkyrie Engineering & Design for written approval. All non-structural issues not covered in this design package including but not limited to corrosion, erosion, electrical, mechanical or waterproofing shall not be the responsibility of Valkyrie Engineering & Design and shall be addressed by the solar designer, installer, or owner.

The design conditions listed in the structural package are the extent of the racking systems structural sufficiency. It is the installer of the racking system to verify that the earth anchors achieve the required capacities for each project.

Notes and Material Specifications:

The intent of this package is to address the structural sufficiency of the components and assembled racking system and internal connections of the components to one another per the required loading criteria listed prior.

The means and methods of construction are the responsibility of the racking contractor and personell on site. Valkyrie Engineering & Design nor the EOR shall bear responsibility for the means and methods of the project construction as neither have control over the installation and erection of any project.

Any inspection required by the local authority having jurisdiction, shall be provided to the EOR.

Diagrams and drawings shown for reference only and shall not be scaled.

○ Material Specifications:

- All racking components are to be steel and shall have a minimum yield strength, F_y , 50KSI or greater, unless noted otherwise.
- All base plates shall be $\frac{1}{4}$ " thick with a minimum F_y of 50KSI.
- All cable braces shall be $\frac{3}{16}$ " \varnothing and have a minimum F_y of 36KSI.
- The rear legs shall consist of telescoping tube steel consisting of one universal external leg ($2\frac{3}{4}$ "x $2\frac{3}{4}$ " – 14ga) & one universal internal leg ($2\frac{3}{8}$ "x $2\frac{3}{8}$ " – 14ga).

Valkyrie Engineering & Design, LLC

- The front legs shall be Trailer Jack assemblies consisting of (3) tube steel parts. The lower tube section shall be 1-5/8" square with a minimum thickness of 12ga. The middle tube section shall be 2" square with a minimum thickness of 11ga. The upper tube section shall be 2-1/4" square and shall have a minimum thickness of 11ga.
- The diagonal brace is comprised of (2) telescoping steel tubes. The external bracing tube shall be 2" square and the internal bracing tube shall be 2.4" square. Each tube shall have a minimum thickness of 14ga.
- Each east-west long tube shall be a minimum HSS4" round tube with a minimum thickness of 11ga.
- Each north-south purlin shall be a cold formed section with a height of 2-5/8" and a width of 1-5/8". The minimum thickness shall be 11ga.
- Each purlin splice shall be a cold formed U-section with a height of 1.94" and a width of 1.97". It shall have a minimum thickness of 10ga.
- All bolts shall be 1/2"Ø A325 (Gr 5) Bolts except the U-bolt which shall be 3/8" Ø A325 (Gr 5) bolt.
- All connection brackets shall be a minimum of 10ga.

*Dimensions given in US Imperial units. It shall be acceptable to use equivalent metric sizes in lieu of the sizes given above.

OPR MAX - 4X3 -FOUNDATION SETS 2					
<u>BOM Level</u>		<u>QTY.</u>	<u>Part Description</u>	<u>Specification (in)</u>	<u>Part Number</u>
1			NS SLOPE PURLIN ASSEMBLY		
	2	12.0	NS PURLIN MAX	UNI2.56X1.65	OPR-821-11-215-093
	2	6.0	RAIL BRACKET	PL14X5.40	OPR-821-10-115-014
1			EW BEAM ASSEMBLY		
	2	6.0	EAST WEST BEAM	o101.6mm	OPR-821-11-235-098
1			SOUTH LEG- UNIVERSAL		
	2	2.0	12" FOUNDATION MAX	PL12X12X25	UNV-011-03-345-012
	2	2.0	FRONT LEG	TRAILER JACK	OPR-810-11-530-051
1			NORTH LEG - 0		
	2	2.0	18" FOUNDATION MAX	PL18X18X25	UNV-011-03-345-018
	2	2.0	UNIVERSAL EXTERNAL LEG	■70x70mm	OPR-821-14-215-054
	2	2.0	UNIVERSAL INTERNAL LEG	■60x60mm	OPR-821-14-215-060
	2	2.0	NORTH BRACKET	PL11.5X5.8	OPR-821-10-115-012
1			LATERAL BRACE		
	2	2.0	LATERAL BRACE EXTERNAL	■60x60mm	OPR-821-14-215-018
	2	2.0	LATERAL BRACE INTERNAL	■50x50mm	OPR-821-14-215-078
	2	2.0	LATERAL BRACKET	PL9.31X2.0	OPR-821-09-115-008
	2	2.0	CABLE BRACE	18FT 4MM CABLE BRACE	OPR-811-500-C18
1			SEISMIC BRACE		
	2	2.0	CABLE BRACE	18FT 4MM CABLE BRACE	OPR-811-500-C18
1			HARWARE		
	2	22.0	CARRIAGE BOLTS GENERAL	1/2-13-4.5" CARRIAGE BOLT	OPR-831-050-X45
	2	6.0	BRACING BOLTS	1/2-13-3" HEX HEAD BOLT	OPR-831-050-B03
	2	28.0	1/2" NUTS	1/2-13 SERRATED NUT	OPR-831-050-N12
	2	16.0	EW U-BOLT TUBE	3/8-16-4OD U-BOLT	OPR-831-050-U04
	2	24.0	SPLICE BOLTS	3/8-16-1" HEX HEAD BOLT	OPR-831-050-B01
	2	56.0	3/8" NUTS	3/8-16 SERRATED NUT	UNV-031-050-N38
	2	18.0	MID CLAMPS	SOLAR MASTERS	UNV-051-050-M05
	2	12.0	END CLAMPS	SOLAR MASTERS	UNV-051-050-E05
			ANCHORS -DEPENDS ON SOIL		
			6FT GRIPPLE ANCHOR LOW	GRIPPLE 6FT TLA3	UNV-223-007-01




OPR MAX - 4X4 -FOUNDATION SETS 3					
<u>BOM Level</u>		<u>QTY.</u>	<u>Part Description</u>	<u>Specification (in)</u>	<u>Part Number</u>
1			NS SLOPE PURLIN ASSEMBLY		
	2	16.0	NS PURLIN MAX	UNI2.56X1.65	OPR-821-11-215-093
	2	8.0	RAIL BRACKET	PL14X5.40	OPR-821-10-115-014
1			EW BEAM ASSEMBLY		
	2	6.0	EAST WEST BEAM	o101.6mm	OPR-821-11-235-098
1			SOUTH LEG- UNIVERSAL		
	2	3.0	12" FOUNDATION MAX	PL12X12X25	UNV-011-03-345-012
	2	3.0	FRONT LEG	TRAILER JACK	OPR-810-11-530-051
1			NORTH LEG - 0		
	2	3.0	18" FOUNDATION MAX	PL18X18X25	UNV-011-03-345-018
	2	3.0	UNIVERSAL EXTERNAL LEG	■70x70mm	OPR-821-14-215-054
	2	3.0	UNIVERSAL INTERNAL LEG	■60x60mm	OPR-821-14-215-060
	2	3.0	NORTH BRACKET	PL11.5X5.8	OPR-821-10-115-012
1			LATERAL BRACE		
	2	3.0	LATERAL BRACE EXTERNAL	■60x60mm	OPR-821-14-215-018
	2	3.0	LATERAL BRACE INTERNAL	■50x50mm	OPR-821-14-215-078
	2	3.0	LATERAL BRACKET	PL9.31X2.0	OPR-821-09-115-008
	2	3.0	CABLE BRACE	18FT 4MM CABLE BRACE	OPR-811-500-C18
1			SEISMIC BRACE		
	2	4.0	CABLE BRACE	18FT 4MM CABLE BRACE	OPR-811-500-C18
1			HARWARE		
	2	30.0	CARRIAGE BOLTS GENERAL	1/2-13-4.5" CARRIAGE BOLT	OPR-831-050-X45
	2	9.0	BRACING BOLTS	1/2-13-3" HEX HEAD BOLT	OPR-831-050-B03
	2	39.0	1/2" NUTS	1/2-13 SERRATED NUT	OPR-831-050-N12
	2	22.0	EW U-BOLT TUBE	3/8-16-4OD U-BOLT	OPR-831-050-U04
	2	32.0	SPLICE BOLTS	3/8-16-1" HEX HEAD BOLT	OPR-831-050-B01
	2	76.0	3/8" NUTS	3/8-16 SERRATED NUT	UNV-031-050-N38
	2	24.0	MID CLAMPS	SOLAR MASTERS	UNV-051-050-M05
	2	16.0	END CLAMPS	SOLAR MASTERS	UNV-051-050-E05
			ANCHORS -DEPENDS ON SOIL		
			6FT GRIPPLE ANCHOR LOW	GRIPPLE 6FT TLA3	UNV-223-007-01


OPR MAX - 4X5 -FOUNDATION SETS 4					
<u>BOM Level</u>		<u>QTY.</u>	<u>Part Description</u>	<u>Specification (in)</u>	<u>Part Number</u>
1			NS SLOPE PURLIN ASSEMBLY		
	2	20.0	NS PURLIN MAX	UNI2.56X1.65	OPR-821-11-215-093
	2	10.0	RAIL BRACKET	PL14X5.40	OPR-821-10-115-014
1			EW BEAM ASSEMBLY		
	2	8.0	EAST WEST BEAM	o101.6mm	OPR-821-11-235-098
1			SOUTH LEG- UNIVERSAL		
	2	4.0	12" FOUNDATION MAX	PL12X12X25	UNV-011-03-345-012
	2	4.0	FRONT LEG	TRAILER JACK	OPR-810-11-530-051
1			NORTH LEG - 0		
	2	4.0	18" FOUNDATION MAX	PL18X18X25	UNV-011-03-345-018
	2	4.0	UNIVERSAL EXTERNAL LEG	■70x70mm	OPR-821-14-215-054
	2	4.0	UNIVERSAL INTERNAL LEG	■60x60mm	OPR-821-14-215-060
	2	4.0	NORTH BRACKET	PL11.5X5.8	OPR-821-10-115-012
1			LATERAL BRACE		
	2	4.0	LATERAL BRACE EXTERNAL	■60x60mm	OPR-821-14-215-018
	2	4.0	LATERAL BRACE INTERNAL	■50x50mm	OPR-821-14-215-078
	2	4.0	LATERAL BRACKET	PL9.31X2.0	OPR-821-09-115-008
	2	4.0	CABLE BRACE	18FT 4MM CABLE BRACE	OPR-811-500-C18
1			SEISMIC BRACE		
	2	6.0	CABLE BRACE	18FT 4MM CABLE BRACE	OPR-811-500-C18
1			HARWARE		
	2	40.0	CARRIAGE BOLTS GENERAL	1/2-13-4.5" CARRIAGE BOLT	OPR-831-050-X45
	2	12.0	BRACING BOLTS	1/2-13-3" HEX HEAD BOLT	OPR-831-050-B03
	2	52.0	1/2" NUTS	1/2-13 SERRATED NUT	OPR-831-050-N12
	2	28.0	EW U-BOLT TUBE	3/8-16-4OD U-BOLT	OPR-831-050-U04
	2	40.0	SPLICE BOLTS	3/8-16-1" HEX HEAD BOLT	OPR-831-050-B01
	2	96.0	3/8" NUTS	3/8-16 SERRATED NUT	UNV-031-050-N38
	2	30.0	MID CLAMPS	SOLAR MASTERS	UNV-051-050-M05
	2	20.0	END CLAMPS	SOLAR MASTERS	UNV-051-050-E05
			ANCHORS -DEPENDS ON SOIL		
			6FT GRIPPLE ANCHOR LOW	GRIPPLE 6FT TLA3	UNV-223-007-01

Unit Types


4x3 Osprey PowerRack



4x4 Osprey PowerRack



4x5 Osprey PowerRack



Valkyrie Engineering & Design, LLC

Vertical & Lateral Load Calculations:

Site Design Criteria

Racking System Information:

- Array Size 4x3, 4x4, 4x5
- Module Size & Weight 95" x 45" & 69lbs
- Front Leg Height Range 26.8" to 52"
- Rear Leg Height Range 48.9" to 105"
- Table Tilt Range 15° to 30°

Wind Design Criteria:

- Wind Speed V (ult) 110 mph
- Exposure Category C
- Wind directional Factor (K_d) 0.85
- Velocity Pressure Coefficient (K_h) 0.85
- Topographic Factor (K_{zt}) 1.00
- Ground Elevation Factor (K_e) 1.00

Snow Loading:

- Ground Snow (P_g) 30 psf

Seismic Design Criteria:

- Site Class (assumed) D
- S_{Ds} 0.507g
- S_{D1} 0.096g
- Building Risk Category I
- Seismic Design Category D

Valkyrie Engineering & Design, LLC

Open Wind Pressure C&C Result Table

Clear Wind Flow, P					
Zone 3		Zone 2		Zone 1	
74.2 psf	-72.3 psf	74.2 psf	-72.3 psf	49.5 psf	-47.6 psf
Obstructed Wind Flow, P					
Zone 3		Zone 2		Zone 1	
45.7 psf	-66.6 psf	45.7 psf	-66.6 psf	30.4 psf	-43.8 psf

Seismic Loading Calculation:

$$\text{Base Shear (V)} = C_s * W$$

$$C_s = S_{DS} / (R/I)$$

$$R = 2.0 \text{ for Non-Building Structures Not Similar to Buildings}$$

$$I = 1.0 \text{ (Seismic Importance Factor)}$$



$$C_s = (.507) / (2/1) \Rightarrow (1/2) = .255$$

$$\text{Panel Weight, W} = 69\text{lbs}$$

$$V = (.255) * (69\text{lbs}) = 17.6\text{lbs}$$

$$\text{Panel Tributary Width per Purlin} = 3.96\text{ft}$$

$$\text{Panel Lateral Load Applied to Purlin} = (17.6\text{lbs}) / (3.96\text{ft}) = 4.4\text{plf}$$



Envelope Only Solution

GWRE

AB



OPR

4X3-30-110W,30S,3LEG-95"X45"

SK-1

Jul 28, 2022

4x3-30-110,30-2leg-95X45 28-07.r3d



Envelope Only Solution

GWRE

AB



OPR

4X3-30-110W,30S,3LEG-95"X45"

SK-2



Jul 28, 2022

4x3-30-110,30-2leg-95X45 28-07.r3d



Envelope Only Solution

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-3
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Envelope Only Solution

GWRE

AB



OPR

4X3-30-110W,30S,3LEG-95"X45"

SK-4



Jul 28, 2022

4x3-30-110,30-2leg-95X45 28-07.r3d





Loads: BLC 1, Dead
Envelope Only Solution

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-5
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Loads: BLC 2, Snow
Envelope Only Solution

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-6
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Loads: BLC 3, Wind Uplift - Balanced
Envelope Only Solution

GWRE

AB



OPR

4X3-30-110W,30S,3LEG-95"X45"

SK-7

Jul 28, 2022

4x3-30-110,30-2leg-95X45 28-07.r3d



Loads: BLC 4, Wind Uplift- Unbalanced
Envelope Only Solution

GWRE

AB



OPR

4X3-30-110W,30S,3LEG-95"X45"



SK-8

Jul 28, 2022

4x3-30-110,30-2leg-95X45 28-07.r3d





GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-9
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d





Loads: BLC 6, Wind Down - Unbalanced
Envelope Only Solution

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-10
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Loads: BLC 7, Seismic - X
Envelope Only Solution

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-11
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Loads: BLC 8, Seismic - Z
Envelope Only Solution

GWRE

AB



OPR-

4X3-30-110W,30S,3LEG-95"X45"



SK-12

Jul 28, 2022

4x3-30-110,30-2leg-95X45 28-07.r3d




GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-13
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d





Envelope Only Solution
Member y Shear Forces (lbs) (Enveloped)

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-14
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d





GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-15
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07,r3d






Envelope Only Solution
Member y Bending Moments (lb-ft) (Enveloped)

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-16
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d





Envelope Only Solution
Member z Bending Moments (lb-ft) (Enveloped)

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-17
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Member Code Checks Displayed (Enveloped)
Envelope Only Solution

GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-18
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



GWRE	4X3-30-110W,30S,3LEG-95"X45"	SK-19
AB		Jul 28, 2022
OPR		4x3-30-110,30-2leg-95X45 28-07.r3d



Company : GWRE
Designer : AB
Job Number : OPR
Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Node Coordinates

	Label	X [in]	Y [in]	Z [in]	Detach From Diaphragm
1	N19	31.5	58.4	-30.51104	
2	N20	31.5	58.4	249.48896	
3	N21	114	5.4	249.48896	
4	N22	114	5.4	-30.51104	
5	N33	31.5	-48.6	31.48896	
6	N34	114	-48.6	31.48896	
7	N35	31.5	-48.6	187.48896	
8	N36	114	-48.6	187.48896	
9	N65B	31.5	58.4	187.48896	
10	N66A	114	5.4	187.48896	
11	N59	31.5	58.4	31.48896	
12	N60	114	5.4	31.48896	
13	N59A	31.5	-43.6	187.48896	
14	N60B	114	-43.6	187.48896	
15	N61B	114	-43.6	31.48896	
16	N62	31.5	-43.6	31.48896	
17	N27	31.5	58.4	232.98896	
18	N28	114	5.4	-14.01104	
19	N29	31.5	58.4	177.98896	
20	N30	114	5.4	40.98896	
21	N31	31.5	58.4	136.98896	
22	N32	114	5.4	81.98896	
23	N37	31.5	58.4	81.98896	
24	N38	114	5.4	136.98896	
25	N42	31.5	58.4	40.98896	
26	N43	114	5.4	177.98896	
27	N44	31.5	58.4	-14.01104	
28	N45	114	5.4	232.98896	
29	N46	-5.5	82.169697	-14.01104	
30	N47	151	-18.369697	-14.01104	
31	N48	-5.5	82.169697	40.98896	
32	N49	151	-18.369697	40.98896	
33	N50	-5.5	82.169697	81.98896	
34	N52	151	-18.369697	81.98896	
35	N58	-5.5	82.169697	136.98896	
36	N61	151	-18.369697	136.98896	
37	N63	-5.5	82.169697	177.98896	



Company : GWRE
Designer : AB
Job Number : OPR
Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Node Coordinates (Continued)

	Label	X [in]	Y [in]	Z [in]	Detach From Diaphragm
38	N64	151	-18.369697	177.98896	
39	N65	-5.5	82.169697	232.98896	
40	N66	151	-18.369697	232.98896	

Hot Rolled Steel Properties

	Label	E [ksi]	G [ksi]	Nu	Therm. Coeff. [1e ⁵ °F ⁻¹]	Density [k/ft ³]	Yield [ksi]	Ry	Fu [ksi]	Rt
1	A36 Gr.36	29000	11154	0.3	0.65	0.49	36	1.5	58	1.2
2	Cable	29000	11154	0.3	0.65	0	150	1.5	160	1.2
3	A572 Gr.50	29000	11154	0.3	0.65	0.49	50	1.1	65	1.1
4	A992	29000	11154	0.3	0.65	0.49	50	1.1	65	1.1
5	A500 Gr.42	29000	11154	0.3	0.65	0.49	42	1.4	58	1.3
6	A500 Gr.46	29000	11154	0.3	0.65	0.49	46	1.4	58	1.3
7	HR Grade 60	29000	11154	0.3	0.65	0.49	60	1.5	72	1.2
8	HR Grade 80	29000	11154	0.3	0.65	0.49	80	1.5	90	1.2
9	HR Grade 51.5	29000	11154	0.3	0.65	0.49	51.5	1.5	65	1.2

Cold Formed Steel Properties

	Label	E [ksi]	G [ksi]	Nu	Therm. Coeff. [1e ⁵ °F ⁻¹]	Density [k/ft ³]	Yield [ksi]	Fu [ksi]
1	A570 Gr.33	29500	11346	0.3	0.65	0.49	33	52
2	A607 C1 Gr.55	29500	11346	0.3	0.65	0.49	55	70
3	Grade 50 Steel	29500	11346	0.3	0.65	0.49	50	65
4	Grade 60 Steel	29500	11346	0.3	0.65	0.49	60	72
5	Grade 80 Steel	29500	11346	0.3	0.65	0.49	80	90
6	Grade 51.5 Steel	29500	11346	0.3	0.65	0.49	51.5	65

Hot Rolled Steel Section Sets

	Label	Shape	Type	Design List	Material	Design Rule	Area [in ²]	Iyy [in ⁴]	Izz [in ⁴]	J [in ⁴]
1	Cable Brace	3.0MMCABLE	VBrace	BAR	Cable	Typical	0.011	1e-5	1e-5	1.9e-5
2	HSS4"x11GA	HSS4"X0.125	Beam	Pipe	HR Grade 51.5	Typical	1.519	2.854	2.854	5.707
3	HSS2.375"x14ga	HSS2.375"X14GA	Column	Tube	HR Grade 51.5	Typical	0.717	0.631	0.631	0.945
4	HSS2"X14GA	HSS2"X14GA	Column	Tube	HR Grade 51.5	Typical	0.6	0.37	0.37	0.554



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Cold Formed Steel Section Sets

	Label	Shape	Type	Design List	Material	Design Rule	Area [in ²]	Iyy [in ⁴]	Izz [in ⁴]	J [in ⁴]
1	NS PURLIN	NSPURLIN	Beam	CS	Grade 51.5 Steel	Typical	0.846	0.62	0.372	0.004

Member Primary Data

	Label	I Node	J Node	Rotate(deg)	Section/Shape	Type	Design List	Material	Design Rule
1	M12	N20	N19		HSS4"x11GA	Beam	Pipe	HR Grade 51.5	Typical
2	M13	N22	N21		HSS4"x11GA	Beam	Pipe	HR Grade 51.5	Typical
3	M29A	N65B	N35		HSS2.375"x14ga	Column	Tube	HR Grade 51.5	Typical
4	M30B	N66A	N36		HSS2"x14GA	Column	Tube	HR Grade 51.5	Typical
5	M31A	N60	N34		HSS2"x14GA	Column	Tube	HR Grade 51.5	Typical
6	M32	N59	N33		HSS2.375"x14ga	Column	Tube	HR Grade 51.5	Typical
7	M35A	N59A	N59		Cable Brace	VBrace	BAR	Cable	Typical
8	M36	N65B	N62		Cable Brace	VBrace	BAR	Cable	Typical
9	M33	N59A	N66A		HSS2"x14GA	Column	Tube	HR Grade 51.5	Typical
10	M34	N65B	N60B		Cable Brace	VBrace	BAR	Cable	Typical
11	M37	N62	N60		HSS2"x14GA	Column	Tube	HR Grade 51.5	Typical
12	M38	N59	N61B		Cable Brace	VBrace	BAR	Cable	Typical
13	M26	N46	N47	270	NS PURLIN	Beam	CS	Grade 51.5 Steel	Typical
14	M27	N48	N49	270	NS PURLIN	Beam	CS	Grade 51.5 Steel	Typical
15	M28	N50	N52	270	NS PURLIN	Beam	CS	Grade 51.5 Steel	Typical
16	M29	N58	N61	270	NS PURLIN	Beam	CS	Grade 51.5 Steel	Typical
17	M30	N63	N64	270	NS PURLIN	Beam	CS	Grade 51.5 Steel	Typical
18	M31	N65	N66	270	NS PURLIN	Beam	CS	Grade 51.5 Steel	Typical

Basic Load Cases

	BLC Description	Category	X Gravity	Y Gravity	Z Gravity	Distributed
1	Dead	DL		-1		6
2	Snow	SL				6
3	Wind Uplift - Balanced	WL				6
4	Wind Uplift- Unbalanced	WL				12
5	Wind Down - Balanced	WL				6
6	Wind Down - Unbalanced	WL				12
7	Seismic - X	ELX	0.5			6
8	Seismic - Z	ELZ			0.5	6
9	Live	LL				



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Basic Load Cases (Continued)

	BLC Description	Category	X Gravity	Y Gravity	Z Gravity	Distributed
10	Diff. Settlement	EPL				
11	Self Weight	OL1		-1		

Load Combinations

	Description	Solve	P-Delta	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor	BLC	Factor
1	ASCE ASD 1	Yes	Y	DL	1										
2	ASCE ASD 2	Yes	Y	DL	1	LL	1	LLS	1						
3	ASCE ASD 3 (a)	Yes	Y	DL	1										
4	ASCE ASD 3 (b)	Yes	Y	DL	1	SL	1	SLN	1						
5	ASCE ASD 4 (b)	Yes	Y	DL	1	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75		
6	ASCE ASD 5 (a)	Yes	Y	DL	1	3	0.6								
7	ASCE ASD 5 (a)	Yes	Y	DL	1	4	0.6								
8	ASCE ASD 5 (a)	Yes	Y	DL	1	5	0.6								
9	ASCE ASD 5 (a)	Yes	Y	DL	1	6	0.6								
10	ASCE ASD 6 (a)	Yes	Y	DL	1	3	0.45	LL	0.75	LLS	0.75				
11	ASCE ASD 6 (a)	Yes	Y	DL	1	4	0.45	LL	0.75	LLS	0.75				
12	ASCE ASD 6 (a)	Yes	Y	DL	1	5	0.45	LL	0.75	LLS	0.75				
13	ASCE ASD 6 (a)	Yes	Y	DL	1	6	0.45	LL	0.75	LLS	0.75				
14	ASCE ASD 6 (c)	Yes	Y	DL	1	3	0.45	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75
15	ASCE ASD 6 (c)	Yes	Y	DL	1	4	0.45	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75
16	ASCE ASD 6 (c)	Yes	Y	DL	1	5	0.45	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75
17	ASCE ASD 6 (c)	Yes	Y	DL	1	6	0.45	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75
18	ASCE ASD 7	Yes	Y	DL	0.6	3	0.6								
19	ASCE ASD 7	Yes	Y	DL	0.6	4	0.6								
20	ASCE ASD 7	Yes	Y	DL	0.6	5	0.6								
21	ASCE ASD 7	Yes	Y	DL	0.6	6	0.6								
22	ASCE ASD 5 (b) (a)	Yes	Y	DL	1	ELX	0.7								
23	ASCE ASD 5 (b) (b)	Yes	Y	DL	1	ELZ	0.7								
24	ASCE ASD 6 (b) (a)	Yes	Y	DL	1	ELX	0.525	LL	0.75	LLS	0.75				
25	ASCE ASD 6 (b) (b)	Yes	Y	DL	1	ELZ	0.525	LL	0.75	LLS	0.75				
26	ASCE ASD 6 (d) (a)	Yes	Y	DL	1	ELX	0.525	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75
27	ASCE ASD 6 (d) (b)	Yes	Y	DL	1	ELZ	0.525	LL	0.75	LLS	0.75	SL	0.75	SLN	0.75
28	ASCE ASD 8 (a)	Yes	Y	DL	0.6	ELX	0.7								
29	ASCE ASD 8 (b)	Yes	Y	DL	0.6	ELZ	0.7								
30	Diff. Settlement		Y	DL	1	EPL	1	5	0.6						
31	Self-Weight		Y	11	1										



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Envelope Node Reactions

Node Label			X [lb]	LC	Y [lb]	LC	Z [lb]	LC	MX [lb-ft]	LC	MY [lb-ft]	LC	MZ [lb-ft]	LC
1	N35	max	2150.967	8	4318.53	8	6.741	19	0	29	0	29	0	29
2		min	-1905.034	6	-3716.193	19	-16.3	29	0	1	0	1	0	1
3	N36	max	100.137	20	2371.721	15	14.557	16	0	29	0	29	0	29
4		min	-24.391	18	-243.788	20	-72.697	29	0	1	0	1	0	1
5	N34	max	100.137	20	2371.721	15	11.456	18	0	29	0	29	0	29
6		min	-24.391	18	-243.788	20	-73.568	29	0	1	0	1	0	1
7	N33	max	2150.967	8	4318.53	8	-0.309	28	0	29	0	29	0	29
8		min	-1905.034	6	-3716.193	19	-338.148	23	0	1	0	1	0	1
9	Totals:	max	4500.445	8	10457.327	16	0	17						
10		min	-3857.395	6	-5151.307	18	-497.658	23						

Envelope Member Section Deflections - Service

Member	Sec		x [in]	LC	y [in]	LC	z [in]	LC	x Rotate [rad]	LC	(n) L/y' Ratio	LC	(n) L/z' Ratio	LC	
1	M12	1	max	0	19	0.527	19	0.437	19	0.005	19	NC	28	NC	28
2			min	-0.399	23	-0.726	16	-0.464	8	-0.002	16	6129.772	23	4582.15	23
3		2	max	0	19	0.03	19	0.118	7	0.004	19	NC	14	NC	29
4			min	-0.399	23	-0.032	16	-0.135	20	-0.002	16	403.384	16	848.49	8
5		3	max	0	28	0.264	19	0.282	7	0.005	19	NC	28	NC	29
6			min	-0.399	23	-0.359	16	-0.266	20	-0.003	16	763.171	16	1311.321	16
7		4	max	0	4	0.03	19	0.118	7	0.004	19	NC	14	NC	29
8			min	-0.4	23	-0.032	16	-0.135	20	-0.002	16	403.384	16	848.49	8
9		5	max	0	4	0.527	19	0.437	19	0.005	19	NC	29	NC	29
10			min	-0.4	23	-0.726	16	-0.464	8	-0.002	16	NC	1	NC	1
11	M13	1	max	0.537	23	0.364	18	0.49	9	0.001	18	NC	29	NC	29
12			min	0	20	-0.75	17	-0.38	18	-0.005	9	NC	1	NC	1
13		2	max	0.537	23	0.001	20	0.106	20	0.001	18	NC	29	NC	29
14			min	0	20	-0.02	15	-0.093	6	-0.004	9	380.565	17	700.278	9
15		3	max	0.537	23	0.162	18	0.266	21	0.001	18	NC	29	NC	29
16			min	0	1	-0.388	17	-0.215	6	-0.005	9	774.457	17	1195.586	17
17		4	max	0.537	23	0.007	29	0.106	20	0.001	18	NC	14	NC	28
18			min	0	6	-0.02	15	-0.093	6	-0.004	9	380.565	17	700.278	9
19		5	max	0.537	23	0.364	18	0.49	9	0.001	18	NC	28	NC	28
20			min	0	14	-0.75	17	-0.38	18	-0.005	9	2352.124	23	2408.016	23
21	M29A	1	max	0.021	16	0.144	20	0	19	0.002	8	NC	29	NC	29
22			min	-0.017	19	-0.125	7	-0.399	23	-0.002	19	NC	1	NC	1



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Envelope Member Section Deflections - Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	z [in]	LC	x Rotate [rad]	LC	(n) L/y' Ratio	LC	(n) L/z' Ratio	LC	
23		2	max	0.016	16	0.188	21	0.017	17	0.002	8	NC	29	NC	28
24			min	-0.013	19	-0.163	6	-0.353	23	-0.002	19	993.482	21	1980.194	23
25		3	max	0.011	16	0.266	20	0.018	17	0.002	8	NC	29	NC	28
26			min	-0.009	19	-0.229	6	-0.261	23	-0.001	19	505.734	21	1742.891	23
27		4	max	0.005	16	0.251	20	0.01	17	0.001	8	NC	29	NC	28
28			min	-0.005	19	-0.212	6	-0.137	23	-0.001	19	498.77	20	2855.848	23
29		5	max	0	29	0	29	0	29	0.001	27	NC	29	NC	29
30			min	0	1	0	1	0	1	-0.001	19	NC	1	NC	1
31	M30B	1	max	0.009	15	0.096	20	0	14	0.001	27	NC	29	NC	29
32			min	-0.001	20	-0.083	6	-0.537	23	0	20	807.888	7	NC	1
33		2	max	0.007	15	0.111	21	0.015	16	0.001	27	NC	29	NC	28
34			min	0	20	-0.088	6	-0.479	23	0	20	1107.527	9	711.427	23
35		3	max	0.005	15	0.099	9	0.017	16	0.001	27	NC	29	NC	28
36			min	0	20	-0.071	18	-0.355	23	0	20	939.266	9	620.847	23
37		4	max	0.002	15	0.058	9	0.011	16	0.001	27	NC	29	NC	28
38			min	0	20	-0.039	18	-0.189	23	0	20	1441.48	9	990.918	23
39		5	max	0	29	0	29	0	29	0.001	27	NC	29	NC	29
40			min	0	1	0	1	0	1	0	20	NC	1	NC	1
41	M31A	1	max	0.009	15	0.096	20	0	20	0	29	NC	29	NC	29
42			min	-0.001	20	-0.083	6	-0.537	23	-0.001	15	807.888	7	NC	1
43		2	max	0.007	15	0.111	21	0.012	18	0	29	NC	29	NC	28
44			min	0	20	-0.088	6	-0.481	23	-0.001	15	1107.527	9	693.081	23
45		3	max	0.005	15	0.099	9	0.013	18	0	29	NC	29	NC	28
46			min	0	20	-0.071	18	-0.358	23	-0.001	15	939.266	9	604.805	23
47		4	max	0.002	15	0.058	9	0.008	18	0	29	NC	29	NC	28
48			min	0	20	-0.039	18	-0.19	23	-0.001	15	1441.48	9	965.219	23
49		5	max	0	29	0	29	0	29	0	29	NC	29	NC	29
50			min	0	1	0	1	0	1	-0.001	15	NC	1	NC	1
51	M32	1	max	0.021	16	0.144	20	0	4	0.002	19	NC	29	NC	29
52			min	-0.017	19	-0.125	7	-0.4	23	-0.002	8	NC	1	NC	1
53		2	max	0.016	16	0.188	21	0.007	18	0.002	19	NC	29	NC	28
54			min	-0.013	19	-0.163	6	-0.378	23	-0.002	8	993.482	21	1363.795	23
55		3	max	0.011	16	0.266	20	0.006	18	0.001	19	NC	29	NC	28
56			min	-0.009	19	-0.229	6	-0.311	23	-0.002	8	505.734	21	961.72	23
57		4	max	0.005	16	0.251	20	0.002	18	0.001	29	NC	29	NC	28
58			min	-0.005	19	-0.212	6	-0.188	23	-0.001	8	498.77	20	1217.804	23
59		5	max	0	29	0	29	0	29	0.002	29	NC	29	NC	29



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Envelope Member Section Deflections - Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	z [in]	LC	x Rotate [rad]	LC	(n) L/y' Ratio	LC	(n) L/z' Ratio	LC
60		min	0	1	0	1	0	1	-0.001	8	NC	1	NC	1
61	M35A	max	0.001	15	0.014	23	0.062	6	0.01	6	NC	29	NC	29
62		min	-0.022	23	-0.002	16	-0.074	20	-0.011	20	NC	1	NC	1
63		max	0.003	19	0.065	23	0.078	6	0.007	6	NC	29	NC	29
64		min	-0.1	23	-0.006	16	-0.091	20	-0.008	20	NC	1	NC	1
65		max	0.005	19	0.116	23	0.093	6	0.005	19	NC	29	NC	29
66		min	-0.179	23	-0.01	16	-0.109	20	-0.006	8	NC	1	NC	1
67		max	0.007	19	0.166	23	0.109	6	0.004	19	NC	29	NC	29
68		min	-0.257	23	-0.014	16	-0.127	20	-0.003	8	NC	1	NC	1
69		max	0.01	19	0.217	23	0.125	7	0.002	19	NC	29	NC	29
70		min	-0.336	23	-0.018	16	-0.144	20	-0.001	14	NC	1	NC	1
71	M36	max	0.011	16	0.015	19	0.125	7	0.002	19	NC	29	NC	29
72		min	-0.332	23	-0.221	23	-0.144	20	-0.001	14	NC	1	NC	1
73		max	0.008	16	0.011	19	0.109	6	0.004	19	NC	29	NC	29
74		min	-0.257	23	-0.172	23	-0.127	20	-0.003	8	NC	1	NC	1
75		max	0.005	16	0.008	19	0.093	6	0.005	19	NC	29	NC	29
76		min	-0.183	23	-0.122	23	-0.109	20	-0.006	8	NC	1	NC	1
77		max	0.003	8	0.004	19	0.078	6	0.007	6	NC	29	NC	29
78		min	-0.108	23	-0.072	23	-0.091	20	-0.008	20	NC	1	NC	1
79		max	0	20	0.001	18	0.062	6	0.01	6	NC	29	NC	29
80		min	-0.034	23	-0.022	23	-0.074	20	-0.011	20	NC	1	NC	1
81	M33	max	0.054	6	0.037	20	0.026	23	0.004	23	NC	29	NC	29
82		min	-0.064	20	-0.031	6	-0.002	17	-0.001	16	NC	1	NC	1
83		max	0.058	6	0.219	20	0.159	23	0.003	23	NC	29	NC	29
84		min	-0.069	20	-0.187	6	-0.001	17	0	17	535.773	20	NC	1
85		max	0.062	6	0.222	21	0.289	23	0.002	23	NC	29	NC	29
86		min	-0.073	20	-0.188	6	-0.001	17	0	7	518.998	21	NC	1
87		max	0.066	6	0.142	21	0.415	23	0.002	23	NC	29	NC	29
88		min	-0.078	20	-0.112	6	0	17	-0.001	7	924.631	21	NC	1
89		max	0.07	6	0.05	20	0.537	23	0.001	8	NC	29	NC	29
90		min	-0.082	20	-0.045	6	0	14	-0.001	19	NC	1	NC	1
91	M34	max	0.069	6	0.108	19	0.399	23	0.002	16	NC	29	NC	29
92		min	-0.077	20	-0.124	8	0	19	-0.001	18	NC	1	NC	1
93		max	0.054	6	0.082	19	0.317	23	0.003	27	NC	29	NC	29
94		min	-0.061	20	-0.097	8	-0.001	16	-0.001	18	NC	1	NC	1
95		max	0.04	6	0.058	18	0.235	23	0.005	23	NC	29	NC	29
96		min	-0.045	20	-0.07	8	-0.002	16	0	18	NC	1	NC	1



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Envelope Member Section Deflections - Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	z [in]	LC	x Rotate [rad]	LC	(n) L/y' Ratio	LC	(n) L/z' Ratio	LC	
97		4	max	0.025	6	0.035	18	0.153	23	0.007	23	NC	29	NC	29
98			min	-0.029	20	-0.043	8	-0.003	16	0	18	NC	1	NC	1
99		5	max	0.01	6	0.011	18	0.071	23	0.009	23	NC	29	NC	29
100			min	-0.014	21	-0.018	9	-0.004	16	0	20	NC	1	NC	1
101	M37	1	max	0.054	6	0.037	20	0.04	23	0.006	23	NC	29	NC	29
102			min	-0.064	20	-0.031	6	0	18	-0.001	18	NC	1	NC	1
103		2	max	0.058	6	0.219	20	0.17	23	0.005	23	NC	29	NC	29
104			min	-0.069	20	-0.187	6	0	18	0	18	535.773	20	NC	1
105		3	max	0.062	6	0.222	21	0.296	23	0.003	23	NC	29	NC	29
106			min	-0.073	20	-0.188	6	0	18	0	20	518.998	21	NC	1
107		4	max	0.066	6	0.142	21	0.418	23	0.002	23	NC	29	NC	29
108			min	-0.078	20	-0.112	6	0	18	-0.001	20	924.631	21	NC	1
109		5	max	0.07	6	0.05	20	0.537	23	0.001	19	NC	29	NC	29
110			min	-0.082	20	-0.045	6	0	20	-0.001	8	NC	1	NC	1
111	M38	1	max	0.069	6	0.108	19	0.4	23	0.001	18	NC	29	NC	29
112			min	-0.077	20	-0.124	8	0	4	-0.002	16	NC	1	NC	1
113		2	max	0.054	6	0.082	19	0.318	23	0.002	29	NC	29	NC	29
114			min	-0.061	20	-0.097	8	-0.001	18	-0.002	16	NC	1	NC	1
115		3	max	0.04	6	0.058	18	0.236	23	0.005	23	NC	29	NC	29
116			min	-0.045	20	-0.07	8	-0.002	18	-0.001	16	NC	1	NC	1
117		4	max	0.025	6	0.035	18	0.154	23	0.007	23	NC	29	NC	29
118			min	-0.029	20	-0.043	8	-0.002	18	-0.001	17	NC	1	NC	1
119		5	max	0.01	6	0.011	18	0.072	23	0.009	23	NC	29	NC	29
120			min	-0.014	21	-0.018	9	-0.003	18	-0.001	15	NC	1	NC	1
121	M26	1	max	0.151	14	0.131	16	0.928	19	0.012	19	NC	29	NC	29
122			min	-0.092	20	-0.383	29	-0.921	16	-0.015	16	NC	1	NC	1
123		2	max	0.15	14	0.002	19	0.464	19	0.012	19	NC	28	NC	29
124			min	-0.092	20	-0.402	23	-0.57	16	-0.015	16	2108.368	16	544.91	16
125		3	max	0.15	14	0.028	19	0.415	18	0.01	18	NC	29	NC	29
126			min	-0.091	20	-0.473	23	-0.621	16	-0.015	16	2386.691	19	662.202	16
127		4	max	0.15	14	0.007	15	0.35	18	0.01	18	NC	29	NC	28
128			min	-0.091	20	-0.534	23	-0.57	17	-0.017	17	1925.552	15	521.191	17
129		5	max	0.15	14	0.031	20	0.568	18	0.01	18	NC	29	NC	29
130			min	-0.091	20	-0.599	23	-1.044	17	-0.017	17	NC	1	NC	1
131	M27	1	max	0.088	6	0.053	19	0.49	19	0.003	16	NC	29	NC	29
132			min	-0.096	20	-0.423	23	-0.411	16	-0.003	19	NC	1	NC	1
133		2	max	0.088	6	0.005	16	0.083	19	0.003	16	NC	28	NC	14



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Envelope Member Section Deflections - Service (Continued)

	Member	Sec		x [in]	LC	y [in]	LC	z [in]	LC	x Rotate [rad]	LC	(n) L/y' Ratio	LC	(n) L/z' Ratio	LC
134			min	-0.096	20	-0.4	23	-0.098	8	-0.003	19	2710.282	16	571.082	16
135		3	max	0.086	6	0.026	8	0.114	18	0.003	16	NC	29	NC	29
136			min	-0.094	20	-0.478	23	-0.147	8	-0.002	18	2100.546	19	707.074	16
137		4	max	0.083	6	0.002	20	0.046	18	0.003	17	NC	28	NC	29
138			min	-0.091	20	-0.537	23	-0.057	8	-0.002	18	2645.242	15	497.524	17
139		5	max	0.083	6	0.089	15	0.263	18	0.003	17	NC	29	NC	29
140			min	-0.091	20	-0.536	23	-0.493	9	-0.002	18	NC	1	NC	1
141	M28	1	max	0.146	14	0.001	20	0.747	19	0.006	16	NC	29	NC	29
142			min	-0.078	20	-0.426	23	-0.682	16	-0.005	19	NC	1	NC	1
143		2	max	0.146	14	0.004	4	0.297	19	0.006	16	NC	28	8704.184	28
144			min	-0.078	20	-0.399	23	-0.324	16	-0.005	19	2532.138	27	531.894	16
145		3	max	0.147	14	0.008	19	0.259	18	0.006	16	NC	29	NC	29
146			min	-0.078	20	-0.475	23	-0.376	16	-0.003	18	7829.055	7	642.751	16
147		4	max	0.147	14	0	19	0.202	18	0.006	17	NC	28	NC	29
148			min	-0.079	20	-0.537	23	-0.331	17	-0.003	18	3780.76	27	507.859	17
149		5	max	0.147	14	0.077	4	0.422	18	0.006	17	NC	29	NC	29
150			min	-0.079	20	-0.542	23	-0.8	9	-0.003	18	NC	1	NC	1
151	M29	1	max	0.146	14	0.077	4	0.747	19	0.005	19	NC	29	NC	29
152			min	-0.078	20	-0.395	29	-0.682	16	-0.006	16	NC	1	NC	1
153		2	max	0.146	14	0	20	0.297	19	0.005	19	NC	28	NC	29
154			min	-0.078	20	-0.401	23	-0.324	16	-0.006	16	4053.229	15	531.894	16
155		3	max	0.147	14	0.007	8	0.259	18	0.003	18	NC	29	NC	29
156			min	-0.078	20	-0.475	23	-0.376	16	-0.006	16	7829.055	7	642.751	16
157		4	max	0.147	14	0.004	4	0.202	18	0.003	18	NC	29	NC	28
158			min	-0.079	20	-0.535	23	-0.331	17	-0.006	17	4148.11	16	507.859	17
159		5	max	0.147	14	0.007	19	0.422	18	0.003	18	NC	29	NC	29
160			min	-0.079	20	-0.574	23	-0.8	9	-0.006	17	NC	1	NC	1
161	M30	1	max	0.088	6	0.091	16	0.49	19	0.003	19	NC	29	NC	29
162			min	-0.096	20	-0.399	29	-0.411	16	-0.003	16	NC	1	NC	1
163		2	max	0.088	6	0.003	19	0.083	19	0.003	19	NC	28	NC	29
164			min	-0.096	20	-0.4	23	-0.098	8	-0.003	16	2710.282	16	571.082	16
165		3	max	0.086	6	0.032	19	0.114	18	0.002	18	NC	29	NC	29
166			min	-0.094	20	-0.477	23	-0.147	8	-0.003	16	2100.546	19	707.074	16
167		4	max	0.083	6	0.005	15	0.046	18	0.002	18	NC	29	NC	28
168			min	-0.091	20	-0.536	23	-0.057	8	-0.003	17	2645.242	15	497.524	17
169		5	max	0.083	6	0.033	20	0.263	18	0.002	18	NC	29	NC	29
170			min	-0.091	20	-0.561	23	-0.493	9	-0.003	17	NC	1	NC	1



Company : GWRE
 Designer : AB
 Job Number : OPR
 Model Name : 4X3-30-110W,30S,3LEG-95"X45"

Checked By : _____

Envelope Member Section Deflections - Service (Continued)


Member	Sec		x [in]	LC	y [in]	LC	z [in]	LC	x Rotate [rad]	LC	(n) L/y' Ratio	LC	(n) L/z' Ratio	LC	
171	M31	1	max	0.151	14	0.031	19	0.928	19	0.015	16	NC	29	NC	29
172			min	-0.092	20	-0.433	27	-0.921	16	-0.012	19	NC	1	NC	1
173		2	max	0.15	14	0.007	16	0.464	19	0.015	16	NC	28	8586.728	29
174			min	-0.092	20	-0.399	23	-0.57	16	-0.012	19	1977.833	27	544.91	16
175		3	max	0.15	14	0.023	8	0.415	18	0.015	16	NC	29	NC	29
176			min	-0.091	20	-0.473	23	-0.621	16	-0.01	18	2386.691	19	662.202	16
177		4	max	0.15	14	0.002	20	0.35	18	0.017	17	NC	29	NC	29
178			min	-0.091	20	-0.537	23	-0.57	17	-0.01	18	1925.552	15	521.191	17
179		5	max	0.15	14	0.141	15	0.568	18	0.017	17	NC	29	NC	29
180			min	-0.091	20	-0.547	29	-1.044	17	-0.01	18	NC	1	NC	1

Envelope AISC 14TH (360-10): ASD Member Steel Code Checks




Member	Shape	Code Check	Loc[in]	LC	Shear Check	Loc[in]	Dir	LC	Pnc/om [lb]	Pnt/om [lb]	Mnyy/om [lb-ft]	Mnzz/om [lb-ft]	Cb	Eqn	
1	M12	HSS4"X0.125	0.711	218.75	16	0.199	215.833		16	43100.663	46829.228	4815.458	4815.458	1	H1-1b
2	M13	HSS4"X0.125	0.768	218.75	17	0.157	215.833		17	43100.663	46829.228	4815.458	4815.458	1	H1-1b
3	M29A	HSS2.375"X14GA	1	102.542	8	0.364	107	y	8	8283.238	22100.716	1558.333	1558.333	2.527	H1-1a
4	M30B	HSS2"X14GA	0.323	0	23	0.019	54	y	8	12952.26	18492.632	1111.323	1111.323	1.663	H1-1b
5	M31A	HSS2"X14GA	0.349	0	27	0.019	54	y	8	12952.26	18492.632	1111.323	1111.323	1.653	H1-1b
6	M32	HSS2.375"X14GA	1	102.542	8	0.364	107	y	8	8283.238	22100.716	1558.333	1558.333	2.527	H1-1a
7	M35A	3.0MMMCABLE	0.012	186.387	19	0.001	186.387		6	0.043	982.275	2.03	2.03	1	H1-1b*
8	M36	3.0MMMCABLE	0.413	186.387	23	0.001	186.387		6	0.043	982.275	2.03	2.03	1	H1-1a*
9	M33	HSS2"X14GA	0.725	0	8	0.026	0	y	8	6037.11	18492.632	1111.323	1111.323	2.201	H1-1a
10	M34	3.0MMMCABLE	0.125	131.188	20	0.001	131.188		29	0.087	982.275	2.03	2.03	1	H1-1b*
11	M37	HSS2"X14GA	0.725	0	8	0.033	95.954	y	23	6037.11	18492.632	1111.323	1111.323	2.201	H1-1a
12	M38	3.0MMMCABLE	0.125	131.188	20	0	131.188		8	0.087	982.275	2.03	2.03	1	H1-1b*

Envelope AISI S100-10: ASD Member Cold Formed Steel Code Checks

Member	Shape	Code Check	Loc[in]	LC	Shear Check	Loc[in]	Dir	LC	Pn/Om[lb]	Tn/Om[lb]	Mnyy/Om[lb-ft]	Mnzz/Om[lb-ft]	Cb	Cmyy	Cmzz	Eqn	
1	M26	NSPURLIN	0.702	141.447	17	0.06	141.447	z	17	7723.227	26095.313	1232.913	1157.296	1	0.85	0.6	C5.2.1-2
2	M27	NSPURLIN	0.845	44.565	19	0.061	141.447	z	17	7723.227	26095.313	1027.555	1157.296	1	0.85	0.6	C5.2.1-2
3	M28	NSPURLIN	0.7	141.447	17	0.059	141.447	z	17	7723.227	26095.313	1232.913	1157.296	1	0.85	0.6	C5.2.1-2
4	M29	NSPURLIN	0.7	141.447	17	0.059	141.447	z	17	7723.227	26095.313	1232.913	1157.296	1	0.85	0.6	C5.2.1-2
5	M30	NSPURLIN	0.845	44.565	19	0.061	141.447	z	17	7723.227	26095.313	1027.555	1157.296	1	0.85	0.6	C5.2.1-2
6	M31	NSPURLIN	0.702	141.447	17	0.06	141.447	z	17	7723.227	26095.313	1232.913	1157.296	1	0.85	0.6	C5.2.1-2






4x3 Plan & Elevation



Member Code Checks Displayed (Enveloped)
Envelope Only Solution

GWRE	4X4-30-110W,30S,3LEG-95"X45"	SK-18
AB		Jul 28, 2022
OPR-LITE		4x4-30-110,30-3leg-95X45_28-07.r3d



Member Shear Checks Displayed (Enveloped)
Envelope Only Solution

GWRE	4X4-30-110W,30S,3LEG-95"X45"	SK-19
AB		Jul 28, 2022
OPR-LITE		4x4-30-110,30-3leg-95X45_28-07.r3d



9/25/2023

FREEDOM FOREVER LLC

43445 BUSINESS PARK DR #110
TEMECULA, CA 92590

Subject: Structural Certification for Installation of Residential Ground Mounted Solar

Project: Sunil Patel

Address: 518 SOUTHWEST WINDSOR DRIVE
LAKE
CITY, FL 32024

Attn.: To Whom It May Concern

The following calculations are for the structural engineering design of the PV ground mount racking and are valid only for the structural information referenced in the stamped plan set. The verification of such info is the responsibility of others. All PV mounting equipment shall be designed and installed per manufacturer's approved installation specifications.

We approve the plans for the above-referenced solar installation per the structural certification provided by:
Valkyrie Engineering & Design, LLC , Dated July 14, 2023
Refer to Attachment A

Limitations:

Installation of the solar panels must be performed in accordance with manufacturer recommendations. All work performed must be in accordance with accepted industry-wide methods and applicable safety standards. The contractor shall notify the consultant should any damage, deterioration, or discrepancies between the as-built condition of the structure and the condition described in this letter be found.

If you have any questions, don't hesitate to contact us.



This item has been electronically signed and sealed by Methode Maniraguha using a Digital Signature and Date. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally
signed by
Methode
Maniraguha
Date:
2023.09.26
12:39:43
+05'30'

Prepared by:

Current Renewables Engineering Inc.
Professional Engineer
info@currentrenewableseng.com

SIGNED ON 9/25/2023



The design criteria and configuration of the Ground Mounted PV System are summarized below:

Design Criteria:

Applicable Codes: ASCE/SEI 7-16 Min. Design Loads for Buildings & Other Structures
Florida Building Code, 2020 Edition

Risk Category: I
Ult Wind Speed: 120 MPH
Wind Exposure: B
Ground Snow: 5 PSF

Ground Mount Configuration

MODULE DIMENSIONS: 68 X 45 L x W (IN)
RACKING TYPE: OSPREY PowerRack™ LTE
RACK SIZE: 4X5
TOTAL NUMBER OF FOUNDATIONS: 4
TILT: 30 DEG

BACK LEG

BASEPLATE SIZE: 18"x18"x0.25" THK
NUMBER OF ANCHORS: 2
ANCHOR TEST LOAD: 4200 LB

FRONT LEG

BASEPLATE SIZE: 12"x12"x0.25" THK
NUMBER OF ANCHORS: 1
ANCHOR TEST LOAD: 1000 LB

ONCE INSTALLED, "PROOF LOADING" PULL TEST RESULTS FOR THE EARTH ANCHOR FOUNDATION SYSTEMS SHALL BE SUBMITTED TO AND APPROVED BY THE ENGINEER OF RECORD (EOR).

Prepared by:

Current Renewables Engineering Inc.
Professional Engineer
info@currentrenewableseng.com



The design criteria and configuration of the Ground Mounted PV System are summarized below:

Design Criteria:

Applicable Codes: ASCE/SEI 7-16 Min. Design Loads for Buildings & Other Structures
Florida Building Code, 2020 Edition

Risk Category: I
Ult Wind Speed: 120 MPH
Wind Exposure: B
Ground Snow: 5 PSF

Ground Mount Configuration

MODULE DIMENSIONS: 68 X 45 L x W (IN)
RACKING TYPE: OSPREY PowerRack™ LTE
RACK SIZE: 4X6
TOTAL NUMBER OF FOUNDATIONS: 5
TILT: 30 DEG

BACK LEG

BASEPLATE SIZE: 18"x18"x0.25" THK
NUMBER OF ANCHORS: 2
ANCHOR TEST LOAD: 3900 LB

FRONT LEG

BASEPLATE SIZE: 12"x12"x0.25" THK
NUMBER OF ANCHORS: 1
ANCHOR TEST LOAD: 1000 LB

ONCE INSTALLED, "PROOF LOADING" PULL TEST RESULTS FOR THE EARTH ANCHOR FOUNDATION SYSTEMS SHALL BE SUBMITTED TO AND APPROVED BY THE ENGINEER OF RECORD (EOR).

Prepared by:

Current Renewables Engineering Inc.
Professional Engineer
info@currentrenewableseng.com

Valkyrie Engineering & Design, LLC

Site Specific Ground Anchor Load Letter

Date: 7/14/23

Project: Freedom Forever - Sunil Patel

Andres Londono,

Regarding the Osprey PowerRack, a structural analysis was carried out on the specified configuration. The analysis identified the maximum uplift values on both the front and rear legs of the rack. A 1.5 safety factor was applied, and the required loads for the rear and front legs were determined after rounding up. It is important to note that anchor load testing needs to exceed the factored load but should not exceed the manufacturers' specifications for the TLA3 or TLA4 anchors. These anchors have a breaking limit of 5,000lbs(Ultimate 3,300lbs allowable. The purpose of this letter is to address the structural stability of the design.

Racking Configuration:

- Rack Configuration: 4x5
- Number of Leg Pairs: 4
- Tilt: 30°

Panel Size:

- Height: 67.8"
- Width: 44.65"

Site Loading:

- Wind(V): 120 mph
- Snow(Pg): 5 psf

Calculated Loads From Risa Analysis:

- Maximum Uplift on Rear Legs: 4096 lbs
- Maximum Uplift on Front Legs: 26 lbs

Factored Loads (Rounded):

- Rear Legs: 6200 lbs
- Front Legs: 750 lbs

- Required Anchors for Rear Legs: 2

Respectfully,
Joshua M. Bice, PE



THIS DOCUMENT HAS BEEN
ELECTRONICALLY SIGNED AND SEALED BY
JOSHUA M. BICE, P.E. ON 7/14/2023 USING A CA-1
AUTHENTICATION CODE. PRINTED COPIES OF
THIS DOCUMENT ARE NOT CONSIDERED SIGNED
AND SEALED AND THE CA-1 AUTHENTICATION
CODE MUST BE VERIFIED ON ANY ELECTRONIC
COPIES.

Valkyrie Engineering & Design, LLC

Site Specific Ground Anchor Load Letter

Date: 7/14/23

Project: Freedom Forever - Sunil Patel

Andres Londono,

Regarding the Osprey PowerRack, a structural analysis was carried out on the specified configuration. The analysis identified the maximum uplift values on both the front and rear legs of the rack. A 1.5 safety factor was applied, and the required loads for the rear and front legs were determined after rounding up. It is important to note that anchor load testing needs to exceed the factored load but should not exceed the manufacturers' specifications for the TLA3 or TLA4 anchors. These anchors have a breaking limit of 5,000lbs(Ultimate 3,300lbs allowable. The purpose of this letter is to address the structural stability of the design.

Racking Configuration:

- Rack Configuration: 4x6
- Number of Leg Pairs: 5
- Tilt: 30°

Panel Size:

- Height: 67.8"
- Width: 44.65"

Site Loading:

- Wind(V): 120 mph
- Snow(Pg): 5 psf

Calculated Loads From Risa Analysis:

- Maximum Uplift on Rear Legs: 3797 lbs
- Maximum Uplift on Front Legs: 46 lbs

Factored Loads (Rounded):

- Rear Legs: 5800 lbs
- Front Legs: 750 lbs

- Required Anchors for Rear Legs: 3

Respectfully,
Joshua M. Bice, PE



THIS DOCUMENT HAS BEEN
ELECTRONICALLY SIGNED AND SEALED BY
JOSHUA M. BICE, P.E. ON 7/14/2023 USING A CA-1
AUTHENTICATION CODE. PRINTED COPIES OF
THIS DOCUMENT ARE NOT CONSIDERED SIGNED
AND SEALED AND THE CA-1 AUTHENTICATION
CODE MUST BE VERIFIED ON ANY ELECTRONIC
COPIES.

Sep 26, 2023



Attn: To Whom It May Concern,

Project Name: Sunil Patel

Project Address 518 Southwest Windsor Drive Lake City, FL, 32024

Per Florida Statute(F.S.) 377.705 (revised 7/1/2017), I, Methode Maniraguha, PE (# 85003) an engineer licensed pursuant to Chapter 471, certify that the PV electrical system and electrical components are designed and approved using the code requirements and standards contained in the Florida Building Code.

If you have questions regarding this matter, please do not hesitate to contact me directly.

Sincerely,

Prepared by:
Current Renewables Engineering Inc.
Riverside, CA
Projects@currentrenewableseng.com



This item has been electronically signed and sealed by Methode Maniraguha using a digital signature and date. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Digitally
signed by
Methode
Maniraguha
Date:
2023.09.26
12:40:43
+05'30'

1960 Chicago Ave, Suite D15, Riverside, CA 92507

www.currentrenewableseng.com | 951.254.5655

INTEGRITY | PROFESSIONALISM | CUSTOMER EXPERIENCE