

**September 12, 2018**

Vicki Halleland  
613 SW Butzer Drive  
Lake City, FL 32024

**Subject: Permit # 37152 – Parcel #03582-001**

Dear Vicki:

Daniel & Gore, LLC has performed a vertical survey on Parcel #03582-011, Columbia County, Florida from a benchmark being a 60d nail North of the new mobile home (elevation assumed at 500.00') and have determined the following:

- The project engineer, Adam Collins Engineering, Inc. requires the minimum finish floor elevation to be 4' above the highest adjacent ground.
- The finish floor elevation of the residence is at 4.0' above the highest adjacent ground, being at the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

