

NEW

PANEL SCHEDULE: HVAC								MOUNTING: SURFACE					LOCATION: RM. 117				
SERVICE: 120/208, 3Ø, 4W								MAIN: 600A M.L.O.					RATING: 22,000 A.I.C				
CKT NO.	DESCRIPTION	C. BKR.			LOAD KVA./Ø			C. BKR.			DESCRIPTION	CKT NO.					
		A	P	B	A	B	C	A	B	C							
1	PANEL HVAC	*	200	3	11.35			2.3		30	3	*	RTU-2	2			
3	↓						11.35		2.3					4			
5	↓						11.35			2.3				6			
7	RTU-3	*	50	3	3.91			3.91		60	3	*	RTU-4	8			
9	↓						3.91		3.91					10			
11	↓						3.91			3.91				12			
13	RTU-5	*	50	3	3.91			3.60		40	3	*	AHU-1	14			
15	↓						3.91			3.60				16			
17	↓						3.91			3.60				18			
19	AHU-2	*	40	3	3.60			3.60		40	3	*	AHU-3	20			
21	↓						3.60		3.60					22			
23	↓						3.60			3.60				24			
25	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	26			
27	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	28			
29	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	30			
31	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	32			
33	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	34			
35	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	36			
37	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	38			
39	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	40			
41	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	42			
					22.77	22.77	22.77	13.41	13.41	13.41	* HACR RATED CIR. BKR.						
TOTAL CONNECTED LOAD: 108.54 KVA								301.5 AMPS									
TOTAL DEMAND LOAD: 108.54 KVA								301.5 AMPS									

NEW

PANEL SCHEDULE: HVAC										MOUNTING: SURFACE					LOCATION: EXTERIOR				
SERVICE: 120/208, 3ø, 4W										MAIN: 225 M.L.O.					RATING: 22,000 A.I.C				
CKT NO.	DESCRIPTION	C. BKR.			LOAD KVA./ø			C. BKR.			DESCRIPTION	CKT NO.							
		A	P		A	B	C	A	B	C			A	P					
1	HP-1	*	50	3	2.95			2.4		50	3	*	HP-2	2					
3							2.95		2.4					4					
5	↓						2.95		2.4					6					
7	HP-3	*	40	3	2.4			3.6		80	3	*	HP-4	8					
9							2.4		3.6					10					
11	↓						2.4		3.6					12					
13	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	14					
15	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	16					
17	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	18					
19	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	20					
21	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	22					
23	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	24					
25	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	26					
27	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	28					
29	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	30					
31	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	32					
33	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	34					
35	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	36					
37	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	38					
39	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	40					
41	SPACE	-	-	-	-	-	-	-	-	-	-	-	SPACE	42					
					5.35	5.35	5.35	6.0	6.0	6.0	PROVIDE NEMA 3R LOCKABLE ENCLOSURE								
TOTAL CONNECTED LOAD: 34.05 KVA										94.8		AMPS		ENCLOSURE					
TOTAL DEMAND LOAD: 34.05 KVA										A		AMPS							

CNB OPERATIONS
CENTER

PROPOSED
ADDITION &
RENOVATIONS

U.S. HIGHWAY 90 EAST
LAKE CITY, FLORIDA



Clemons, Rutherford
& Associates Inc.

Architects
Planners
Interior Designers
Construction Managers

2027 Thomasville Road
Tallahassee, Florida 32312

(904) 385-6153
Fax (904) 386-8420

The drawings, specifications and other documents prepared by Clemons, Rutherford & Associates, Inc. (CRA) for this Project are instruments of CRA for use only with respect to the Project and, unless otherwise provided, CRA shall be deemed to warrant only the accuracy of the information provided by the Owner and not the accuracy of the information provided by the Owner's consultants, subcontractors, or other third parties. CRA shall not be responsible for any errors or omissions in the drawings, specifications, or other documents prepared by the Owner or its consultants, subcontractors, or other third parties. CRA shall not be responsible for any errors or omissions in the drawings, specifications, or other documents prepared by the Owner or its consultants, subcontractors, or other third parties. CRA shall not be responsible for any errors or omissions in the drawings, specifications, or other documents prepared by the Owner or its consultants, subcontractors, or other third parties.

PHASE			
PHASE	DATE	DRAWN	CHECK
SUB REVIEW	10/20/99	K. SCOTT	K. FOLMAR
CON. DOCS.	12/02/99	K. SCOTT	K. FOLMAR

REVISIONS		
#	DATE	COMMENTS

CRA PROJ#: 96103

PHASE: 100% CONSTRUCTION
DOCUMENTS

SHEET TITLE
PANEL SCHEDULES

E-10 10 of 39

"HVAC"	"HVACA"	

