

Project Information


For: Rebecca Prior
 300 SW Legree Terrace, Fort White, FL 32038

Design Conditions

Location:				Indoor:		Heating	Cooling
Gainesville Regional, FL, US				Indoor temperature (°F)		70	75
Elevation: 123 ft				Design TD (°F)		37	17
Latitude: 30°N				Relative humidity (%)		50	50
				Moisture difference (gr/lb)		32.6	43.8
Outdoor:	Heating	Cooling			Infiltration:		
Dry bulb (°F)	33	92			Method		Simplified
Daily range (°F)	-	18 (M)			Construction quality		Average
Wet bulb (°F)	-	76			Fireplaces		0
Wind speed (mph)	15.0	7.5					


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	4.2	2428	29.7
Glazing	12.1	413	5.0
Doors	14.4	577	7.1
Ceilings	1.6	570	7.0
Floors	6.5	2345	28.7
Infiltration	2.8	1845	22.6
Ducts		0	0
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
Total		8177	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.8	1630	23.5
Glazing	11.8	401	5.8
Doors	11.6	466	6.7
Ceilings	1.4	514	7.4
Floors	0	0	0
Infiltration	0.7	452	6.5
Ducts		0	0
Ventilation		0	0
Internal gains		3460	50.0
Blower		0	0
Adjustments		0	0
Total		6923	100.0



Latent Cooling Load = 1112 Btuh
 Overall U-value = 0.126 Btuh/ft²·°F

Data entries checked.



Project Information


For: Rebecca Prior
 300 SW Legree Terrace, Fort White, FL 32038

Design Conditions

Location:		Indoor:		Heating	Cooling
Gainesville Regional, FL, US		Indoor temperature (°F)		70	75
Elevation: 123 ft		Design TD (°F)		37	17
Latitude: 30°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		32.6	43.8
Outdoor:	Heating	Cooling	Infiltration:		
Dry bulb (°F)	33	92	Method	Simplified	
Daily range (°F)	-	18 (M)	Construction quality	Average	
Wet bulb (°F)	-	76	Fireplaces	0	
Wind speed (mph)	15.0	7.5			


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	4.2	2388	24.7
Glazing	12.1	1647	17.0
Doors	14.4	288	3.0
Ceilings	1.6	684	7.1
Floors	6.0	2605	27.0
Infiltration	2.8	2049	21.2
Ducts		0	0
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
Total		9662	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.8	1603	22.2
Glazing	18.7	2532	35.1
Doors	11.6	233	3.2
Ceilings	1.4	617	8.5
Floors	0	0	0
Infiltration	0.7	503	7.0
Ducts		0	0
Ventilation		0	0
Internal gains		1730	24.0
Blower		0	0
Adjustments		0	0
Total		7217	100.0



Latent Cooling Load = 991 Btuh
 Overall U-value = 0.131 Btuh/ft²·°F

WARNING: window to floor area ratio = 31.4% - more than 25%.

Project Information

For: Rebecca Prior
300 SW Legree Terrace, Fort White, FL 32038

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	44 gr/lb

Heating Summary

Structure	8177 Btuh
Ducts	0 Btuh
Central vent (0 cfm) (none)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	8177 Btuh

Sensible Cooling Equipment Load Sizing

Structure	6923 Btuh
Ducts	0 Btuh
Central vent (0 cfm) (none)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	6923 Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	0

Latent Cooling Equipment Load Sizing

Structure	1112 Btuh
Ducts	0 Btuh
Central vent (0 cfm) (none)	0 Btuh
Equipment latent load	1112 Btuh

	Heating	Cooling
Area (ft ²)	360	360
Volume (ft ³)	4320	4320
Air changes/hour	0.64	0.33
Equiv. AVF (cfm)	46	24

Equipment Total Load (Sen+Lat)	8035 Btuh
Req. total capacity at 0.87 SHR	0.7 ton

Heating Equipment Summary

Make	9K
Trade	
Model	
AHRI ref	
Efficiency	8.5 HSPF
Heating input	
Heating output	9000 Btuh @ 47°F
Temperature rise	27 °F
Actual air flow	300 cfm
Air flow factor	0.037 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	
Capacity balance point = 0 °F	

Cooling Equipment Summary

Make	9K
Trade	
Cond	
Coil	
AHRI ref	
Efficiency	15 SEER
Sensible cooling	7830 Btuh
Latent cooling	1170 Btuh
Total cooling	9000 Btuh
Actual air flow	300 cfm
Air flow factor	0.043 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.86

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Rebecca Prior
 300 SW Legree Terrace, Fort White, FL 32038

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db 33 °F
 Inside db 70 °F
 Design TD 37 °F

Summer Design Conditions

Outside db 92 °F
 Inside db 75 °F
 Design TD 17 °F
 Daily range M
 Relative humidity 50 %
 Moisture difference 44 gr/lb

Heating Summary

Structure 9662 Btuh
 Ducts 0 Btuh
 Central vent (0 cfm)
 (none) 0 Btuh
 Humidification 0 Btuh
 Piping 0 Btuh
 Equipment load 9662 Btuh

Sensible Cooling Equipment Load Sizing

Structure 7217 Btuh
 Ducts 0 Btuh
 Central vent (0 cfm)
 (none) 0 Btuh
 Blower 0 Btuh
 Use manufacturer's data y
 Rate/swing multiplier 1.00
 Equipment sensible load 7217 Btuh

Infiltration

Method Simplified
 Construction quality Average
 Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure 991 Btuh
 Ducts 0 Btuh
 Central vent (0 cfm)
 (none) 0 Btuh
 Equipment latent load 991 Btuh
Equipment Total Load (Sen+Lat) 8208 Btuh
 Req. total capacity at 0.89 SHR 0.7 ton

	Heating	Cooling
Area (ft ²)	432	432
Volume (ft ³)	5184	5184
Air changes/hour	0.59	0.31
Equiv. AVF (cfm)	51	27

Heating Equipment Summary

Make 9K
 Trade
 Model
 AHRI ref
 Efficiency 8.5 HSPF
 Heating input
 Heating output 9000 Btuh @ 47°F
 Temperature rise 27 °F
 Actual air flow 300 cfm
 Air flow factor 0.031 cfm/Btuh
 Static pressure 0 in H2O
 Space thermostat
 Capacity balance point = 0 °F

Cooling Equipment Summary

Make 9K
 Trade
 Cond
 Coil
 AHRI ref
 Efficiency 15 SEER
 Sensible cooling 8010 Btuh
 Latent cooling 990 Btuh
 Total cooling 9000 Btuh
 Actual air flow 300 cfm
 Air flow factor 0.042 cfm/Btuh
 Static pressure 0 in H2O
 Load sensible heat ratio 0.88

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Manual S Compliance Report A

Job: Rebecca Prior 300 SW L...

Date: Jun 24, 2021

By: Energycalcs.net

Energycalcs.net 267 deleon road, Debary, FL 32713

Project Information

For: Rebecca Prior
300 SW Legree Terrace, Fort White, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	6923 Btuh	Entering coil DB:	75.0°F
Outdoor design WB:	75.8°F	Latent gain:	1112 Btuh	Entering coil WB:	62.5°F
Indoor design DB:	75.0°F	Total gain:	8035 Btuh		
Indoor RH:	50%	Estimated airflow:	300 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	9K	Model:			
Actual airflow:	300 cfm				
Sensible capacity:	7800 Btuh	113% of load			
Latent capacity:	1200 Btuh	108% of load			
Total capacity:	9000 Btuh	112% of load	SHR:	87%	

Heating Equipment

Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	8177 Btuh	Entering coil DB:	70.0°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	9K	Model:			
Actual airflow:	300 cfm				
Output capacity:	9000 Btuh	110% of load	Capacity balance:	0 °F	
Supplemental heat required:	0 Btuh	Economic balance:	0 °F		

Meets all requirements of ACCA Manual S.



Project Information

For: Rebecca Prior
300 SW Legree Terrace, Fort White, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	7217 Btuh	Entering coil DB:	75.0°F
Outdoor design WB:	75.8°F	Latent gain:	991 Btuh	Entering coil WB:	62.5°F
Indoor design DB:	75.0°F	Total gain:	8208 Btuh		
Indoor RH:	50%	Estimated airflow:	300 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP	Model:	
Manufacturer:	9K		
Actual airflow:	300 cfm		
Sensible capacity:	8000 Btuh	111% of load	
Latent capacity:	1000 Btuh	101% of load	
Total capacity:	9000 Btuh	110% of load	SHR: 89%

Heating Equipment

Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	9662 Btuh	Entering coil DB:	70.0°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP	Model:			
Manufacturer:	9K				
Actual airflow:	300 cfm				
Output capacity:	9000 Btuh	93% of load		Capacity balance:	0 °F
Supplemental heat required:	662 Btuh			Economic balance:	0 °F

Meets all requirements of ACCA Manual S.