

36745

Weise Residence, Columbia County FL
Proposed Slab Elevation Evaluation
(In Compliance with the 2017 Florida Building Code)

Prepared By: Marty J. Humphries, P.E. # 51976
7932 240th St., O'Brien, FL 32071
(386)935-2406

On 03/22/18 a site evaluation was conducted at the Weise property parcel # 00-00-00-01079-001, to evaluate the proposed location and finished slab elevation of the Wiese residence. A review of the current FEMA Flood Insurance Rate Map (FIRM) Panel 12023C0458C and the Suwannee River Water Management Flood software does not indicate a mapped 100 year flood zone within the parcel. A review of the proposed slab location indicates the building is not located at the lowest portion of the property, but is on a gradual slope at the proposed location. Considering this information and observations made in the field, the finished slab elevation(living area) may be constructed a minimum of 1' above the natural grade. Place fill around the perimeter of the home sloping gently away from the home to provide site drainage around the home.



Marty J. Humphries
3-26-18