

TomasPonce MSCE,PE50068

367 Madallion Pl.

Chulota, Florida 32766

March 22,2022

RE:

Permit # 000043660

162 NW Dogwood Terrace

Lake City, Fl.

To whom it may concern,

I have been informed that the the contractor has requested to delete the 6X6 posts as shown in Detail CD12 for the front Entry Columns on the submitted set of plans. He has requested to change them to CMU blk. as shown in Detail CD09 which is also shown on the plan for the rear columns. This detail will be adequate for the replacement of the wood post.


If you need any additional information or clarification, please do not hesitate to contact me.

Sincerely,



Tomas Ponce MSCE,PE

FLPE: 50068



Digitally signed
by Tomas Ponce
Date:
2022.03.23
19:23:54-04'00'

This item has been digitally signed and sealed by [Tomas Ponce PE, FL # 0050068], on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.