



Affine Engineering and Surveying, Inc.

---

Date:4/6/2021

Mr. Kevin Bedenbaugh, Jr

Plumb Level Construction

386.365.5264


Re: **Elevation Letter-234 Turkey Creek Way, Lake City, FL.**

SUBJECT:

FINISH FLOOR HEIGHT VERIFICATION

To whom it may concern,

During a field survey conducted 4/6/2021 on Lot 24 of Turkey Creek Unit I – Parcel 23-3S-16-02279-124, the finish floor of the existing structure was measured. According to an elevation letter prepared by Carol Chadwick PE - Job#FL20186 signed 9-23-2020, the elevation of the road at the front of the house is at elevation 158.10'. Based on that elevation and after measuring the elevation of the Finish Floor, it was found that the Finish Floor is at elevation 159.82 feet.



4/13/21

Victor O. Marrero, PE, PSM

Florida PSM 6586

Rev 4/13/2021

