

Roof Replacement or Repair Application #74946



Tuesday, January 27, 2026 1:26 PM

Checklist:

<input type="checkbox"/> Address	<input type="checkbox"/> Application Submitted	
<input type="checkbox"/> Drive/ROW	<input type="checkbox"/> Zoning Review	<input type="checkbox"/> Legal Lot of Record
<input type="checkbox"/> Septic	<input type="checkbox"/> Plans Reviewed	<input type="checkbox"/> Flood Zone
<input type="checkbox"/> Site Use Approved	<input type="checkbox"/> Required Inspections Assigned	<input type="checkbox"/> FDEP Needed
<input type="checkbox"/> Docs Reviewed/Accepted	<input type="checkbox"/> Invoiced	

APPLICANT: Daniel Byrd **PHONE:** (386) 935-6559

ADDRESS: 118 Suwannee Ave Branford Fl 32008

OWNER: LEONARD GEORGE E, LEONARD SYLVIA M **PHONE:** (386) 365-7143

ADDRESS: 9948 SW COUNTY ROAD 240 LAKE CITY, FL 32024

PARCEL ID: 18-5S-16-03644-105 **SUBDIVISION:** WHITE OAK PLANTATION

LOT: 5 **BLOCK:** **PHASE:** **UNIT:** **ACRES:** 4.98

CONTRACTOR	TYPE	LIC#	BUSINESS NAME
Daniel Byrd	General	CCC1332899	Byrd's Eye Roofing

ROOFING JOB DETAILS

Type Roofing Job	Replacement - Tear off Existing and Replace
Further Job Details (Explain if decking is being replaced and or Repairs are being done.)	Tear off and replace with shingle
Type of structure	Mobile Home
Further Structure Details (if needed)	Mobile home
Total Estimated Cost	11312
Commercial or Residential	Residential
Roof Area (for this job) Sq Ft	2986
No. of Stories	1
Ventilation:	Off-ridge Vent
Flashing:	Replace All
Drip Edge:	Replace All
Valley Treatment:	New Mineral Surface
Roof Pitch	2:12 to 4:12
Second Roof Pitch (if applicable)	
Any cable and/or race-way wiring located on or within the roof assembly?	No
Is the existing roof being removed?	Yes
Explain if not removing the existing roofing material?	
Type of New Roofing Product	Asphalt Shingles
Florida Product Approval Number	FL10124-R35
Product Manufacturer	GAF
Product Description	Asphalts shingles
Other Roofing Product Type Not Listed	

Sealed roof decking options: (Must select an option.)

a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¼ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.

Sealed roof decking explanation for other option.

Review Notes: