



Donald F. Lee & Associates, Inc.

LAND SURVEYORS • ENGINEERS

140 NW Ridgewood Avenue
Lake City, Florida 32055

PH 386-755-6166 FAX 386-755-6167
email: donald@dfa.com
website: www.dfa.com

Since 1984

- Highway & Route Surveys
- Topographic Surveys
- Land & Subdivision Surveys
- Control Surveying
- Civil Engineering

DATE: Wednesday, September 04, 2019

TO: Columbia County Building Department

FROM: Tim Delbene – Donald F. Lee & Associates

CC: Justin Peeler – Creative Concrete Design

RE: Floor Elevation – Dollar General Store (under construction) on parcel
05-4S-16-02778-005, at SW intersection of Pinemount Road & Birley Road.

This is to certify that an elevation was obtained on the floor of a building under construction on the above referenced lands. The results are as follows:

FLOOR ELEVATION: 112.03 feet NAVD1988 datum

The elevation was projected from a benchmark set with the original design survey for the project (by others). The site plan for the project indicates that the minimum floor elevation is 112.00 feet.

