

**D**  
**G** **Daniel & Gore, LLC**  
**Professional Surveying and Mapping**

P.O. Box 1501  
Lake City, Florida 32056

**December 12, 2022**

Joan Williams  
385 SW Sumac Lake  
Lake City, FL 32024

**Subject: Parcel # 03231-011**

Dear Elouise:

Daniel & Gore, LLC has performed a vertical survey on Parcel # 03231-011, Columbia County, Florida from a benchmark being a FDOT concrete monument (2902011 GPS4) on the West right of way of SR-47 (elevation – 96.67', NAVD 1988) and have determined the following:

- The Elevation Letter by Carol Chadwick, P.E. requires the minimum finish floor elevation to be 99.50'
- The finish floor of the residence is at 101.9', being 2.4' above the minimum finish floor requirement per Carol Chadwick's letter.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM