

Air America Heating & Cooling, Inc.

PO Box 298 High Springs, Fl. 32655
CMC1250300

PROPOSAL FOR:

**Rick Anderson Residence
837 SW Meadowlands Dr.
Lake City, FL 32024**

9/23/2024

Prepared 9/23/2024 using O'Brien Quick Loads Pro - Version 1.06 - SN: QP-070101-41073

Air America Heating & Cooling, Inc.PO Box 298 High Springs, FL 32655
CMC1250300**Heat Load Detail Report for Rick Anderson Residence**

Room 1 of 3

Room Specifications: Great Room

Room Length (Ft.) :	38	Sq. Ft. windows facing NE & NW :	--	Watts Incandescent Light :	--
Room Width (Ft.) :	24	Sq. Ft. windows facing South :	20	Watts Fluorescent Light :	100
Room Height (Ft.) :	8	Sq. Ft. windows facing SE & SW :	--	Duct Length from A/H to room :	--
Exposed Wall Length (Ft.) :	86	Number of Exterior Doors :	1	Number of Large Electric Motors :	--
Wall against unconditioned room (Ft.) :	--	Sq. Ft. Exterior Doors :	21	Average Electric Motor Horsepower :	--
Sq. Ft. windows facing North :	9	Number of People in Room :	3	BTUH Appliance Sensible Heat :	10000
Sq. Ft. windows facing E & W :	39			BTUH Appliance Latent Heat :	--

Indoor/Outdoor Design Temperatures (degrees Farenheit)

Summer:		Winter:	
Inside (Thermostat setting) :	74	Inside (Thermostat setting) :	72
Outside (Above ground) :	97	Outside (Above ground) :	20
Outside (Below ground) :	65	Outside (Below ground) :	60
Unconditioned Space :	97	Unconditioned Space :	65
Above Ceiling (Attic/Crawl Space) :	130	Above Ceiling (Attic/Crawl Space) :	45
Concrete Slab (Ground temperature) :	80	Concrete Slab (Ground temperature) :	55
Unconditioned Basement :	60	Unconditioned Basement :	55
Below Floor Crawl Space :	85	Below Floor Crawl Space :	50

Applicable Temperatures: Above Ceiling: Attic or Crawl Space Below Floor: Concrete Slab Exposed Walls: Above Ground

Design Conditions

Occupant Sensible Load (BTUH per person) :	250
Occupant Latent Load (BTUH per person) :	200
Duct Insulation Factor :	1
Duct Temperature Difference (Summer) :	20
Duct Temperature Difference (Winter) :	45
Humidity Difference Inside/Outside % (Summer) :	20
Humidity Difference Inside/Outside % (Winter) :	15
Fresh Air Per Person (CFM) :	2
Air Change Factor (Air change per hour) :	.5
Space Shading Factor :	.4
Air Handler Design Cooling (CFM per ton) :	400
Hydronic Heat (BTUH per linear ft. :	600

Insulation Values (U-Factors)

Exposed Walls (Above Ground) :	.080
Exposed Walls (Below Ground) :	.5
Partitions :	.075
Roof/Ceiling :	.055
Floor (Above basement) :	.083
Floor (Concrete slab) :	.001
Floor (Between conditioned spaces) :	.287
Doors :	.500
Windows :	.900

Calculated Room Results - Summer Heat Gains

Wall Heat Gain (BTUH) :	1286	Appliance/Elec Motor Latent Heat Gain (BTUH) :	600
Ceiling or Roof Heat Gain (BTUH) :	2809	Appliance/Elec Motor Sensible Heat Gain (BTUH) :	11175
Floor Heat Gain (BTUH) :	5	Ventilation Latent Heat Gain (BTUH) :	1486
Glass Heat Gain (BTUH) :	1113	Ventilation Sensible Gain (BTUH) :	2755
Exterior Door & North Window Heat Gain (BTUH) :	290	Summer Total Latent Heat Gain :	2086
Solar Heat Gain (BTUH) :	3354	Summer Total Sensible Heat Gain (BTUH) :	22767
Total Transmission Heat Gain (BTUH) :	8837	TOTAL SUMMER COOLING LOAD (BTUH) :	24854

Calculated Room Results - Winter Heat Losses

Transmission Heat Losses (BTUH) :	7403	Latent Ventilation Heat Losses (BTUH) :	1115
Sensible Ventilation Heat Losses (BTUH) :	6229	Hydronic Heat (Linear Ft.) :	25
		TOTAL WINTER HEATING LOAD (BTUH) :	14747

Calculated Totals for Entire Structure

Size of Structure (Sq. Ft.) :	1556	Total Sensible Heat Gain (BTUH) :	33264
Total Heat Loss (BTUH) :	23584	Total Cooling Gain (BTUH) :	36327
Total Hydronic Heat (Linear Ft.) :	39.31	Total Cooling Requirement (Tons) :	3.03
Total Latent Heat Gain (BTUH) :	3063	Total Cooling CFM :	1211

Disclaimer

These computed results should be treated as estimates only and should be viewed as only one of the many tools required for a professional installation. The installing contractor's experience and expert judgement are also major factors in sizing and installing a complete system. The weather, customer usage, duct installation, and structure design may vary on each estimate and should be taken into account. Correct system sizing is based on the systems ability to meet both latent and sensible heat requirements, not just total BTUs.

Prepared 9/23/2024 using O'Brien Quick Loads Pro - Version 1.06 - SN: QP-070101-41073

Air America Heating & Cooling, Inc.PO Box 298 High Springs, FL 32655
CMC1250300**Heat Load Detail Report for Rick Anderson Residence**

Room 2 of 3

Room Specifications: Master

Room Length (Ft.) :	23	Sq. Ft windows facing NE & NW :	--	Watts Incandescent Light :	--
Room Width (Ft.) :	15	Sq. Ft windows facing South :	--	Watts Fluorescent Light :	100
Room Height (Ft.) :	8	Sq. Ft windows facing SE & SW :	--	Duct Length from A/H to room :	--
Exposed Wall Length (Ft.) :	38	Number of Exterior Doors :	--	Number of Large Electric Motors :	--
Wall against unconditioned room (Ft.) :	--	Sq. Ft. Exterior Doors :	--	Average Electric Motor Horsepower :	--
Sq. Ft windows facing North :	--	Number of People in Room :	1	BTUH Appliance Sensible Heat :	--
Sq. Ft windows facing E & W :	30			BTUH Appliance Latent Heat :	--

Indoor/Outdoor Design Temperatures (degrees Farenheit)

Summer:		Winter:	
Inside (Thermostat setting) :	74	Inside (Thermostat setting) :	72
Outside (Above ground) :	97	Outside (Above ground) :	20
Outside (Below ground) :	65	Outside (Below ground) :	60
Unconditioned Space :	97	Unconditioned Space :	65
Above Ceiling (Attic/Crawl Space) :	130	Above Ceiling (Attic/Crawl Space) :	45
Concrete Slab (Ground temperature) :	80	Concrete Slab (Ground temperature) :	55
Unconditioned Basement :	60	Unconditioned Basement :	55
Below Floor Crawl Space :	85	Below Floor Crawl Space :	50

Applicable Temperatures: Above Ceiling: Attic or Crawl Space Below Floor: Concrete Slab Exposed Walls: Above Ground

Design Conditions

Occupant Sensible Load (BTUH per person) :	250
Occupant Latent Load (BTUH per person) :	200
Duct Insulation Factor :	1
Duct Temperature Difference (Summer) :	20
Duct Temperature Difference (Winter) :	45
Humidity Difference Inside/Outside % (Summer) :	20
Humidity Difference Inside/Outside % (Winter) :	15
Fresh Air Per Person (CFM) :	2
Air Change Factor (Air change per hour) :	.5
Space Shading Factor :	.4
Air Handler Design Cooling (CFM per ton) :	400
Hydronic Heat (BTUH per linear ft) :	600

Insulation Values (U-Factors)

Exposed Walls (Above Ground) :	.080
Exposed Walls (Below Ground) :	.5
Partitions :	.075
Roof/Ceiling :	.055
Floor (Above basement) :	.083
Floor (Concrete slab) :	.001
Floor (Between conditioned spaces) :	.287
Doors :	.500
Windows :	.900

Calculated Room Results - Summer Heat Gains

Wall Heat Gain (BTUH) :	559	Appliance/Elec Motor Latent Heat Gain (BTUH) :	200
Ceiling or Roof Heat Gain (BTUH) :	1063	Appliance/Elec Motor Sensible Heat Gain (BTUH) :	675
Floor Heat Gain (BTUH) :	2	Ventilation Latent Heat Gain (BTUH) :	309
Glass Heat Gain (BTUH) :	566	Ventilation Sensible Gain (BTUH) :	572
Exterior Door & North Window Heat Gain (BTUH) :	0	Summer Total Latent Heat Gain :	509
Solar Heat Gain (BTUH) :	2580	Summer Total Sensible Heat Gain (BTUH) :	6017
Total Transmission Heat Gain (BTUH) :	4770	TOTAL SUMMER COOLING LOAD (BTUH) :	6526

Calculated Room Results - Winter Heat Losses

Transmission Heat Losses (BTUH) :	3062	Latent Ventilation Heat Losses (BTUH) :	232
Sensible Ventilation Heat Losses (BTUH) :	1294	Hydronic Heat (Linear Ft.) :	8
		TOTAL WINTER HEATING LOAD (BTUH) :	4588

Calculated Totals for Entire Structure

Size of Structure (Sq. Ft.):	1556	Total Sensible Heat Gain (BTUH):	33264
Total Heat Loss (BTUH):	23584	Total Cooling Gain (BTUH):	36327
Total Hydronic Heat (Linear Ft.):	39.31	Total Cooling Requirement (Tons):	3.03
Total Latent Heat Gain (BTUH):	3063	Total Cooling CFM:	1211

Disclaimer

These computed results should be treated as estimates only and should be viewed as only one of the many tools required for a professional installation. The installing contractor's experience and expert judgement are also major factors in sizing and installing a complete system. The weather, customer usage, duct installation, and structure design may vary on each estimate and should be taken into account. Correct system sizing is based on the systems ability to meet both latent and sensible heat requirements, not just total BTUs.

Prepared 9/23/2024 using O'Brien Quick Loads Pro - Version 1.06 - SN: QP-070101-41073

Air America Heating & Cooling, Inc.PO Box 298 High Springs, FL 32655
CMC1250300**Heat Load Detail Report for Rick Anderson Residence**

Room 3 of 3

Room Specifications: Bedroom 1

Room Length (Ft.) :	23	Sq. Ft windows facing NE & NW:	--	Watts Incandescent Light:	--
Room Width (Ft.) :	13	Sq. Ft windows facing South:	15	Watts Fluorescent Light:	100
Room Height (Ft.) :	8	Sq. Ft windows facing SE & SW:	--	Duct Length from A/H to room:	--
Exposed Wall Length (Ft.) :	36	Number of Exterior Doors:	--	Number of Large Electric Motors:	--
Wall against unconditioned room (Ft.) :	--	Sq. Ft. Exterior Doors:	--	Average Electric Motor Horsepower:	--
Sq. Ft windows facing North:	--	Number of People in Room:	1	BTUH Appliance Sensible Heat:	--
Sq. Ft windows facing E & W:	15			BTUH Appliance Latent Heat:	--

Indoor/Outdoor Design Temperatures (degrees Fahrenheit)

Summer:		Winter:	
Inside (Thermostat setting) :	74	Inside (Thermostat setting) :	72
Outside (Above ground):	97	Outside (Above ground) :	20
Outside (Below ground):	65	Outside (Below ground) :	60
Unconditioned Space :	97	Unconditioned Space :	65
Above Ceiling (Attic/Crawl Space) :	130	Above Ceiling (Attic/Crawl Space) :	45
Concrete Slab (Ground temperature) :	80	Concrete Slab (Ground temperature) :	55
Unconditioned Basement :	60	Unconditioned Basement :	55
Below Floor Crawl Space :	85	Below Floor Crawl Space :	50

Applicable Temperatures: Above Ceiling: Attic or Crawl Space Below Floor: Concrete Slab Exposed Walls: Above Ground

Design Conditions

Occupant Sensible Load (BTUH per person) :	250
Occupant Latent Load (BTUH per person) :	200
Duct Insulation Factor :	1
Duct Temperature Difference (Summer) :	20
Duct Temperature Difference (Winter) :	45
Humidity Difference Inside/Outside % (Summer) :	20
Humidity Difference Inside/Outside % (Winter) :	15
Fresh Air Per Person (CFM) :	2
Air Change Factor (Air change per hour) :	.5
Space Shading Factor :	.4
Air Handler Design Cooling (CFM per ton) :	400
Hydronic Heat (BTUH per linear ft) :	600

Insulation Values (U-Factors)

Exposed Walls (Above Ground) :	.080
Exposed Walls (Below Ground) :	.5
Partitions :	.075
Roof/Ceiling :	.055
Floor (Above basement) :	.083
Floor (Concrete slab) :	.001
Floor (Between conditioned spaces) :	.287
Doors :	.500
Windows :	.900

Calculated Room Results - Summer Heat Gains

Wall Heat Gain (BTUH) :	530	Appliance/Elec Motor Latent Heat Gain (BTUH) :	200
Ceiling or Roof Heat Gain (BTUH) :	921	Appliance/Elec Motor Sensible Heat Gain (BTUH) :	675
Floor Heat Gain (BTUH) :	2	Ventilation Latent Heat Gain (BTUH) :	268
Glass Heat Gain (BTUH) :	566	Ventilation Sensible Gain (BTUH) :	496
Exterior Door & North Window Heat Gain (BTUH) :	0	Summer Total Latent Heat Gain:	468
Solar Heat Gain (BTUH) :	1290	Summer Total Sensible Heat Gain (BTUH) :	4480
Total Transmission Heat Gain (BTUH) :	3308	TOTAL SUMMER COOLING LOAD (BTUH) :	4947

Calculated Room Results - Winter Heat Losses

Transmission Heat Losses (BTUH) :	2926	Latent Ventilation Heat Losses (BTUH) :	201
Sensible Ventilation Heat Losses (BTUH) :	1122	Hydronic Heat (Linear Ft.) :	7
		TOTAL WINTER HEATING LOAD (BTUH) :	4249

Calculated Totals for Entire Structure

Size of Structure (Sq. Ft.):	1556	Total Sensible Heat Gain (BTUH):	33264
Total Heat Loss (BTUH):	23584	Total Cooling Gain (BTUH):	36327
Total Hydronic Heat (Linear Ft.):	39.31	Total Cooling Requirement (Tons):	3.03
Total Latent Heat Gain (BTUH):	3063	Total Cooling CFM:	1211

Disclaimer

These computed results should be treated as estimates only and should be viewed as only one of the many tools required for a professional installation. The installing contractor's experience and expert judgement are also major factors in sizing and installing a complete system. The weather, customer usage, duct installation, and structure design may vary on each estimate and should be taken into account. Correct system sizing is based on the systems ability to meet both latent and sensible heat requirements, not just total BTUs.

Prepared 9/23/2024 using O'Brien Quick Loads Pro - Version 1.06 - SN: QP-070101-41073