



Patrick Taylor
Building Official
224 Pine Ave
Live Oak, FL 32060
Email: patrickt@suw.gov.org
Office: 386-364-3408
Fax: 386-364-3754

BLOWER DOOR TEST FORM
For Prescriptive and Performance Method

Permit #: 000048583
BDT#: _____

Date Completed: 4-23-25

Builder: Darg Thompson
Owner: Michael McCallister
Sec: _____ Twp: _____ Range: _____ Parcel #: _____
Job Address: ~~583 SW~~ ~~583~~ Jeanlea Place
City, State, Zip: Ft White, FL

Air Infiltration Test Results

CFM (50) = 2214

Volume = 28,550

ACH (50) = CFM (50) X 60 / Volume = $2214 \times 60 = 132,840 \div 28,550 = 4.65$

☒ Pass

☐ Fail

Passing Results must be **7** ACH (50) or less

Certification of Test Results

I hereby certify that the above Air Infiltration Test results demonstrate compliance with the Florida Energy Code requirements in accordance with the Florida Building Code-Energy Conservation R402.4.1.2, 5th Edition (2014).

Signature: Michael Paugh
Printed Name: Michael Paugh
Company: Alcons Heat & A/C Inc.
BDT Registration #: CAC1813540
Date: 4-23-25