

# ENERGY PERFORMANCE LEVEL (EPL) DISPLAY CARD

## ESTIMATED ENERGY PERFORMANCE INDEX\* = 95

The lower the EnergyPerformance Index, the more efficient the home.

„FL,

1. New construction or existing	New (From Plans)	10. Wall Types(3874.0 sqft.)	Insulation	Area
2. Single family or multiple family	Detached	a. Frame - Wood, Exterior	R=13.0	3874.00 ft <sup>2</sup>
3. Number of units, if multiple family	1	b. N/A	R=	ft <sup>2</sup>
4. Number of Bedrooms	5	c. N/A	R=	ft <sup>2</sup>
5. Is this a worst case?	No	d. N/A	R=	ft <sup>2</sup>
6. Conditioned floor area above grade (ft <sup>2</sup> )	3865	11. Ceiling Types(2726.0 sqft.)	Insulation	Area
Conditioned floor area below grade (ft <sup>2</sup> )	0	a. Under Attic (Vented)	R=38.0	2726.00 ft <sup>2</sup>
7. Windows**	Description	b. N/A	R=	ft <sup>2</sup>
a. U-Factor:	Dbl, U=0.35	c. N/A	R=	ft <sup>2</sup>
SHGC:	SHGC=0.29	12. Ducts, location & insulation level	R	ft <sup>2</sup>
b. U-Factor:	N/A	a. a. Sup: Attic, Ret: Attic, AH: 1st Floor	8	386.5
SHGC:		b. b. Sup: Attic, Ret: Attic, AH: 1st Floor	8	386.5
c. U-Factor:	N/A	c.		
SHGC:		13. Cooling Systems	kBtu/hr	Efficiency
Area Weighted Average Overhang Depth:	1.000 ft	a. Central Unit	48.0	SEER:14.00
Area Weighted Average SHGC:	0.290	b. Central Unit	24.0	SEER:14.00
8. Skylights	Description	14. Heating Systems	kBtu/hr	Efficiency
U-Factor:(AVG)	N/A	a. Electric Heat Pump	48.0	HSPF:8.20
SHGC(AVG):	N/A	b. Electric Heat Pump	24.0	HSPF:8.20
9. Floor Types	Insulation	15. Hot Water Systems		
a. Slab-On-Grade Edge Insulation	R= 0.0	a. Electric	Cap: 40 gallons	
b. N/A	R=		EF: 0.960	
c. N/A	R=	b. Conservation features		
		16. Credits		None
				Pstat

I certify that this home has complied with the Florida Energy Efficiency Code for Building Construction through the above energy saving features which will be installed (or exceeded) in this home before final inspection. Otherwise, a new EPL Display Card will be completed based on installed Code compliant features.

Builder Signature: [Signature] Date: 5-16-22  
 Address of New Home: 7313 W. US Hwy 90 City/FL Zip: Lake City FL 32055



\*Note: This is not a Building Energy Rating. If your Index is below 70, your home may qualify for energy efficient mortgage (EEM) incentives if you obtain a Florida Energy Rating. For information about the Florida Building Code, Energy Conservation, contact the Florida Building Commission's support staff.

\*\*Label required by Section R303.1.3 of the Florida Building Code, Energy Conservation, if not DEFAULT.