



Load Short Form MINI SPLIT BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	33	94	Method	Simplified
Inside db (°F)	70	75	Construction quality	Semi-tight
Design TD (°F)	37	19	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	32	46		

0

HEATING EQUIPMENT

Make MITSUBISHI
Trade TRANE
Model NTXSMT09A112A*
AHRI ref 202373737

Efficiency 10 HSPF
Heating input
Heating output 9500 Btuh @ 47°F
Temperature rise 29 °F
Actual air flow 300 cfm
Air flow factor 0.104 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 6 °F

Backup:
Input = 2 kW, Output = 5141 Btuh, 100 AFUE

COOLING EQUIPMENT

Make MITSUBISHI
Trade TRANE
Cond NTXSMT09A112A*
Coil NTXWMT09A112A*
AHRI ref 202373737

Efficiency 12.0 EER, 18 SEER
Sensible cooling 6300 Btuh
Latent cooling 2700 Btuh
Total cooling 9000 Btuh
Actual air flow 300 cfm
Air flow factor 0.268 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.86



ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
WORKSHOP	157	2879	1119	300	300
MINI SPLIT	157	2879	1119	300	300
Other equip loads		0	0		
Equip. @ 0.99 RSM			1102		
Latent cooling			182		
TOTALS	157	2879	1284	300	300

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2018 18.0.16 RSU09167

2021-Apr-19 14:42:48

Page 1

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E



Load Short Form
UP STAIRS
BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	33	94	Method	Simplified
Inside db (°F)	70	75	Construction quality	Semi-tight
Design TD (°F)	37	19	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	32	46		

HEATING EQUIPMENT

Make Trane
Trade TRANE
Model 4TWR4018G1
AHRI ref 8908426

Efficiency 8.5 HSPF
Heating input
Heating output 17200 Btuh @ 47°F
Temperature rise 26 °F
Actual air flow 600 cfm
Air flow factor 0.117 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 5 °F

Backup:
Input = 2 kW, Output = 5141 Btuh, 100 AFUE

COOLING EQUIPMENT

Make Trane
Trade TRANE
Cond 4TWR4018G1
Coil TEM4A0B18S21++TDR
AHRI ref 8908426
Efficiency 11.5 EER, 14 SEER
Sensible cooling 12600 Btuh
Latent cooling 5400 Btuh
Total cooling 18000 Btuh
Actual air flow 600 cfm
Air flow factor 0.125 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.83

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
BATH	64	0	0	0	0
STAIRS	51	858	170	100	21
BEDROOM 1	120	1197	1283	140	161
BATH1	50	534	307	62	38
BATH 2	50	391	230	46	29
BEDROOM 2	120	1105	1317	129	165
STAIRS 1	65	716	410	84	51
LIVING	81	340	1072	40	134

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2018 18.0.16 RSU09167

2021-Apr-19 14:42:48

Page 2

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E

UP STAIRS	d	601	5141	4790	600	600
Other equip loads			0	0		
Equip. @ 0.99 RSM				4718		
Latent cooling				950		
TOTALS		601	5141	5667	600	600

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Project Summary
MINI SPLIT
BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

Notes: NEW CONSTRUCTION GARAGE

Design Information

Weather: Gainesville Regional AP, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

Summer Design Conditions

Outside db	94 °F
Inside db	75 °F
Design TD	19 °F
Daily range	M
Relative humidity	50 %
Moisture difference	46 gr/lb

Heating Summary

Structure	2879 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	2879 Btuh

Sensible Cooling Equipment Load Sizing

Structure	1119 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.99
Equipment sensible load	1102 Btuh

Infiltration

Method	Simplified
Construction quality	Semi-tight
Fireplaces	0

Latent Cooling Equipment Load Sizing

Structure	182 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Equipment latent load	182 Btuh

	Heating	Cooling
Area (ft²)	157	157
Volume (ft³)	1569	1569
Air changes/hour	0.41	0.22
Equiv. AVF (cfm)	11	6

Equipment Total Load (Sen+Lat)	1284 Btuh
Req. total capacity at 0.70 SHR	0.1 ton

Heating Equipment Summary

Make	MITSHUBISHI
Trade	TRANE
Model	NTXSMT09A112A*
AHRI ref	202373737
Efficiency	10 HSPF
Heating input	
Heating output	9500 Btuh @ 47°F
Temperature rise	29 °F
Actual air flow	300 cfm
Air flow factor	0.104 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 6 °F	

Backup:
Input = 2 kW, Output = 5141 Btuh, 100 AFUE

Cooling Equipment Summary

Make	MITSHUBISHI
Trade	TRANE
Cond	NTXSMT09A112A*
Coil	NTXWMT09A112A*
AHRI ref	202373737
Efficiency	12.0 EER, 18 SEER
Sensible cooling	6300 Btuh
Latent cooling	2700 Btuh
Total cooling	9000 Btuh
Actual air flow	300 cfm
Air flow factor	0.268 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.86

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2018 18.0.16 RSU09167

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E

2021-Apr-19 14:42:48

Page 1



Project Summary
UP STAIRS
BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

Notes: NEW CONSTRUCTION GARAGE

Design Information

Weather: Gainesville Regional AP, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 70 °F
Design TD 37 °F

Summer Design Conditions

Outside db 94 °F
Inside db 75 °F
Design TD 19 °F
Daily range M
Relative humidity 50 %
Moisture difference 46 gr/lb

Heating Summary

Structure 5141 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 5141 Btuh

Sensible Cooling Equipment Load Sizing

Structure 4790 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.99
Equipment sensible load 4718 Btuh

Infiltration

Method Simplified
Construction quality Semi-tight
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure 950 Btuh
Ducts 0 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 950 Btuh

	Heating	Cooling
Area (ft²)	601	601
Volume (ft³)	4807	4807
Air changes/hour	0.41	0.22
Equiv. AVF (cfm)	33	18

Equipment Total Load (Sen+Lat) 5667 Btuh
Req. total capacity at 0.70 SHR 0.6 ton

Heating Equipment Summary

Make Trane
Trade TRANE
Model 4TWR4018G1
AHRI ref 8908426

Efficiency 8.5 HSPF
Heating input 17200 Btuh @ 47°F
Heating output 26 °F
Temperature rise 600 cfm
Actual air flow 0.117 cfm/Btuh
Air flow factor 0.50 in H2O
Static pressure
Space thermostat
Capacity balance point = 5 °F

Backup:
Input = 2 kW, Output = 5141 Btuh, 100 AFUE

Cooling Equipment Summary

Make Trane
Trade TRANE
Cond 4TWR4018G1
Coil TEM4A0B18S21++TDR
AHRI ref 8908426

Efficiency 11.5 EER, 14 SEER
Sensible cooling 12600 Btuh
Latent cooling 5400 Btuh
Total cooling 18000 Btuh
Actual air flow 600 cfm
Air flow factor 0.125 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.83

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2018 18.0.16 RSU09167

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E

2021-Apr-19 14:42:48

Page 2



Duct System Summary

MINI SPLIT

BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.50 in H2O	0.50 in H2O
Supply / return available pressure	0.250 / 0.250 in H2O	0.250 / 0.250 in H2O
Lowest friction rate	0 in/100ft	0 in/100ft
Actual air flow	300 cfm	300 cfm
Total effective length (TEL)		0 ft

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
WORKSHOP	c 559	150	150	0	0	0x0	ShMt	0	0	
WORKSHOP-A	c 559	150	150	0	0	0x0	ShMt	0	0	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb9	0x0	300	300	0	0	0	0	0x0		ShMt	



Right-Suite® Universal 2018 18.0.16 RSU09167

2021-Apr-19 14:42:48

Page 1

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E



Duct System Summary

UP STAIRS

BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CAC058697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.50 in H2O	0.50 in H2O
Supply / return available pressure	0.209 / 0.291 in H2O	0.209 / 0.291 in H2O
Lowest friction rate	0.068 in/100ft	0.068 in/100ft
Actual air flow	600 cfm	600 cfm
Total effective length (TEL)	731 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
BATH 2	h 391	46	29	0.069	4.0	0x 0	VIFx	23.1	280.0	st3A
BATH1	h 534	62	38	0.078	4.0	0x 0	VIFx	33.5	235.0	st3A
BEDROOM 1	c 1283	140	161	0.068	8.0	0x 0	VIFx	40.8	265.0	st3B
BEDROOM 2	c 1317	129	165	0.132	8.0	0x 0	VIFx	13.3	145.0	st3
LIVING-A	c 1072	40	134	0.109	8.0	0x 0	VIFx	26.7	165.0	st3
STAIRS	h 170	100	21	0	0	0x 0	VIFx	0	0	
STAIRS 1	h 716	84	51	0.082	6.0	0x 0	VIFx	39.9	215.0	st3A

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	500	579	0.068	541	14.0	0 x 0	VinlFlx	st1
st1	Peak AVF	500	579	0.068	541	14.0	0 x 0	VinlFlx	
st3B	Peak AVF	140	161	0.068	364	9.0	0 x 0	VinlFlx	st3A
st3A	Peak AVF	331	279	0.068	422	12.0	0 x 0	VinlFlx	st3

Bold/italic values have been manually overridden



Right-Suite® Universal 2018 18.0.16 RSU09167

2021-Apr-19 14:42:48

Page 2

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb8	0x 0	235	206	425.3	0.068	432	10.0	0x 0		VIFx	rt1A
rb7	0x 0	157	193	319.3	0.091	437	9.0	0x 0		VIFx	rt1
rb6	0x 0	208	201	246.8	0.118	471	9.0	0x 0		VIFx	rt1

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt1	Peak AVF	600	600	0.068	561	14.0	0 x 0	RectFbg	
rt1A	Peak AVF	235	206	0.068	432	10.0	0 x 0	RectFbg	rt1



Manual S Compliance Report
MINI SPLIT
BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

Cooling Equipment

Design Conditions

Outdoor design DB:	93.5°F	Sensible gain:	1119 Btuh	Entering coil DB:	75.0°F
Outdoor design WB:	76.5°F	Latent gain:	182 Btuh	Entering coil WB:	62.5°F
Indoor design DB:	75.0°F	Total gain:	1300 Btuh		
Indoor RH:	50%	Estimated airflow:	300 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	MITSHUBISHI	Model:	NTXSMT09A112A*+NTXWMT09A112A*		
Actual airflow:	300 cfm				
Sensible capacity:	6300 Btuh	563% of load			
Latent capacity:	2700 Btuh	1486% of load			
Total capacity:	9000 Btuh	692% of load	SHR:	70%	

Heating Equipment

Design Conditions

Outdoor design DB:	33.4°F	Heat loss:	2879 Btuh	Entering coil DB:	70.0°F
Indoor design DB:	70.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	MITSHUBISHI	Model:	NTXSMT09A112A*+NTXWMT09A112A*		
Actual airflow:	300 cfm				
Output capacity:	9500 Btuh	330% of load		Capacity balance:	5.8 °F
Supplemental heat required:	0 Btuh			Economic balance:	-99 °F

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2018 18.0.16 RSU09167

2021-Apr-19 14:42:48

Page 1

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E



Manual S Compliance Report
UP STAIRS
BABIONE'S A/C & HEATING INC.

Job:
Date: Apr 06, 2021
By: JEFF

820 N MAIN ST., WILLISTON, FL 32696 Phone: 352-529-1034 Fax: 352-529-0007 Email: jeffbabione@embarqmail.com Web: www.babionesac.com License: CACO58697

Project Information

For: RELYEA RESIDENCE GARAGE AREA, JOSHUA SHATKIN
HIGH SPRINGS, FL
Phone: 352-222-3443

Cooling Equipment

Design Conditions

Outdoor design DB:	93.5°F	Sensible gain:	4790	Btuh	Entering coil DB:	75.0°F
Outdoor design WB:	76.5°F	Latent gain:	950	Btuh	Entering coil WB:	62.5°F
Indoor design DB:	75.0°F	Total gain:	5739	Btuh		
Indoor RH:	50%	Estimated airflow:	600	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4018G1+TEM4A0B18S21++TDR		
Actual airflow:	600	cfm			
Sensible capacity:	14105	Btuh	294%	of load	
Latent capacity:	2270	Btuh	239%	of load	
Total capacity:	16375	Btuh	285%	of load SHR: 86%	

Heating Equipment

Design Conditions

Outdoor design DB:	33.4°F	Heat loss:	5141	Btuh	Entering coil DB:	70.0°F
Indoor design DB:	70.0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Trane	Model:	4TWR4018G1+TEM4A0B18S21++TDR		
Actual airflow:	600	cfm			
Output capacity:	17200	Btuh	335%	of load	
Supplemental heat required:	0	Btuh			
Capacity balance:	4.5 °F				
Economic balance:	-99 °F				

Backup equipment type:	Elec strip				
Manufacturer:	Model:				
Actual airflow:	600	cfm			
Output capacity:	1.5	kW	100%	of load Temp. rise: 50 °F	

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2018 18.0.16 RSU09167

2021-Apr-19 14:42:48

Page 2

...ocuments\Wrightsoft HVAC\RELYEA GARAGE BLDG.rup Calc = MJ8 Front Door faces: E



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1
15 Mar 09

Header Information

Contractor: BABIONE'S A/C & HEATING INC.

Mechanical license: CACO58697

Building plan #:

Home address (Street or Lot#, Block, Subdivision): , MINI SPLIT

REQUIRED ATTACHMENTS

Manual J1 Form (and supporting worksheets):
or MJ1AE Form* (and supporting worksheets):
OEM performance data (heating, cooling, blower):
Manual D Friction Rate Worksheet:
Duct distribution sketch:

ATTACHED

Yes ☐	No ☐
Yes ☐	No ☐
Yes ☐	No ☐
Yes ☐	No ☐
Yes ☐	No ☐

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature: 33 °F
Indoor temperature: 70 °F
Total heat loss: 2879 Btuh

Summer Design Conditions

Outdoor temperature: 94 °F
Indoor temperature: 75 °F
Grains difference: 46 gr/lb @50% RH
Sensible heat gain: 1136 Btuh
Latent heat gain: 184 Btuh
Total heat gain: 1320 Btuh

Building Construction Information


Building

Orientation: Front Door faces East
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 0
Conditioned floor area: 157 ft²
Number of occupants: 0

Windows

Eave overhang depth: 1.0 ft
Internal shade: none
Blinds, drapes, etc.
Number of skylights: 0



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type: Split ASHP
Furnace, Heat pump, Boiler, etc.
Model: MITSUBISHI
NTXSMT09A112A*+NTXWMT09A112A*
Heating output capacity: 0 Btuh
Heat pumps - capacity at winter design outdoor conditions
Aux. heating output capacity: 0 Btuh

Cooling Equipment Data

Equipment type: Split ASHP
Air Conditioner, Heat pump, etc.
Model: MITSUBISHI
NTXSMT09A112A*+NTXWMT09A112A*
Total cooling capacity: 0 Btuh
Sensible cooling capacity: 0 Btuh
Latent cooling capacity: 0 Btuh

Blower Data

Heating cfm: 300
Cooling cfm: 300
Static pressure: 0.50 in H₂O
Fan's rated external static pressure for design airflow

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 300 cfm	Longest supply duct: 0 ft	Duct Materials Used
Equipment design ESP: 0.50 in H ₂ O	Longest return duct: 0 ft	Trunk duct:
Total device pressure losses: 0 in H ₂ O	Total effective length (TEL): 0 ft	Branch duct: Sheet metal
Available static pressure (ASP): 0.50 in H ₂ O	Friction rate: 0 in/100ft	

Friction Rate = ASP ÷ (TEL x 100)

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: _____

Contractor's signature: _____ Date: _____

Reserved for County, Town Municipality or Authority having jurisdiction use.

*Home qualifies for MJ1AE Form based on Abridged Edition Checklist



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form
RPER 1
15 Mar 09

Header Information

Contractor: BABIONE'S A/C & HEATING INC.
Mechanical license: CACO58697
Building plan #:
Home address (Street or Lot#, Block, Subdivision): , UP STAIRS

REQUIRED ATTACHMENTS
Manual J1 Form (and supporting worksheets):
or MJ1AE Form* (and supporting worksheets):
OEM performance data (heating, cooling, blower):
Manual D Friction Rate Worksheet:
Duct distribution sketch:

ATTACHED
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐
Yes ☐ No ☐

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions

Outdoor temperature: 33 °F
Indoor temperature: 70 °F
Total heat loss: 5141 Btuh

Summer Design Conditions

Outdoor temperature: 94 °F
Indoor temperature: 75 °F
Grains difference: 46 gr/lb @ 50% RH
Sensible heat gain: 4863 Btuh
Latent heat gain: 964 Btuh
Total heat gain: 5827 Btuh

Building Construction Information


Building

Orientation: Front Door faces East
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 0
Conditioned floor area: 601 ft²
Number of occupants: 2

Windows

Eave overhang depth: 1.0 ft
Internal shade: none
Blinds, drapes, etc.
Number of skylights: 0



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type: Split ASHP
Furnace, Heat pump, Boiler, etc.
Model: Trane
4TWR4018G1+TEM4A0B18S21++TDR
Heating output capacity: 0 Btuh
Heat pumps - capacity at winter design outdoor conditions
Aux. heating output capacity: 5141 Btuh

Cooling Equipment Data

Equipment type: Split ASHP
Air Conditioner, Heat pump, etc.
Model: Trane
4TWR4018G1+TEM4A0B18S21++TDR
Total cooling capacity: 16375 Btuh
Sensible cooling capacity: 14105 Btuh
Latent cooling capacity: 2270 Btuh

Blower Data

Heating cfm: 600
Cooling cfm: 600
Static pressure: 0.50 in H₂O
Fan's rated external static pressure for design airflow

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 600 cfm
Equipment design ESP: 0.50 in H₂O
Total device pressure losses: 0 in H₂O
Available static pressure (ASP): 0.50 in H₂O
Longest supply duct: 306 ft
Longest return duct: 425 ft
Total effective length (TEL): 731 ft
Friction rate: 0.068 in/100ft
Duct Materials Used
Trunk duct: Round flex vinyl, Fiberglass board
Branch duct: Round flex vinyl

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: JEFF BABIONE

Contractor's signature: *Jeff Babione*


Date: 4-20-2021

Reserved for County, Town Municipality or Authority having jurisdiction use.

*Home qualifies for MJ1AE Form based on Abridged Edition Checklist



Level 1



Job #:
Performed by JEFF for:
RELYEA RESIDENCE GARAGE AREA

HIGH SPRINGS, FL
Phone: 352-222-3443

BABIONE'S A/C & HEATING INC.


820 N MAIN ST.
WILLISTON, FL 32696
Phone: 352-529-1034 Fax: 352-529-0007
www.babionesac.com jeffbabione@embarqmail.com

Scale: 1 : 54

Page 1
Right-Suite® Universal 2018
18.0.16 RSU09167
2021-Apr-19 14:44:58
...soft HVAC\RELYEA GARAGE BLI



SECOND FLOOR



Job #:
Performed by JEFF for:
RELYEA RESIDENCE GARAGE AREA

HIGH SPRINGS, FL
Phone: 352-222-3443

BABIONE'S A/C & HEATING INC.

820 N MAIN ST.
WILLISTON, FL 32696
Phone: 352-529-1034 Fax: 352-529-0007
www.babionesac.com jeffbabione@embarqmail.com

Scale: 1 : 54

Page 2
Right-Suite® Universal 2018
18.0.16 RSU09167
2021-Apr-19 14:44:58
...soft HVAC\RELYEA GARAGE BLU