

DATE 04/12/2006

Columbia County Building Permit

PERMIT

This Permit Expires One Year From the Date of Issue

000024387

APPLICANT JOSH HARPER PHONE 352 562-2859
ADDRESS 588 SW LOWE COURT FT. WHITE FL 32038
OWNER SUSAN HARPER/JOSH HARPER PHONE 352 562-2859
ADDRESS SW LOWE COURT FT. WHITE FL 32038
CONTRACTOR VIC ETHRIDGE PHONE 386 462-7554
LOCATION OF PROPERTY 47S, TR ON ELIM CHURCH RD, TL ON LOWE COURT, TO THE
END GOES INTO DRIVE

TYPE DEVELOPMENT MH,UTILITY ESTIMATED COST OF CONSTRUCTION 0.00
HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES
FOUNDATION WALLS ROOF PITCH FLOOR
LAND USE & ZONING A-3 MAX. HEIGHT
Minimum Set Back Requirments: STREET-FRONT 30.00 REAR 25.00 SIDE 25.00
NO. EX.D.U. 0 FLOOD ZONE X DEVELOPMENT PERMIT NO.

PARCEL ID 17-6S-16-03847-005 SUBDIVISION
LOT BLOCK PHASE UNIT TOTAL ACRES

IH0000144
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor
EXISTING 06-0348-N BK JH Y
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: ONE FOOT ABOVE THE ROAD
911 BEFORE POWER
DESIGNATING 5 ACRES OF 15 TO SON FOR MH Check # or Cash CASH

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic
date/app. by date/app. by date/app. by
Under slab rough-in plumbing Slab Sheathing/Nailing
date/app. by date/app. by date/app. by
Framing Rough-in plumbing above slab and below wood floor
date/app. by date/app. by
Electrical rough-in Heat & Air Duct Peri. beam (Lintel)
date/app. by date/app. by date/app. by
Permanent power C.O. Final Culvert
date/app. by date/app. by date/app. by
M/H tie downs, blocking, electricity and plumbing Pool
date/app. by date/app. by
Reconnection Pump pole Utility Pole
date/app. by date/app. by date/app. by
M/H Pole Travel Trailer Re-roof
date/app. by date/app. by date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00
MISC. FEES \$ 200.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 35.52 WASTE FEE \$ 73.50
FLOOD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 384.02
INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

This Permit Must Be Prominently Posted on Premises During Construction

PLEASE NOTIFY THE COLUMBIA COUNTY BUILDING DEPARTMENT AT LEAST 24 HOURS IN ADVANCE OF EACH INSPECTION, IN ORDER THAT IT MAY BE MADE WITHOUT DELAY OR INCONVENIENCE, PHONE 758-1008. THIS PERMIT IS NOT VALID UNLESS THE WORK AUTHORIZED BY IT IS COMMENCED WITHIN 6 MONTHS AFTER ISSUANCE.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

For Office Use Only (Revised 6-23-05)

Zoning Official BLK 1004.06 Building Official OK JTH 4-5-06

AP# 0604-09 Date Received 4-4-06 By LH Permit # 24387

Flood Zone X Development Permit N/A Zoning A3 Land Use Plan Map Category A3

Comments Designating 5 of the 15 Acres of the Son's MH.

911 ADDRESS NEEDED

FEMA Map# _____ Elevation _____ Finished Floor _____ River _____ In Floodway _____

☒ Site Plan with Setbacks Shown ☐ EH Signed Site Plan ☐ EH Release ☐ Well letter ☒ Existing well

☒ Copy of Recorded Deed or Affidavit from land owner ☒ Letter of Authorization from installer

Tex Bill (Letter from Alan) Pre-Insp Approved & attached

Property ID # 17-65-16 03847-005 Must have a copy of the property deed

New Mobile Home _____ Used Mobile Home ☒ Year 1981

Applicant Josh R. Harper Phone # (352)-562-2859

Address _____

Name of Property Owner Susan Z. Harper Phone# (386)497-1325

911 Address _____

Circle the correct power company - FL Power & Light - Clay Electric
(Circle One) - Suwannee Valley Electric - Progress Energy

Name of Owner of Mobile Home Josh R. Harper Phone # 352-562-2859

Address _____

Relationship to Property Owner Son

Current Number of Dwellings on Property 0

Lot Size _____ Total Acreage 5 Acres

Do you : Have an Existing Drive or need a Culvert Permit or a Culvert Waiver (Circle one)

Is this Mobile Home Replacing an Existing Mobile Home No 2nd unit (owes)

Driving Directions to the Property Elim Church Road West off of Hwy 47,
left on Love RD all the way to the end past
588 & 632


Name of Licensed Dealer/Installer Vic Ethelridge Phone # 386 462 2554

Installers Address PO Box 3266 High Springs, FL 32655

License Number T Nooob 144 Installation Decal # 265020

JW called JOSH 4-17-06

28.0.0.2.



Columbia County Property Appraiser

J. Doyle Crews, CFA - Lake City, Florida - 386-758-1083


PARCEL: 17-6S-16-03847-005 HX WX - IMPROVED A (005000)

COMM NE COR OF SW1/4, RUN W 165.03 FT, S 2136.39 FT FOR POB, CONT S 133 FT, W 163.76

Name: HARPER SUSAN ZONA
 Site: LOWE
 Mail: 588 SW LOWE CT
 FT WHITE, FL 32038
 Sales Info: 8/16/1992 \$0.00 V / U

LandVal	\$13,089.00
BldgVal	\$64,341.00
ApprVal	\$84,830.00
JustVal	\$166,650.00
Assd	\$64,205.00
Exmpt	\$25,500.00
Taxable	\$38,705.00

0 0.2 0.4 0.6 mi



This information, GIS Map Updated: 2/7/2006, was derived from data which was compiled by the Columbia County Property Appraiser Office solely for the governmental purpose of property assessment. This information should not be relied upon by anyone as a determination of the ownership of property or market value. No warranties, expressed or implied, are provided for the accuracy of the data herein, its use, or its interpretation. Although it is periodically updated, this information may not reflect the data currently on file in the Property Appraiser's office. The assessed values are NOT certified values and therefore are subject to change before being finalized for ad valorem assessment purposes.

PERMIT NUMBER

Installer Vic Ethelridge License # IL0000144




Address of home being installed _____

Manufacturer Redman Length x width 14 x 20

NOTE: if home is a single wide fill out one half of the blocking plan
if home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used) where the sidewall ties exceed 5 ft 4 in.

Installer's initials SK



New Home ☐ Used Home ☒
Home installed to the Manufacturer's Installation Manual ☐
Home is installed in accordance with Rule 15-C ☒
Single wide ☒ Wind Zone II ☒ Wind Zone III ☐
Double wide ☐ Installation Decal # 265020
Triple/Quad ☐ Serial # 1141516x 70F38DRN

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16" x 16" (256)	18 1/2" x 18 1/2" (342)	20" x 20" (400)	22" x 22" (484)*	24" x 24" (576)*	26" x 26" (676)
1000 psf	3'	4'	4'	5'	6'	7'	8'
1500 psf	4'6"	6'	6'	7'	8'	8'	8'
2000 psf	6'	8'	8'	8'	8'	8'	8'
2500 psf	7'6"	8'	8'	8'	8'	8'	8'
3000 psf	8'	8'	8'	8'	8'	8'	8'
3500 psf	8'	8'	8'	8'	8'	8'	8'

* interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 12x25
Perimeter pier pad size 8x17
Other pier pad sizes (required by the mfg.) 16x16

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.



List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening _____ Pier pad size _____

4 ft 5 ft

FRAME TIES

within 2' of end of home spaced at 5' 4" oc

TIEDOWN COMPONENTS

OTHER TIES

Number

Sidewall _____
Longitudinal _____
Marriage wall _____
Shearwall _____

Longitudinal Stabilizing Device (LSD)

Manufacturer CR 1600 w/ology
Longitudinal Stabilizing Device w/ Lateral Arms
Manufacturer _____

PERMIT NUMBER

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to psf or check here to declare 1000 lb. soil without testing.

X 1000 X 900 X 1500

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

X X X

TORQUE PROBE TEST

The results of the torque probe test is 310 inch pounds or check here if you are declaring 5" anchors without testing 310. A test showing 275 inch pounds or less will require 4 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. I understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may requires anchors with 4000 lb holding capacity.

Installer's initials

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name V.C. Eshen: d a e
Date Tested 3-21-06

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg.

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg.

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg.

Site Preparation

Debris and organic material removed yes
Water drainage: Natural ✓ Swale Pad Other

Fastening multi wide units

Floor: Type Fastener: H/A Length: Spacing:
Walls: Type Fastener: Length: Spacing:
Roof: Type Fastener: Length: Spacing:
For used homes a min. 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherproofing requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials

Type gasket H/A
Pg.
Installed:
Between Floors Yes
Between Walls Yes
Bottom of ridgebeam Yes

Weatherproofing

The bottomboard will be repaired and/or taped. Yes ✓ Pg.
Siding on units is installed to manufacturer's specifications. Yes
Fireplace chimney installed so as not to allow intrusion of rain water. Yes

Miscellaneous

Skirting to be installed. Yes ✓ No
Dryer vent installed outside of skirting. Yes ✓ N/A
Range downflow vent installed outside of skirting. Yes ✓ N/A
Drain lines supported at 4 foot intervals. Yes ✓
Electrical crossovers protected. Yes H/A
Other:


Installer verifies all information given with this permit worksheet is accurate and true based on the manufacturer's installation instructions and or Rule 15C-1 & 2

Installer Signature

[Signature] Date 3-29-06


Applicant shall provide layout from manufacturer specific to the model installed. This form may be used if the layout from the manufacturer is not available.

SINGLE WIDE MOBILE HOME



1000 lb Soil Piers on 5' 4" center on 17x25 ABS PADS
300 lb TORQUE 4' Anchors on 5' 4" centers

 Oliver Tech **DOUBLE WIDE MOBILE HOME**
Longitudinal Stabilizer Devices



ANCHOR



PIER



PIER FOOTING

Show all pier (with size of piers & pads) and anchor location, with maximum spacing and distance from end walls, as required in the manufacturer's specifications. Any special pier footing required (over 16 x 16 inches) shall be noted separately with required dimensions per the manufacturer's specifications. To determine footing size and spacing, a soil bearing capacity test shall be used. Pier footings to be poured-in-place, whether required by manufacturer's specifications or by preference, must be inspected by the Building Department prior to pouring.

Columbia County Property Appraiser

DB Last Updated: 3/7/2006

Parcel: 17-6S-16-03847-005 HX WX

2006 Proposed Values

Tax Record

Property Card

Interactive GIS Map

Print

Owner & Property Info

Search Result: 1 of 1

Owner's Name	HARPER SUSAN ZONA
Site Address	LOWE
Mailing Address	588 SW LOWE CT FT WHITE, FL 32038
Brief Legal	COMM NE COR OF SW1/4, RUN W 165.03 FT, S 2136.39 FT FOR POB, CONT S 133 FT, W 163.76

Use Desc. (code)	IMPROVED A (005000)
Neighborhood	17616.00
Tax District	3
UD Codes	MKTA02
Market Area	02
Total Land Area	15.120 ACRES

Property & Assessment Values

Mkt Land Value	cnt: (2)	\$13,089.00
Ag Land Value	cnt: (2)	\$2,900.00
Building Value	cnt: (1)	\$64,341.00
XFOB Value	cnt: (3)	\$4,500.00
Total Appraised Value		\$84,830.00

Just Value	\$166,650.00
Class Value	\$84,830.00
Assessed Value	\$64,205.00
Exempt Value	(code: HX WX) \$25,500.00
Total Taxable Value	\$38,705.00

Sales History

Sale Date	Book/Page	Inst. Type	Sale VImp	Sale Qual	Sale RCode	Sale Price
8/16/1992	765/697	WD	V	U	02	\$0.00

Building Characteristics

Bldg Item	Bldg Desc	Year Blt	Ext. Walls	Heated S.F.	Actual S.F.	Bldg Value
1	SINGLE FAM (000100)	1995	Vinyl Side (31)	1296	1996	\$64,341.00
Note: All S.F. calculations are based on exterior building dimensions.						

Extra Features & Out Buildings

Code	Desc	Year Blt	Value	Units	Dims	Condition (% Good)
0040	BARN,POLE	1999	\$1,200.00	1.000	20 x 20 x 0	(.00)
0297	SHED CONCR	1999	\$800.00	1.000	12 x 44 x 0	(.00)
0294	SHED WOOD/	1999	\$2,500.00	1.000	22 x 13 x 0	(.00)


Land Breakdown

Lnd Code	Desc	Units	Adjustments	Eff Rate	Lnd Value
000100	SFR (MKT)	1.000 AC	1.00/1.00/1.00/1.00	\$12,339.60	\$12,339.00
005500	TIMBER 2 (AG)	10.000 AC	1.00/1.00/1.00/1.00	\$220.00	\$2,200.00
006200	PASTURE 3 (AG)	4.120 AC	1.00/1.00/1.00/1.00	\$170.00	\$700.00
009910	MKT.VAL.AG (MKT)	14.120 AC	1.00/1.00/1.00/1.00	\$0.00	\$84,720.00
009947	SEPTIC (MKT)	1.000 UT - (.000AC)	1.00/1.00/1.00/1.00	\$750.00	\$750.00


Columbia County Property Appraiser

DB Last Updated: 3/7/2006

1 of 1



APPROXIMATE SCALE IN FEET



NATIONAL FLOOD INSURANCE PROGRAM

FIRM FLOOD INSURANCE RATE MAP

COLUMBIA
COUNTY,
FLORIDA
(UNINCORPORATED AREAS)

PANEL 225 OF 290

PANEL LOCATION




COMMUNITY-PANEL NUMBER
120070 0225 B
EFFECTIVE DATE:
JANUARY 6, 1988



Federal Emergency Management Agency


This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT Version 1.0. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. Further information about National Flood Insurance Program flood hazard maps is available at www.fema.gov/nifm

SITE PLAN EXAMPLE / WORKSHEET



Use this example to draw your own site plan. Show all existing buildings and any other homes on this property and show the distances between them, Also show where the roads or roads are around the property. This site plan can also be used for the 911 Addressing department if you include the distance from the driveway to the nearest property line.

Site plan



(5 Acres)

4/3/06

I, Susan Zona Harper give My son,
Josh R. Harper Permission to put a
mobile Home on the North-West site
of my Property.

Property
ID # 17-65-46-03847-00-5

Susan Zona Harper

Gale Tedder
4/3/06



RONNIE BRANNON
COLUMBIA COUNTY TAX COLLECTOR

THIRD INSTALLMENT (DEC) 2005 114956.0000
NOTICE OF AD VALOREM TAXES AND NON-AD VALOREM ASSESSMENTS

ACCOUNT NUMBER	ESCROW CD	ASSESSED VALUE	EXEMPTIONS	TAXABLE VALUE	MILLAGE CODE
R03847-005	999	62,419	25,500	36,919	003

HARPER SUSAN ZONA
588 SW LOWE CT
FT WHITE FL

32038

17-69-16 5000/5000 15.12 Acres
COMM NE COR OF SW1/4, RUN W
165.03 FT, S 2136.39 FT FOR
POB, CONT S 133 FT, W 163.76
FT, S 266 FT, E 163.76 FT,
S 133.32 FT, W 583.71 FT, N
See Additional Legal on Tax Roll

Control # 2202644.0001
Date 12/20/05 Amount
PAID BY: HARPER SUSAN ZONA

RONNIE BRANNON TAX COLLECTOR

TAXING AUTHORITY	MILLAGE RATE	EXEMPTION AMOUNT	TAXABLE VALUE	TAXES LEVIED
001 BOARD OF COUNTY COMMIS	8.7260			322.16
002 COLUMBIA COUNTY SCHOOL				244.39K
DISCRETIONARY				
LOCAL	.7600			28.06
CAPITAL OUTLAY	5.1950			191.79
SR SUWANNEE RIVER WATER M	2.0000			73.84
ILSH LAKE SHORE HOSPITAL AU	.4914			18.14
IDA INDUSTRIAL DEVELOPEMEN	1.7500			64.61
	.1380			5.09

TOTAL MILLAGE 19.0604

AD VALOREM TAXES

703.69

LEVYING AUTHORITY	RATE	AMOUNT
FIR FIRE ASSESSMENTS		99.09
GAR SOLID WASTE - ANNUAL		147.00

NON-AD VALOREM ASSESSMENTS

246.09

COMBINED TAXES AND ASSESSMENTS 949.78 See reverse side for Important information

005 Gross	Gross	Discount	If Paid By	Dec 31 2005
949.78	251.95	7.56	Please	

Please
Retain this
Portion for
your Records

◀ IF PAID BY

AAA
MOBILE HOME TRANSPORT

Phone (352) 372-1366
Home (386) 462-7554
Mobile (352) 316-0953
State Lic # DH0000144

Vic Etheridge

Owner/Operator

DATE 3-27-06

NAME OF LICENSE HOLDER

Vic Etheridge

LICENSE CERTIFICATE #

214 0000 114

THE FOLLOWING PERSON(S) ARE AUTHORIZED TO SIGN FOR PERMITS FOR THE ABOVE REFERENCED LICENSE HOLDER

NAMES: PLEASE PRINT

SIGNATURE

RELATIONSHIP

Hager, Josh	<i>[Signature]</i>	Customer
	"1" One	PERMIT ONLY

Authorizations forms are good 12 months of dated form. (Unless otherwise specified if less than 12 months)

The foregoing instrument was acknowledged before me this 27th day of March 2006
by Victor Etheridge who is personally known to me or has produced

identification Type of Identification _____ # _____

Signature of License Holder

Signature of Notary

[Signature]
[Signature]

Commission # & Seal/Stamp:

LAURA KATHERINE A PYLE
Notary Public, State of Florida
My comm. exp. June 23, 2008
Comm. No. DD 324711

**CODE ENFORCEMENT I
PRELIMINARY MOBILE HOME INSPECTION REPORT**

DATE RECEIVED _____ BY BD IS THE M/H ON THE PROPERTY WHERE THE PERMIT WILL BE ISSUED? _____

OWNERS NAME Josh Harper PHONE _____ CELL _____

ADDRESS _____

MOBILE HOME PARK _____ SUBDIVISION _____

DRIVING DIRECTIONS TO MOBILE HOME CR 240 441^S / R 240 1 1/2 mile on Right
White Summit with Skirting pulled off

MOBILE HOME INSTALLER AAA Movers PHONE _____ CELL _____

MOBILE HOME INFORMATION

MAKE _____ YEAR 91 SIZE 14 x 70 COLOR white

SERIAL No. 11415164

WIND ZONE II Must be wind zone II or higher NO WIND ZONE I ALLOWED

INTERIOR:

INSPECTION STANDARDS

(P or F) - P= PASS F= FAILED

P SMOKE DETECTOR () OPERATIONAL () MISSING

P FLOORS () SOLID () WEAK () HOLES DAMAGED LOCATION _____

P DOORS () OPERABLE () DAMAGED

P WALLS () SOLID () STRUCTURALLY UNSOUND

P WINDOWS () OPERABLE () INOPERABLE

P PLUMBING FIXTURES () OPERABLE () INOPERABLE () MISSING

P CEILING () SOLID () HOLES () LEAKS APPARENT

P ELECTRICAL (FIXTURES/OUTLETS) () OPERABLE () EXPOSED WIRING () OUTLET COVERS MISSING () LIGHT FIXTURES MISSING

EXTERIOR:

P WALLS / SIDING () LOOSE SIDING () STRUCTURALLY UNSOUND () NOT WEATHERTIGHT () NEEDS CLEANING

P WINDOWS () CRACKED/ BROKEN GLASS () SCREENS MISSING () WEATHERTIGHT

P ROOF () APPEARS SOLID () DAMAGED

STATUS:

APPROVED ✓ WITH CONDITIONS: _____

NOT APPROVED _____ NEED REINSPECTION FOR FOLLOWING CONDITIONS _____

SIGNATURE _____ ID NUMBER _____ DATE _____

COLUMBIA COUNTY 9-1-1 ADDRESSING

P. O. Box 1787, Lake City, FL 32056-1787

PHONE: (386) 758-1125 * FAX: (386) 758-1365 * Email: ron_croft@columbiacountyfla.com

Addressing Maintenance

To maintain the Countywide Addressing Policy you must make application for a 9-1-1 Address at the time you apply for a building permit. The established standards for assigning and posting numbers to all principal buildings, dwellings, businesses and industries are contained in Columbia County Ordinance 2001-9. The addressing system is to enable Emergency Service Agencies to locate you in an emergency, and to assist the United States Postal Service and the public in the timely and efficient provision of services to residents and businesses of Columbia County.

DATE REQUESTED: 4/3/2006 DATE ISSUED: 4/19/2006

ENHANCED 9-1-1 ADDRESS:

661 SW LOWE CT

FORT WHITE FL 32038

PROPERTY APPRAISER PARCEL NUMBER:

17-6S-16-03847-005

Remarks:

Address Issued By: _____

Columbia County 9-1-1 Addressing / GIS Department

NOTICE: THIS ADDRESS WAS ISSUED BASED ON LOCATION INFORMATION RECEIVED FROM THE REQUESTER. SHOULD, AT A LATER DATE, THE LOCATION INFORMATION BE FOUND TO BE IN ERROR, THIS ADDRESS IS SUBJECT TO CHANGE.

170

COLUMBIA COUNTY
9-1-1 ADDRESSING
APPROVED

24387

Gaylord Pump & Irrigation Inc.

P.O. Box 548

Branford, Fl. 32008

386-935-0932 Fax 386-935-0778

06/12/06

Permit Number 4000024387

Josh Harper

We will be drilling a well for Josh Harper. The property ID number is 17-6S-16-03847-005. The following equipment will be used.

4" Steel Casing

1 Hp Submersible pump

1-1/4" Galvanize drop pipe

81 Gallon diaphragm tank with 24.9 gallons of draw down

This equipment meets or exceeds the Florida building code, plumbing section 612 table 612.1

Sincerely,

Donald Gaylord



Licensed Well Driller

Florida License 2630