



SUWANNEE RIVER WATER MANAGEMENT DISTRICT

March 14, 2012

Matthew T. Gray
JSN Properties, Inc.
3400 SW 22 Place
Bell, FL 32619

Subject: Receipt of Environmental Resource Permit Application for
Gray Construction Office Building Addition - ERP05-0417M -
Gilchrist County

Dear Mr. Gray:

The Suwannee River Water Management District (District) received your application package on March 14, 2012, for Gray Construction Office Building Addition. Your proposed project has been assigned permit number ERP05-0417M, and is currently under review by permitting staff. You will receive a response from staff within 30 days after receipt of the application package. This is pursuant to Chapter 120.60(1), Florida Statutes.

Please be advised that it is a violation of District rules to begin any work before a permit is issued, unless you have applied for a General Permit After Notice for Construction, Operation, Maintenance, Alteration, Abandonment or Removal of Minor Silvicultural Surface Water Management Systems under section 40B-400.500, Florida Administrative Code. Your submitted application package does not alleviate you from having to obtain all other clearances, permits, or authorization required by any other unit of local, state, or federal government.

Florida Statutes 373.419 states, "Within 30 days after the completion of construction or alteration of any stormwater management system, dam, impoundment, reservoir, appurtenant work, or works, the permittee shall file a written statement of completion with the governing board..." We will enclose the appropriate forms upon issuance of the permit to satisfy the requirement.

If you have any further questions, please contact John Hastings at 386.362.1001, or toll free at 800.226.1066. In order to better serve you, please include the permit number in all correspondence.

Sincerely,

A handwritten signature in dark ink, appearing to read "Tim Sagul".

Tim Sagul, P.E.

Senior Professional Engineer

cc: Josh Highlander, PE

Water for Nature, Water for People

9225 CR 49 • LIVE OAK, FLORIDA 32060 • TELEPHONE 386/362-1001 • 800/226-1066 • FAX 386/362-1056
mysuwanneeriver.com

29

DON QUINCEY
Chairman
Chiefland, Florida

ALPHONAS ALEXANDER
Vice Chairman
Madison, Florida

RAY CURTIS
Secretary/Treasurer
Perry, Florida

KEVIN BROWN
Alachua, Florida

GEORGE COLE
Monticello, FL

HEATH DAVIS
Cedar Key, Florida

CARL E. MEECE
O'Brien, Florida

JAMES L. FRALEIGH
Madison, Florida

GUY N. WILLIAMS
Lake City, Florida

DAVID A. STILL
Executive Director
Lake City, Florida



COLUMBIA COUNTY FIRE RESCUE

Life Safety Services

P.O. BOX 1529 Lake City, Florida 32056
Office (386) 754-7071 Fax (386) 754-7064

Interim Fire Chief
David L. Boozer

23 March 2012

TO: Troy Crews
Columbia County Building and Zoning

FROM: David L. Boozer
Interim Fire Chief/Fire Marshal

RE: Clay Electric Coop
1659 SW SR 47
Lake City, Florida 32025

A plan review was performed of the submitted plans for the New Clay Electric Coop building to be located at 1659 SW SR 47, Lake City, Florida. This building meets the requirements as outlined in Chapter 38, New Business, of the Florida Fire Prevention Code 2007 edition. I recommend approval with the following condition;

- Light Weight Truss Marking - State Fire Marshal rule(s) 69A-3.012 for Uniform Code buildings or 69A60.008 for Minimum Code buildings requires you to install the required symbol(s) by March 13, 2010.

Should you require any additional information, please feel free to contact my office.

Sincerely,

David L. Boozer



#30199

ENG, DENMAN & ASSOCIATES, INC.

ENGINEERS • SURVEYORS • PLANNERS

OK
10 SEPT. 2012
BLK

September 7, 2012

Gray Construction, Inc.
Attn: Kelly Stone
222 West Wade Street
Trenton, FL 32693

Via Email: kstone@gray-construction.com

Re: Finished Floor Elevations
Clay Electric Cooperative, Lake City District Office
State Road No. 47, Columbia County, Florida
Project No. 2012-138-502

Dear Mr. Stone,

I do hereby certify that on September 7, 2012 I established the finished floor elevation (the top of the concrete foundation slab) of the office/warehouse building to be 133.54 feet and the finished floor elevation (the top of the concrete foundation slab) of the garage building to be 130.52 feet.

These elevations are based on NAVD 1988 datum.

These buildings are under construction and are located on Columbia County, Florida Tax Parcel No. 18-4S-17-08451-004.

Sincerely,

Robert W. Graver
P.S.M. 4239





130199

ASI ARCHITECT'S SUPPLEMENTAL INSTRUCTIONS

606 N.E. First Street
Phone (352) 372-0425

Gainesville, Florida
FAX (352) 372-0427

PAGE 1 OF 4

TO: Gray Construction Services, Inc.
222 West Wade Street
Trenton, FL 32693

DATE November 19, 2012
RE: Clay Electric Cooperative, Inc.
New District Office - Project Number 11-1300
Lake City, FL
(3702.060)

ATTN: Ryan Parker

COMMENTS: ARCHITECT'S SUPPLEMENTAL INSTRUCTIONS NO. 21:

You are hereby directed to execute promptly this (ASI) which interprets the Contract Documents or orders minor changes in the Work without change in Contract Sum or Contract Time. If you consider that a change in Contract Sum or Contract Time is required, please submit your itemized proposal to the Architect immediately and before proceeding with this Work. If your proposal is found to be satisfactory and in proper order, a Change Order or a Contingency Use Authorization as appropriate will be executed to formalize the change(s).

Contract Dated: February 29, 2012

Description: Garage Addition

Add an open air addition to the east side of the Garage as indicated on Supplemental Drawings SK-27, SK-28A and SK-28B.

Attachments:*

Supplemental Drawings SK-27, SK-28A and SK-28B, all dated 11/15/12.

**It is the Contactor's responsibility to distribute any attachments contained in this ASI to any and all necessary parties.*

CC: Barry Marquart
Kelly Stone

Brame Architects

Donald L. Heck, AIA, LEED AP