

28 JULY 2022

BUILDING OFFICIAL
COLUMBIA COUNTY, BUILDING DEPT.
COLUMBIA COUNTY COURTHOUSE ANNEX
LAKE CITY, FLORIDA 32055

RE: JONES RESIDENCE, FOREST COUNTRY S/D PERMIT Nr.:

DEAR SIR:

PLEASE BE ADVISED OF THE FOLLOWING CHANGES TO THE CONSTRUCTION DOCUMENTS FOR THE ABOVE REFERENCED PROJECT:

- 1. DETAIL B/A.T SHALL BE AMENDED TO DELETE THE 2nd SILL PLATE AT EITHER SIDE OF THE GARAGE DOOR OPENING
- 2. IN LIEU OF THE ANCHOR BOLTS AS CALLED FOR IN THE CONSTRUCTION DOCUMENTS, IT SHALL BE PERMISSIBLE TO INSTALL 1/2" X 10" "J" BOLTS IN ALL LOCATIONS REQUIRED BY THE PLAN NOTES AND DETAILS.

SHOULD YOU HAVE ANY FURTHER QUESTIONS WITH THIS, PLEASE CALL FOR ASSISTANCE.

No.

YOURS TRULY, NICHOLAS PAUL GEISLER, ARCHITECT AROOOTOOS

> N. P. GEISL ER

Digitally signed by: N. P. GEISLER
DN: CN = N. P. GEISLER
C = US O = AR0007005
OU = ARCHITECT
Date: 2022.07.28 10:43:
08-05'00'