



CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
7540 103rd St. Suite 215 • Jacksonville, FL 32210

Lake City • (386) 755-3633
Fax • (386) 752-5456

Jacksonville • (904) 381-8901
Fax • (904) 381-8902

JOB NO.: 21-492
DATE TESTED: 10-22-21

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: X (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: ADF Concrete 359 SE Seward way

CLIENT: ADF Concrete

GENERAL CONTRACTOR: Snc EARTHWORK CONTRACTOR: Snc

SOIL USE (SEE NOTE): I SPECIFICATION REQUIREMENTS: 95%

TECHNICIAN: Cody Stettin

MODIFIED (ASTM D-1557): X STANDARD (ASTM D-698):

TEST NO.	TEST LOCATION	TEST: DEPTH ELEV. LIFT	PROCTOR NO.	WET DENS. LBS.CU.FT.	DRY DENS. LBS.CU.FT.	MOIST PERCENT	% MAX. DENS.
1	10' NE + 5' SE From W Corner	12"	1039	110.9	103.9	6.8	100%
2	5' NE + 25' SE From W Corner	12"	1039	107.6	103.3	4.2	99%
3	25' NE + 75' SE From W Corner	12"	1039	107.4	102.6	4.7	99%

REMARKS:

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
1		1039	14.2

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.