



12 MARCH 2020

RE: PORCH POST CONNECTION

CUSTOMER: PETER & ANNA LEV

BUILDING OFFICIAL: COLUMBIA COUNTY BUILDING DEPARTMENT

TO WHOM IT MAY CONCERN,

UPON REVIEW OF POST/ BEAM CONNECTION AT THE PORCHES, THE INTERMEDIATE POST CONNECTION IS SUFFICIENT AS CONSTRUCTED. THE CORNER POST SHALL HAVE AN ST-22 POST TO BEAM STRAP ON BOTH EXTERIOR FACES OF THE POST. FILL ALL HOLES WITH 10d HDG NAILS.

IF YOU HAVE ANY FURTHER QUESTIONS, OR IF WE MAY BE OF FURTHER SERVICE, PLEASE CONTACT MY PERSONAL REPRESENTATIVE FOR THIS PROJECT:

WILL MYERS  
WM DESIGN & ASSOCIATES, INC.  
426 SW COMMERCE DR. STE 130  
LAKE CITY, FLORIDA 32025  
PHONE: 386.867.1394  
EMAIL: will@willmyers.net

THANK YOU,

SINCERELY,

NICHOLAS PAUL GEISLER, ARCHITECT AR0007005