

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Florida Department of Business and Professional Regulation - Residential Performance Method


Project Name: Odum Residence Street: 363 NW Celtic Ct City, State, Zip: Lake City, FL, 32055- Owner: Odum Design Location: FL, Gainesville	Builder Name: Bryan Zecher Construction Permit Office: Columbia County Permit Number: Jurisdiction: 221000
---	---

<table style="width: 100%;"> <tr> <td style="width: 30%;">1. New construction or existing</td> <td style="width: 30%;">New (From Plans)</td> <td style="width: 40%;"></td> </tr> <tr> <td>2. Single family or multiple family</td> <td>Single-family</td> <td></td> </tr> <tr> <td>3. Number of units, if multiple family</td> <td>1</td> <td></td> </tr> <tr> <td>4. Number of Bedrooms</td> <td>3</td> <td></td> </tr> <tr> <td>5. Is this a worst case?</td> <td>No</td> <td></td> </tr> <tr> <td>6. Conditioned floor area above grade (ft²)</td> <td>2419</td> <td></td> </tr> <tr> <td>Conditioned floor area below grade (ft²)</td> <td>0</td> <td></td> </tr> <tr> <td>7. Windows (222.9 sqft.)</td> <td>Description</td> <td>Area</td> </tr> <tr> <td>a. U-Factor:</td> <td>Dbf, U=0.55</td> <td>222.94 ft²</td> </tr> <tr> <td>SHGC:</td> <td>SHGC=0.60</td> <td></td> </tr> <tr> <td>b. U-Factor:</td> <td>N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> <td></td> </tr> <tr> <td>c. U-Factor:</td> <td>N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> <td></td> </tr> <tr> <td>d. U-Factor:</td> <td>N/A</td> <td>ft²</td> </tr> <tr> <td>SHGC:</td> <td></td> <td></td> </tr> <tr> <td colspan="2">Area Weighted Average Overhang Depth:</td> <td>13.243 ft.</td> </tr> <tr> <td colspan="2">Area Weighted Average SHGC:</td> <td>0.600</td> </tr> <tr> <td>8. Floor Types (2419.0 sqft.)</td> <td>Insulation</td> <td>Area</td> </tr> <tr> <td>a. Slab-On-Grade Edge Insulation</td> <td>R=0.0</td> <td>2419.00 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R=</td> <td>ft²</td> </tr> <tr> <td>c. N/A</td> <td>R=</td> <td>ft²</td> </tr> </table>	1. New construction or existing	New (From Plans)		2. Single family or multiple family	Single-family		3. Number of units, if multiple family	1		4. Number of Bedrooms	3		5. Is this a worst case?	No		6. Conditioned floor area above grade (ft ²)	2419		Conditioned floor area below grade (ft ²)	0		7. Windows (222.9 sqft.)	Description	Area	a. U-Factor:	Dbf, U=0.55	222.94 ft ²	SHGC:	SHGC=0.60		b. U-Factor:	N/A	ft ²	SHGC:			c. U-Factor:	N/A	ft ²	SHGC:			d. U-Factor:	N/A	ft ²	SHGC:			Area Weighted Average Overhang Depth:		13.243 ft.	Area Weighted Average SHGC:		0.600	8. Floor Types (2419.0 sqft.)	Insulation	Area	a. Slab-On-Grade Edge Insulation	R=0.0	2419.00 ft ²	b. N/A	R=	ft ²	c. N/A	R=	ft ²	<table style="width: 100%;"> <tr> <td style="width: 30%;">9. Wall Types (1845.8 sqft.)</td> <td style="width: 30%;">Insulation</td> <td style="width: 40%;">Area</td> </tr> <tr> <td>a. Frame - Wood, Exterior</td> <td>R=19.0</td> <td>1845.80 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R=</td> <td>ft²</td> </tr> <tr> <td>c. N/A</td> <td>R=</td> <td>ft²</td> </tr> <tr> <td>d. N/A</td> <td>R=</td> <td>ft²</td> </tr> <tr> <td>10. Ceiling Types (2419.0 sqft.)</td> <td>Insulation</td> <td>Area</td> </tr> <tr> <td>a. Under Attic (Vented)</td> <td>R=30.0</td> <td>2419.00 ft²</td> </tr> <tr> <td>b. N/A</td> <td>R=</td> <td>ft²</td> </tr> <tr> <td>c. N/A</td> <td>R=</td> <td>ft²</td> </tr> <tr> <td>11. Ducts</td> <td>R</td> <td>ft²</td> </tr> <tr> <td>a. Sup: Attic, Ret: Attic, AH: Main</td> <td>6</td> <td>483.8</td> </tr> <tr> <td>12. Cooling systems</td> <td>kBtu/hr</td> <td>Efficiency</td> </tr> <tr> <td>a. Central Unit</td> <td>35.0</td> <td>SEER:14.00</td> </tr> <tr> <td>13. Heating systems</td> <td>kBtu/hr</td> <td>Efficiency</td> </tr> <tr> <td>a. Electric Heat Pump</td> <td>35.0</td> <td>HSPF:7.70</td> </tr> <tr> <td>14. Hot water systems</td> <td></td> <td></td> </tr> <tr> <td>a. Electric</td> <td></td> <td>Cap: 66 gallons</td> </tr> <tr> <td></td> <td></td> <td>EF: 0.920</td> </tr> <tr> <td>b. Conservation features</td> <td></td> <td></td> </tr> <tr> <td>None</td> <td></td> <td></td> </tr> <tr> <td>15. Credits</td> <td></td> <td>CF, Pstat</td> </tr> </table>	9. Wall Types (1845.8 sqft.)	Insulation	Area	a. Frame - Wood, Exterior	R=19.0	1845.80 ft ²	b. N/A	R=	ft ²	c. N/A	R=	ft ²	d. N/A	R=	ft ²	10. Ceiling Types (2419.0 sqft.)	Insulation	Area	a. Under Attic (Vented)	R=30.0	2419.00 ft ²	b. N/A	R=	ft ²	c. N/A	R=	ft ²	11. Ducts	R	ft ²	a. Sup: Attic, Ret: Attic, AH: Main	6	483.8	12. Cooling systems	kBtu/hr	Efficiency	a. Central Unit	35.0	SEER:14.00	13. Heating systems	kBtu/hr	Efficiency	a. Electric Heat Pump	35.0	HSPF:7.70	14. Hot water systems			a. Electric		Cap: 66 gallons			EF: 0.920	b. Conservation features			None			15. Credits		CF, Pstat
1. New construction or existing	New (From Plans)																																																																																																																																	
2. Single family or multiple family	Single-family																																																																																																																																	
3. Number of units, if multiple family	1																																																																																																																																	
4. Number of Bedrooms	3																																																																																																																																	
5. Is this a worst case?	No																																																																																																																																	
6. Conditioned floor area above grade (ft ²)	2419																																																																																																																																	
Conditioned floor area below grade (ft ²)	0																																																																																																																																	
7. Windows (222.9 sqft.)	Description	Area																																																																																																																																
a. U-Factor:	Dbf, U=0.55	222.94 ft ²																																																																																																																																
SHGC:	SHGC=0.60																																																																																																																																	
b. U-Factor:	N/A	ft ²																																																																																																																																
SHGC:																																																																																																																																		
c. U-Factor:	N/A	ft ²																																																																																																																																
SHGC:																																																																																																																																		
d. U-Factor:	N/A	ft ²																																																																																																																																
SHGC:																																																																																																																																		
Area Weighted Average Overhang Depth:		13.243 ft.																																																																																																																																
Area Weighted Average SHGC:		0.600																																																																																																																																
8. Floor Types (2419.0 sqft.)	Insulation	Area																																																																																																																																
a. Slab-On-Grade Edge Insulation	R=0.0	2419.00 ft ²																																																																																																																																
b. N/A	R=	ft ²																																																																																																																																
c. N/A	R=	ft ²																																																																																																																																
9. Wall Types (1845.8 sqft.)	Insulation	Area																																																																																																																																
a. Frame - Wood, Exterior	R=19.0	1845.80 ft ²																																																																																																																																
b. N/A	R=	ft ²																																																																																																																																
c. N/A	R=	ft ²																																																																																																																																
d. N/A	R=	ft ²																																																																																																																																
10. Ceiling Types (2419.0 sqft.)	Insulation	Area																																																																																																																																
a. Under Attic (Vented)	R=30.0	2419.00 ft ²																																																																																																																																
b. N/A	R=	ft ²																																																																																																																																
c. N/A	R=	ft ²																																																																																																																																
11. Ducts	R	ft ²																																																																																																																																
a. Sup: Attic, Ret: Attic, AH: Main	6	483.8																																																																																																																																
12. Cooling systems	kBtu/hr	Efficiency																																																																																																																																
a. Central Unit	35.0	SEER:14.00																																																																																																																																
13. Heating systems	kBtu/hr	Efficiency																																																																																																																																
a. Electric Heat Pump	35.0	HSPF:7.70																																																																																																																																
14. Hot water systems																																																																																																																																		
a. Electric		Cap: 66 gallons																																																																																																																																
		EF: 0.920																																																																																																																																
b. Conservation features																																																																																																																																		
None																																																																																																																																		
15. Credits		CF, Pstat																																																																																																																																

Glass/Floor Area: 0.092	Total Proposed Modified Loads: 30.08	PASS
	Total Standard Reference Loads: 46.87	

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code. PREPARED BY: <u>T. A. Dilline</u> DATE: <u>8/12/12</u> I hereby certify that this building, as designed, is in compliance with the Florida Energy Code. OWNER/AGENT: <u>[Signature]</u> DATE: <u>8/14/12</u>	Review of the plans and specifications covered by this calculation indicates compliance with the Florida Energy Code. Before construction is completed this building will be inspected for compliance with Section 553.908 Florida Statutes. BUILDING OFFICIAL: _____ DATE: _____ 
---	---

- Compliance requires completion of a Florida Air Barrier and Insulation Inspection Checklist



PROJECT												
Title:	Odum Residence		Bedrooms:	3		Address Type:		Street Address				
Building Type:	User		Conditioned Area:	2419		Lot #						
Owner:	Odum		Total Stories:	1		Block/SubDivision:						
# of Units:	1		Worst Case:	No		PlatBook:						
Builder Name:	Bryan Zecher Construction		Rotate Angle:	0		Street:		363 NW Celtic Ct				
Permit Office:	Columbia County		Cross Ventilation:			County:		Columbia				
Jurisdiction:	221000		Whole House Fan:			City, State, Zip:		Lake City , FL , 32055-				
Family Type:	Single-family											
New/Existing:	New (From Plans)											
Comment:												
CLIMATE												
✓	Design Location	TMY Site	IECC Zone	Design Temp 97.5 %	2.5 %	Int Design Temp Winter	Summer	Heating Degree Days	Design Moisture	Daily Temp Range		
_____	FL, Gainesville	FL_GAINESVILLE_REGI	2	32	92	70	75	1305.5	51	Medlum		
BLOCKS												
	Number	Name	Area	Volume								
	1	Block1	2419	21771								
SPACES												
	Number	Name	Area	Volume	Kitchen	Occupants	Bedrooms	Infil ID	Finished	Cooled	Heated	
	1	Main	2419	21771	Yes	3	3	1	Yes	Yes	Yes	
FLOORS												
✓	#	Floor Type	Space	Perimeter	R-Value	Area		Tile	Wood	Carpet		
_____	1	Slab-On-Grade Edge Insulation	Main	226 ft	0	2419 ft²	----	0.8	0	0.2		
ROOF												
✓	#	Type	Materials	Roof Area	Gable Area	Roof Color	Solar Absor.	SA Tested	Emitt	Emitt Tested	Deck Insul.	Pitch (deg)
_____	1	Gable or shed	Composition shingles	2705 ft²	606 ft²	Medium	0.96	No	0.9	No	0	26.6
ATTIC												
✓	#	Type	Ventilation	Vent Ratio (1 in)	Area	RBS	IRCC					
_____	1	Full attic	Vented	300	2419 ft²	N	N					
CEILING												
✓	#	Ceiling Type	Space	R-Value	Area	Framing Frac	Truss Type					
_____	1	Under Attic (Vented)	Main	30	2419 ft²	0.11	Wood					

WALLS															
✓	#	Orit	Adjacent To	Wall Type	Space	Cavity R-Value	Width Ft	In	Height Ft	In	Area	Sheathing R-Value	Framing Fraction	Solar Absor	Below Grade%
✓	1	N	Exterior	Frame - Wood	Main	19	17	4	9	0	156.0 ft²		0.23	0.75	0
✓	2	N	Exterior	Frame - Wood	Main	19	36	6	9	0	328.5 ft²		0.23	0.75	0
✓	3	N	Exterior	Frame - Wood	Main	19	37	7	9	0	338.3 ft²		0.23	0.75	0
✓	4	N	Exterior	Frame - Wood	Main	19	52	1	9	0	468.8 ft²		0.23	0.75	0
✓	5	N	Exterior	Frame - Wood	Main	19	6	11	9	0	62.3 ft²		0.23	0.75	0
✓	6	N	Exterior	Frame - Wood	Main	19	41	8	9	0	375.0 ft²		0.23	0.75	0
✓	7	N	Exterior	Frame - Wood	Main	19	13	0	9	0	117.0 ft²		0.23	0.75	0

DOORS											
✓	#	Orit	Door Type	Space	Storms	U-Value	Width Ft	In	Height Ft	In	Area
✓	1	N	Insulated	Main	Metal	.28	6		8		48 ft²
✓	2	N	Insulated	Main	Metal	.28	2	8	6	8	17.9 ft²
✓	3	N	Insulated	Main	Metal	.28	3		8	8	20 ft²

WINDOWS														
Orientation shown is the entered, Proposed orientation.														
✓	#	Orit	Wall ID	Frame	Panels	NFRC	U-Factor	SHGC	Area	Overhang Depth	Separation	Int Shade	Screening	
✓	1	N	1	Vinyl	Low-E Double	Yes	0.55	0.6	17.3 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	
✓	2	N	2	Vinyl	Low-E Double	Yes	0.55	0.6	5.3 ft²	2 ft 8 in	5 ft 8 in	Drapes/blinds	None	
✓	3	N	2	Vinyl	Low-E Double	Yes	0.55	0.6	6.7 ft²	6 ft 6 in	0 ft 4 in	Drapes/blinds	None	
✓	4	N	3	Vinyl	Low-E Double	Yes	0.55	0.6	4.4 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	
✓	5	N	3	Vinyl	Low-E Double	Yes	0.55	0.6	10.9 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	
✓	6	N	4	Vinyl	Low-E Double	Yes	0.55	0.6	18.7 ft²	20 ft 8 in	0 ft 4 in	Drapes/blinds	None	
✓	7	N	4	Vinyl	Low-E Double	Yes	0.55	0.6	98.2 ft²	20 ft 8 in	0 ft 4 in	Drapes/blinds	None	
✓	8	N	4	Vinyl	Low-E Double	Yes	0.55	0.6	30.2 ft²	11 ft 8 in	0 ft 4 in	Drapes/blinds	None	
✓	9	N	5	Vinyl	Low-E Double	Yes	0.55	0.6	3.7 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	
✓	10	N	6	Vinyl	Low-E Double	Yes	0.55	0.6	12.4 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	
✓	11	N	6	Vinyl	Low-E Double	Yes	0.55	0.6	2.7 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	
✓	12	N	6	Vinyl	Low-E Double	Yes	0.55	0.6	12.4 ft²	2 ft 0 in	0 ft 4 in	Drapes/blinds	None	

INFILTRATION								
#	Scope	Method	SLA	CFM 50	ELA	EqLA	ACH	ACH 50
1	Wholehouse	Best Guess	.0005	3172.5	174.17	327.55	.385	8.7434

HEATING SYSTEM									
✓	#	System Type	Subtype	Efficiency	Capacity	Block	Ducts		
✓	1	Electric Heat Pump	None	HSPF: 7.7	35 kBtu/hr	1	sys#1		

COOLING SYSTEM									
✓	#	System Type	Subtype	Efficiency	Capacity	Air Flow	SHR	Block	Ducts
✓	1	Central Unit	Split	SEER: 14	35 kBtu/hr	1050 cfm	0.75	1	sys#1

HOT WATER SYSTEM									
✓	#	System Type	SubType	Location	EF	Cap	Use	SelPnt	Conservation
✓	1	Electric	None	Main	0.92	66 gal	60 gal	120 deg	None

SOLAR HOT WATER SYSTEM									
✓	FSEC Cert #	Company Name	System Model #	Collector Model #	Collector Area	Storage Volume	FEF		
✓	None	None			112				

DUCTS														
✓	#	--- Supply ---			--- Return ---		Leakage Type	Air Handler	CFM 25 TOT	CFM25 OUT	QN	RLF	HVAC #	
		Location	R-Value	Area	Location	Area							Heat	Cool
✓	1	Attic	6	483.8 ft²	Attic	120.95 f	Default Leakage	Main	(Default)	c(Default)	c		1	1

TEMPERATURES														
Programable Thermostat: Y					Celling Fans:									
Cooling	Heating	Venting	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
			☒	☒	☒	☒	☒	☒	☒	☒	☒	☒	☒	☒
			Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec

Thermostat Schedule: HERS 2006 Reference														
Schedule Type		1	2	3	4	5	6	7	8	9	10	11	12	
Cooling (WD)	AM	78	78	78	78	78	78	78	78	80	80	80	80	
	PM	80	80	78	78	78	78	78	78	78	78	78	78	
Cooling (WEH)	AM	78	78	78	78	78	78	78	78	78	78	78	78	
	PM	78	78	78	78	78	78	78	78	78	78	78	78	
Heating (WD)	AM	66	66	66	66	66	66	66	66	66	66	66	66	
	PM	66	66	66	66	66	66	66	66	66	66	66	66	
Heating (WEH)	AM	66	66	66	66	66	66	66	66	66	66	66	66	
	PM	66	66	66	66	66	66	66	66	66	66	66	66	

Florida Code Compliance Checklist

Florida Department of Business and Professional Regulations
Residential Whole Building Performance Method

ADDRESS: 363 NW Celtic Ct
Lake City, FL, 32055-

PERMIT #:

MANDATORY REQUIREMENTS SUMMARY - See individual code sections for full details.

COMPONENT	SECTION	SUMMARY OF REQUIREMENT(S)	CHECK
Air leakage	402.4	To be caulked, gasketed, weatherstripped or otherwise sealed. Recessed lighting IC-rated as meeting ASTM E 288. Windows and doors = 0.30 cfm/sq.ft. Testing or visual inspection required. Fireplaces: gasketed doors & outdoor combustion air. Must complete envelope leakage report or visually verify Table 402.4.2.	✓
Thermostat & controls	403.1	At least one thermostat shall be provided for each separate heating and cooling system. Where forced-air furnace is primary system, programmable thermostat is required. Heat pumps with supplemental electric heat must prevent supplemental heat when compressor can meet the load.	✓
Ducts	403.2.2	All ducts, air handlers, filter boxes and building cavities which form the primary air containment passageways for air distribution systems shall be considered ducts or plenum chambers, shall be constructed and sealed in accordance with Section 503.2.7.2 of this code.	✓
	403.3.3	Building framing cavities shall not be used as supply ducts.	
Water heaters	403.4	Heat trap required for vertical pipe risers. Comply with efficiencies in Table 403.4.3.2. Provide switch or clearly marked circuit breaker (electric) or shutoff (gas). Circulating system pipes insulated to = R-2 + accessible manual OFF switch.	✓
Mechanical ventilation	403.5	Homes designed to operate at positive pressure or with mechanical ventilation systems shall not exceed the minimum ASHRAE 62 level. No make-up air from attics, crawlspaces, garages or outdoors adjacent to pools or spas.	✓
Swimming Pools & Spas	403.9	Pool pumps and pool pump motors with a total horsepower (HP) of = 1 HP shall have the capability of operating at two or more speeds. Spas and heated pools must have vapor-retardant covers or a liquid cover or other means proven to reduce heat loss except if 70% of heat from site-recovered energy. Off/timer switch required. Gas heaters minimum thermal efficiency=78% (82% after 4/16/13). Heat pump pool heaters minimum COP= 4.0.	N/A
Cooling/heating equipment	403.6	Sizing calculation performed & attached. Minimum efficiencies per Tables 503.2.3. Equipment efficiency verification required. Special occasion cooling or heating capacity requires separate system or variable capacity system. Electric heat >10kW must be divided into two or more stages.	✓
Ceilings/knee walls	405.2.1	R-19 space permitting.	✓