

*CP-AB-Floyd*  
*HVAC Load Calculations*

for

Amira Builders  
14901 N Main St  
Alachua, FL 32615

Prepared By:

Ken Fonorow  
Florida H.E.R.O., Inc.  
15220 NW 5th Ave  
Newberry, FL 32669  
(352) 472-5661  
Tuesday, February 2, 2021

## Project Report

### General Project Information

Project Title: CP-AB-Floyd  
 Designed By: Ken Fonorow  
 Project Date: 2/2/2021  
 Project Comment: Custom Home  
 Client Name: Amira Builders  
 Client Address: 14901 N Main St  
 Client City: Alachua, FL 32615  
 Client Phone: 386 462-9071  
 Client E-Mail Address: amirabuilders@aol.com  
 Company Name: Florida H.E.R.O., Inc.  
 Company Representative: Ken Fonorow  
 Company Address: 15220 NW 5th Ave  
 Company City: Newberry, FL 32669  
 Company Phone: (352) 472-5661  
 Company E-Mail Address: ken@floridahero.com  
 Company Website: www.floridahero.com

### Design Data

Reference City: Gainesville, Florida  
 Building Orientation: Front door faces West  
 Daily Temperature Range: Medium  
 Latitude: 29 Degrees  
 Elevation: 152 ft.  
 Altitude Factor: 0.995

	Outdoor Dry Bulb	Outdoor Wet Bulb	Outdoor Rel.Hum	Indoor Rel.Hum	Indoor Dry Bulb	Grains Difference
Winter:	33	30.8	n/a	n/a	72	n/a
Summer:	92	77	51%	50%	75	52

### Check Figures

Total Building Supply CFM:	1,000	CFM Per Square ft.:	0.438
Square ft. of Room Area:	2,285	Square ft. Per Ton:	970
Volume (ft³):	23,339		

### Building Loads

Total Heating Required Including Ventilation Air:	33,789 Btuh	33.789 MBH
Total Sensible Gain:	22,084 Btuh	78 %
Total Latent Gain:	6,194 Btuh	22 %
Total Cooling Required Including Ventilation Air:	28,278 Btuh	2.36 Tons (Based On Sensible + Latent)

### Notes

Rhvac is an ACCA approved Manual J, D and S computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.

## Miscellaneous Report

System 1 Whole House Input Data	Outdoor Dry Bulb	Outdoor Wet Bulb	Outdoor Rel.Hum	Indoor Rel.Hum	Indoor Dry Bulb	Grains Difference
Winter:	33	30.8	80%	n/a	72	n/a
Summer:	92	77	51%	50%	75	51.69

### Duct Sizing Inputs

	Main Trunk	Runouts
Calculate:	Yes	Yes
Use Schedule:	Yes	Yes
Roughness Factor:	0.15000	0.15000
Pressure Drop:	0.1000 in.wg./100 ft.	0.1000 in.wg./100 ft.
Minimum Velocity:	650 ft./min	450 ft./min
Maximum Velocity:	900 ft./min	750 ft./min
Minimum Height:	0 in.	0 in.
Maximum Height:	0 in.	0 in.

### Outside Air Data

	Winter	Summer
Infiltration Specified:	0.220 AC/hr 86 CFM	0.110 AC/hr 43 CFM
Infiltration Actual:	0.229 AC/hr	0.089 AC/hr
Above Grade Volume:	X 23,339 Cu.ft. 5,349 Cu.ft./hr X 0.0167	X 23,339 Cu.ft. 2,084 Cu.ft./hr X 0.0167
Total Building Infiltration:	89 CFM	35 CFM
Total Building Ventilation:	25 CFM	50 CFM

#### ---System 1---

Infiltration & Ventilation Sensible Gain Multiplier:	18.60	= (1.10 X 0.995 X 17.00 Summer Temp. Difference)
Infiltration & Ventilation Latent Gain Multiplier:	34.96	= (0.68 X 0.995 X 51.69 Grains Difference)
Infiltration & Ventilation Sensible Loss Multiplier:	42.66	= (1.10 X 0.995 X 39.00 Winter Temp. Difference)
Winter Infiltration Specified:	0.220 AC/hr (86 CFM), Construction: Semi-Tight	
Summer Infiltration Specified:	0.110 AC/hr (43 CFM), Construction: Semi-Tight	

### Duct Load Factor Scenarios for System 1

No.	Type	Description	Location	Attic Ceiling	Duct Leakage	Duct Insulation	Surface Area	From [T]MDD
1	Supply	Main	Attic	16B	0.06	6	614	No
1	Return	Main	Attic	16B	0.06	6	227	No

## Tabular Manual D Ductsize Grid

Ducts	Room	Feeds Zones	Flow	Diam	Wid	Hei	Vel
<input type="checkbox"/> <b>CP-AB-Floyd</b>							
<input type="checkbox"/> CP-AB-Floyd							
<input type="checkbox"/> System 2							
Supply							
Return							
<input type="checkbox"/> System 4							
Supply							
Return							
<input type="checkbox"/> System 6							
Supply							
Return							
<input type="checkbox"/> System 8							
Supply							
Return							
<input type="checkbox"/> System 10							
Supply							
Return							
<input type="checkbox"/> System 12							
Supply							
Return							
<input type="checkbox"/> System 14							
Supply							
Return							

**Total Building Summary Loads**

Component Description	Area Quan	Sen Loss	Lat Gain	Sen Gain	Total Gain
VYN 34 23: Glazing-Dbl Pn Vyn Fr U .34 SHGC .23, ground reflectance = 0.23, outdoor insect screen with 50% coverage, medium color blinds at 45° with 25% coverage, U-value 0.34, SHGC 0.23	81	1,075	0	1,129	1,129
VYN 34 23: Glazing-Dbl Pn Vyn Fr U .34 SHGC .23, ground reflectance = 0.23, U-value 0.34, SHGC 0.23	38.2	507	0	524	524
FrDr 34 23: Glazing-Fr Dr Dbl Pn Vyn U .34 SHGC .23, ground reflectance = 0.32, medium color blinds at 45° with 50% coverage, U-value 0.34, SHGC 0.23	114.5	1,517	0	1,108	1,108
VYN 34 23: Glazing-Dbl Pn Vyn Fr U .34 SHGC .23, ground reflectance = 0.32, outdoor insect screen with 50% coverage, medium color blinds at 45° with 25% coverage, U-value 0.34, SHGC 0.23	42	556	0	738	738
VYN 34 23: Glazing-Dbl Pn Vyn Fr U .34 SHGC .23, ground reflectance = 0.23, medium color blinds at 45° with 100% coverage, U-value 0.34, SHGC 0.23	30	398	0	608	608
VYN 34 23: Glazing-Dbl Pn Vyn Fr U .34 SHGC .23, ground reflectance = 0.32, U-value 0.34, SHGC 0.23	12	160	0	126	126
VYN 34 23: Glazing-Dbl Pn Vyn Fr U .34 SHGC .23, ground reflectance = 0.32, outdoor insect screen with 50% coverage, medium color blinds at 45° with 50% coverage, U-value 0.34, SHGC 0.23	42	556	0	712	712
11P: Door-Metal - Polyurethane Core, U-value 0.29	17.8	201	0	145	145
12E-Osw: Wall-Frame, R-19 insulation in 2 x 6 stud cavity, no board insulation, siding finish, wood studs, U-value 0.068	2218.4	5,885	0	2,929	2,929
16B-30: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Vented Attic, No Radiant Barrier, Dark Asphalt Shingles or Dark Metal, Tar and Gravel or Membrane, R-30 insulation, U-value 0.032	2284.9	2,852	0	3,803	3,803
16B-19: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Vented Attic, No Radiant Barrier, Dark Asphalt Shingles or Dark Metal, Tar and Gravel or Membrane, R-19 insulation, U-value 0.049	96	183	0	246	246
22A-pl: Floor-Slab on grade, No edge insulation, no insulation below floor, any floor cover, passive, light dry soil, U-value 0.989	267	10,299	0	0	0
Subtotals for structure:		24,189	0	12,068	12,068
People:	6		1,200	1,380	2,580
Equipment:			1,350	2,650	4,000
Lighting:	0			0	0
Ductwork:		4,730	681	3,533	4,215
Infiltration: Winter CFM: 89, Summer CFM: 35		3,803	1,215	647	1,862
Ventilation: Winter CFM: 25, Summer CFM: 50		1,067	1,748	930	2,678
Exhaust: Winter CFM: 50, Summer CFM: 25					
AED Excursion:		0	0	876	876
Total Building Load Totals:		33,789	6,194	22,084	28,278

**Check Figures**

Total Building Supply CFM:	1,000	CFM Per Square ft.:	0.438
Square ft. of Room Area:	2,285	Square ft. Per Ton:	970
Volume (ft³):	23,339		

**Building Loads**

Total Heating Required Including Ventilation Air:	33,789 Btuh	33.789 MBH
---	-------------	------------

## *Total Building Summary Loads (cont'd)*

### Building Loads

Total Sensible Gain:	22,084	Btuh	78	%
Total Latent Gain:	6,194	Btuh	22	%
Total Cooling Required Including Ventilation Air:	28,278	Btuh	2.36	Tons (Based On Sensible + Latent)

### Notes

Rhvac is an ACCA approved Manual J, D and S computer program.  
Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.  
All computed results are estimates as building use and weather may vary.  
Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.

## System 1 Room Load Summary

Room No	Room Name	Area SF	Htg Sens Btuh	Min Htg CFM	Run Duct Size	Run Duct Vel	Clg Sens Btuh	Clg Lat Btuh	Min Clg CFM	Act Sys CFM
---Zone 1---										
1	Master Suite	252	3,430	63	2-6	358	3,080	535	141	141
2	Master Bath	180	2,784	51	1-6	338	1,452	668	66	66
3	MBR WIC	143	2,374	43	1-4	376	718	103	33	33
4	Laundry	99	139	3	1-4	251	478	350	22	22
5	PWDR	36	816	15	1-4	113	216	88	10	10
6	Garage Entry	90	1,517	28	0-0	0	669	51	31	31
Zone 1 subtotal		800	11,059	202			6,613	1,795	302	302
---Zone 2---										
7	Kitchen	204	2,452	45	1-7	481	2,815	648	129	129
8	Pantry	76	858	16	1-4	306	584	34	27	27
9	Dining	156	2,120	39	1-6	523	2,246	84	103	103
10	Foyer	96	1,961	36	1-7	575	3,361	67	154	154
11	Great Room	345	3,177	58	2-6	504	4,332	483	198	198
12	Bedroom 2	182	3,331	61	1-7	559	3,266	133	149	149
13	Bath	195	1,651	30	1-4	438	837	311	38	38
14	Bedroom 3	192	4,332	79	1-6	432	1,856	187	85	85
15	BR 3 WIC	40	504	9	1-4	88	167	23	8	8
Zone 2 subtotal		1,485	20,387	373			19,464	1,970	890	890
Ventilation			1,067				930	1,748		
Duct Latent								497		
Return Duct			1,277				954	184		
System 1 total		2,285	33,789	575			22,084	6,194	923	1,000

System 1 Main Trunk Size: 14x14 in.  
 Velocity: 735 ft./min  
 Loss per 100 ft.: 0.347 in.wg

Note: Since the system is multizone, the Peak Fenestration Gain Procedure was used to determine glass sensible gains at the room and zone levels, so the sums of the zone sensible gains and airflows for cooling shown above are not intended to equal the totals at the system level. Room and zone sensible gains and cooling CFM values are for the hour in which the glass sensible gain for the zone is at its peak. Sensible gains at the system level are based on the "Average Load Procedure + Excursion" method.

## Cooling System Summary

	Cooling Tons	Sensible/Latent Split	Sensible Btuh	Latent Btuh	Total Btuh
Net Required:	2.36	78% / 22%	22,084	6,194	28,278
Actual:	2.38	77% / 23%	22,022	6,578	28,600

## Equipment Data

	Heating System	Cooling System
Type:	Air Source Heat Pump	Air Source Heat Pump
Model:	CH14NB030*0**A*	CH14NB030*0**A*
Indoor Model:		FB4CNP030L
Brand:	14 SEER HP	14 SEER HP
Description:	Air Source Heat Pump	Air Source Heat Pump
Efficiency:	8.2 HSPF	14 SEER
Sound:	0	0
Capacity:	28,600 Btuh	28,600 Btuh
Sensible Capacity:	n/a	22,022 Btuh
Latent Capacity:	n/a	6,578 Btuh
AHRI Reference No.:	n/a	9162305

## *System 1 Room Load Summary (cont'd)*

### Equipment Data

This system's equipment was selected in accordance with ACCA Manual S.


Manual S equipment sizing data: SODB: 92F, SOWB: 77F, WODB: 33F, SIDB: 75F, SIRH: 50%, WIDB: 72F, Sen. gain: 22,084 Btuh, Lat. gain: 6,194 Btuh, Sen. loss: 33,789 Btuh, Entering clg. coil DB: 76.7F, Entering clg. coil WB: 63.6F, Entering htg. coil DB: 69.9F, Clg. coil TD: 20F, Htg. coil TD: 50F, Req. clg. airflow: 923 CFM, Req. htg. airflow: 575 CFM



CP-AB-Floyd

APPROX. AREA	
LIVING	2285
GARAGE	169
LANAI	271
PORCH	190
TOTAL	3521

DESIGN CRITERIA			
F.L. BUILDING CODE	RESIDENTIAL	2017	
F.L. ELECTRICAL	NAT. ELEC. CODE	2014	
F.L. PLUMBING	F.L.	2017	
MECHANICAL	F.L.	2017	
WIND LOAD DESIGN	ASCE 7-10 (ALL HEIGHTS)		
WIND LOAD DESIGN	FBC, TPI 2014	FBC 2017	
ROOF LIVE LOAD	20 PSF		
FLOOR LIVE LOAD	40 PSF		



MAIN FLOOR PLAN

ALL WINDOWS AND DOORS TO BE INSTALLED PER MANUFACTURERS RECOMMENDATIONS AND PART COORDINATE WITH ARCHITECT. WORKSHOPS WITH PART COORDINATE.

ALL INTERIOR & EXTERIOR DOORS TO BE 6' TALL

IT IS THE OWNER AND/OR THE CONTRACTORS RESPONSIBILITY TO VERIFY ALL STRUCTURAL ASPECTS OF THESE DRAWINGS. THIS INCLUDES BUT NOT LIMITED TO: WALL HEIGHTS AND MATERIAL, WINDOW LOCATIONS, ALSO ALL STATE AND LOCAL CODES. PL.