



Project Summary

Entire House

Job:
Date: Aug 01, 2025
By:

Project Information

For: Howe, Corey Amira

Notes:



Review for Code Compliance
Universal Engineering Science

Lawrence Pennell
Examiner-License No.

PX2707

10/20/2025

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 68 °F
Design TD 35 °F

Ventilation Method MJ8

Heating Summary

Structure 29824 Btuh
Ducts (R-6.0) 4200 Btuh
Central vent (0 cfm) 0 Btuh

Humidification 0 Btuh
Piping 0 Btuh
Equipment load 34024 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

	Heating	Cooling
Area (ft ²)	1223	1223
Volume (ft ³)	11498	11498
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	86	44

Heating Equipment Summary

Make Carrier
Trade 15 SEER2 HP
Model GH5SAN53000AA0
AHRI ref 214101792

Efficiency 7.5 HSPF2
Heating input
Heating output 28600 Btuh @ 47°F
Temperature rise 28 °F
Actual air flow 947 cfm
Air flow factor 0.028 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 38 °F

Backup: n/a n/a
Input = 0 kW, Output = 0 Btuh, 100 AFUE

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 44 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 19415 Btuh
Ducts (R-6.0) 5263 Btuh
Central vent (0 cfm) 0 Btuh

Blower 0 Btuh

Use manufacturer's data n
Rate/swing multiplier 0.97
Equipment sensible load 23987 Btuh

Latent Cooling Equipment Load Sizing

Structure 1907 Btuh
Ducts 1009 Btuh
Central vent (0 cfm) 0 Btuh

Equipment latent load 2916 Btuh

Equipment Total Load (Sen+Lat) 26903 Btuh
Req. total capacity at 0.70 SHR 2.9 ton

Cooling Equipment Summary

Make Carrier
Trade 15 SEER2 HP
Cond GH5SAN53000AA0
Coil FJ5ANXB30L00
AHRI ref 214101792

Efficiency 12.0 EER2, 14.5 SEER2
Sensible cooling 19880 Btuh
Latent cooling 8520 Btuh
Total cooling 28400 Btuh
Actual air flow 947 cfm
Air flow factor 0.038 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.89

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Load Short Form

Entire House

Job:
Date: Aug 01, 2025
By:

Project Information

For: Howe, Corey Amira



Review for Code Compliance
Universal Engineering Science

Design Information

PX2707

10/20/2025

Examiner License No.

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Average
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	44		

HEATING EQUIPMENT

Make Carrier
Trade 15 SEER2 HP
Model GH5SAN53000AA0
AHRI ref 214101792

Efficiency 7.5 HSPF2
Heating input
Heating output 28600 Btuh @ 47°F
Temperature rise 28 °F
Actual air flow 947 cfm
Air flow factor 0.028 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 38 °F

Backup: n/a n/a

Input = 0 kW, Output = 0 Btuh, 100 AFUE

COOLING EQUIPMENT

Make Carrier
Trade 15 SEER2 HP
Cond GH5SAN53000AA0
Coil FJ5ANXB30L00
AHRI ref 214101792

Efficiency 12.0 EER2, 14.5 SEER2
Sensible cooling 19880 Btuh
Latent cooling 8520 Btuh
Total cooling 28400 Btuh
Actual air flow 947 cfm
Air flow factor 0.038 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.89

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
bedroom 2	168	7887	5729	220	220
wic 2	35	1357	746	38	29
master bedroom	183	4277	3120	119	120
master bath	101	6823	3625	190	139
hall	42	0	0	0	0
pantry	27	1339	716	37	27
wic	32	40	68	1	3
bath	52	78	131	2	5
kitchen	204	4772	3953	133	152
great room	378	7451	6590	207	253

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2025 25.0.01 RSU57217

2025-Aug-04 14:59:03

Page 1

...F plans & J&D (2025)Amira, Corey\Howe\Howe.rup Calc = MJ8 Front Door faces: N

Entire House	1223	34024	24678	947	947
Other equip loads		0	0		
Equip. @ 0.97 RSM			23987		
Latent cooling			2916		
TOTALS	1223	34024	25503	947	947



Review for Code Compliance
Universal Engineering Science

Lawrence Pennell
Examiner-License No.

PX2707 10/20/2025

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Review for Code Compliance
Universal Engineering Science


Lawrence Pennell
Examiner-License No.

PX2707

10/20/2025

6'-0"

Level 1



Job #:
Performed for:
Howe

Scale: 1 : 126
Page 1
Right-Suite® Universal 2025
25.0.01 RSU57217
2025-Aug-04 14:59:24
...2025)\Amira, Corey\Howe\Howe.ru



Manual S Compliance Report

Entire House

Job:
Date: Aug 01, 2025
By:



Review for Code Compliance
Universal Engineering Science

Project Information

PX2707

10/20/2025

Examiner License No.

For: Howe, Corey Amira

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	24678 Btuh	Entering coil DB:	76.7°F
Outdoor design WB:	75.8°F	Latent gain:	2916 Btuh	Entering coil WB:	63.3°F
Indoor design DB:	75.0°F	Total gain:	27594 Btuh		
Indoor RH:	50%	Estimated airflow:	947 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Carrier	Model:	GH5SAN53000AA0+FJ5ANXB30L00
Actual airflow:	947 cfm		
Sensible capacity:	19880 Btuh	81% of load	
Latent capacity:	8520 Btuh	292% of load	
Total capacity:	28400 Btuh	103% of load	SHR: 70%

Heating Equipment

Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	34024 Btuh	Entering coil DB:	67.2°F
Indoor design DB:	68.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Carrier	Model:	GH5SAN53000AA0+FJ5ANXB30L00
Actual airflow:	947 cfm		
Output capacity:	28600 Btuh	84% of load	
Supplemental heat required:	5424 Btuh		
		Capacity balance:	38 °F
		Economic balance:	-99 °F

Backup equipment type:	Elec strip		
Manufacturer:	n/a	Model:	n/a+n/a
Actual airflow:	947 cfm		
Output capacity:	0 kW	0% of load	Temp. rise: 0 °F

Meets all requirements of ACCA Manual S.



Duct System Summary

Entire House

Job:
Date: Aug 01, 2025
By:



Review for Code Compliance
Universal Engineering Science

Project Information

PX2707

10/20/2025

For: Howe, Corey Amira

Examiner License No.

	Heating	Cooling
External static pressure	0.50 in H ₂ O	0.50 in H ₂ O
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0.50 in H ₂ O	0.50 in H ₂ O
Supply / return available pressure	0.404 / 0.096 in H ₂ O	0.404 / 0.096 in H ₂ O
Lowest friction rate	0.316 in/100ft	0.316 in/100ft
Actual air flow	947 cfm	947 cfm
Total effective length (TEL)	158 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath	c 131	2	5	0.357	4.0	0x0	VIFx	23.2	90.0	st1
bedroom 2-A	c 5729	220	220	0.323	7.0	0x0	VIFx	35.2	90.0	st1
great room	c 3295	104	126	0.368	7.0	0x0	VIFx	19.8	90.0	st1
great room-A	c 3295	104	126	0.358	7.0	0x0	VIFx	22.9	90.0	st1
kitchen	c 3953	133	152	0.389	8.0	0x0	VIFx	14.0	90.0	st1
master bath	h 6823	190	139	0.320	6.0	0x0	VIFx	31.2	95.0	st1
master bedroom	c 3120	119	120	0.346	7.0	0x0	VIFx	26.7	90.0	st1
pantry	h 1339	37	27	0.349	4.0	0x0	VIFx	25.7	90.0	st1
wic	c 68	1	3	0.352	4.0	0x0	VIFx	24.9	90.0	st1
wic 2	h 1357	38	29	0.316	4.0	0x0	VIFx	37.9	90.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	947	947	0.316	678	16.0	0 x 0	VinIFlx	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	947	947	30.3	0.316	536	18.0	0x0		VIFx	rst2

Bold/italic values have been manually overridden

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rst2	Peak AVF	947	947	0.316	678	16.0	0 x 0	VinIFlx	



Review for Code Compliance
Universal Engineering Science

Lester Parnell

PX2707

10/20/2025

Examiner-License No.

Bold/italic values have been manually overridden



Right-Suite® Universal 2025 25.0.01 RSU57217

...F plans & J&D (2025)Amira, Corey\Howe\Howe.rup Calc = MJ8 Front Door faces: N

2025-Aug-04 14:59:03

Page 2