



**METAL ROOF PANEL FASTENER SPECIFICATIONS**

**PROJECT ID:** 688 SW COUNTY ROAD 242A, LAKE CITY, FLORIDA  
**PARCEL NO.:** 29-4S-17-08841-006 **COUNTY:** COLUMBIA  
**PREPARED FOR:** DEEP SOUTH METALS  
**PREPARED BY:** THOMAS BECHTOL, P.E., FLORIDA LICENSE NO. 38538  
**DATE PREPARED:** 12-31-2024

---

MATERIAL SPECIFICATIONS:

**ROOF PANELS:** DEEP SOUTH METALS "SOUTH RIB" 26 OR 29 GA., 36" WIDE PANELS.

**SUBSTRATE:** EXISTING NOMINAL ½" OSB SHEATHING (RE-NAILED AS REQUIRED PER SECTION 706.7.1.2 FBC EXISTING BUILDING EIGHTH EDITION (2023)).

**ROOF PANEL FASTENERS:** #10 WOOD SCREWS WITH CONTROL SEAL WASHER, LENGTH AS NEEDED FOR FULL PENETRATION THROUGH SHEATHING.

DESIGN CRITERIA:

**RISK CATEGORY:** II

**EXPOSURE CATEGORY:** C

**ULTIMATE WIND SPEED:** 120 MPH

**NOMINAL DESIGN WIND SPEED:** 93 MPH

**BUILDING CLASSIFICATION:** ENCLOSED

**MEAN ROOF HEIGHT:** 15 FEET MAXIMUM

**ROOF ANGLE:** 9.5 DEGREES

**EFFECTIVE WIND AREA:** 10 S.F.

COMPONENT AND CLADDING DESIGN WIND PRESSURES:

DESIGN UNIT LOADS (q): SEE ATTACHED WIND PRESSURE CALCULATIONS.

**MAXIMUM DESIGN PRESSURE:** -60.4 PSF.

ROOF PANEL FASTENER DESIGN CALCULATIONS:

DESIGN FASTENER: #10 SCREWS INTO NOMINAL 1/2" OSB SHEATHING.

ALLOWABLE PULL-OUT CAPACITY = 71 POUNDS / SCREW (INCORPORATES MINIMUM SF = 5)

FASTENER ROW SPACING = 16" = 1.33' ON CENTERS.

USE 1 SCREW AT EACH FASTENING POINT ALONG EACH ROW.

USE MAXIMUM WIND PRESSURE = 60.4 PSF

MAXIMUM FASTENING POINT SPACING =  $(71) / (1.33)(60.4) = 0.88' = 10.6"$

**DESIGN: USE ONE (1) SCREW @ 9" O.C.(ADJACENT TO OR ON EACH RIB) ALONG FASTENER ROWS  
SPACED AT 16" ON CENTERS**

---

THIS IS TO CERTIFY THAT THE CALCULATIONS AND SPECIFICATIONS HEREIN HAVE BEEN PREPARED BY THE UNDERSIGNED PROFESSIONAL ENGINEER, AND ARE IN ACCORDANCE WITH THE REQUIREMENTS OF SECTION 1609 OF THE FLORIDA BUILDING CODE EIGHTH EDITION (2023) AND CHAPTER 30 OF ASCE 7-22.

***Bechtol Engineering and Testing, Inc.***

Thomas Bechtol

Digitally signed by Thomas  
Bechtol

Date: 2024.12.31 14:05:18 -05'00'

**Thomas Bechtol, P.E.**

**President / Principal Engineer**

This item has been digitally signed and sealed by Thomas Bechtol, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.



# DESIGN WIND PRESSURES CALCULATION SHEET

PROJECT ID: 688 SW COUNTY ROAD 242A, LAKE CITY, FLORIDA			
ENCLOSURE TYPE: ENCLOSED	RISK CATEGORY: II		
ENCLOSURE TYPE: ENCLOSED	EXPOSURE CATEGORY: C		
MEAN ROOF HEIGHT (FT): 15 MAX	ROOF SLOPE ( $\theta^\circ$ ): $7 < \theta \leq 20$		
MEAN ROOF HEIGHT (FT): 15 MAX	ROOF TYPE: GABLE		
ULTIMATE WIND SPEED (FROM FIGURE 1609.3, FLORIDA BUILDING CODE EIGHTH EDITION (2023))	$V_{ult} = 120$		
WIND DIRECTIONALITY FACTOR (FROM TABLE 26.6-1, ASCE 7-22)	$K_d = 0.85$		
TOPOGRAPHIC FACTOR (FROM SECTION 26.8.2, ASCE 7-22)	$K_{zt} = 1.00$		
GROUND ELEVATION FACTOR (FROM TABLE 26.9-1, ASCE 7-22)	$K_e = 1.00$		
INTERNAL PRESSURE COEFFICIENT (FROM TABLE 26.13-1, ASCE 7-22)	$GC_{pi} = 0.18$		
VELOCITY PRESSURE EXPOSURE COEFFICIENT (FROM TABLE 26.10-1, ASCE 7-22)	$K_z = 0.85$		
VELOCITY PRESSURE ( $q_h$ ) $q_h = 0.00256(K_z)(K_{zt})(K_e)(V_{ult})^2(0.6) = 0.001536(K_z)(V_{ult})^2$	$q_h = 18.80$		
EXTERNAL PRESSURE COEFFICIENTS (FROM FIGURE 30.3, ASCE 7-22)	ROOF	ZONE 1	$GC_p = -2.0$
		ZONE 2	$GC_p = -2.7$
		ZONE 3	$GC_p = -3.6$
	WALL	ZONE 4	$GC_p = N/A$
		ZONE 5	$GC_p = N/A$
DESIGN WIND PRESSURES (P)  $P = q_h K_d (GC_p - GC_{pi})$	ROOF	ZONE 1	$P = -34.8$
		ZONE 2	$P = -46.0$
		ZONE 3	$P = -60.4$
	WALL	ZONE 4	$P = N/A$
		ZONE 5	$P = N/A$

**Bechtol Engineering and Testing, Inc.**

Thomas Bechtol | Digitally signed by Thomas Bechtol  
Date: 2024.12.31 14:07:55 -05'00'

**Thomas Bechtol, P.E.**  
**President / Principal Engineer**

This item has been digitally signed and sealed by Thomas Bechtol, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.

