

# EMS HVAC Load Calculator

www.hvacloadcalculator.com



Date: Thu Jan 13  
2022 13:51pm

Loaded Document: paul spicer//luke

Welcome - frank l

## Company Info

Company southern air sales and servi  
Preparer franl  
Phone (352) 494-2252  
Email perkins318@cox.net

## Client Information

Name paul spicer //luke  
Address1 1880 sw county rd 778  
Address2 high springs  
Address3 columbia co.  
Phone (386) 590-1040  
Email perkins318@cox.net  
Date 13-Jan-2022

*This HVAC load calculation has been performed using sound engineering principles as prescribed by Manual J eighth edition and ASHRAE Handbook of Fundamentals. Duct sizing has been performed as prescribed by Manual D.*

## 1. Design Conditions(Temp. F)

☐ Check If Using Celcius

	INDOOR	OUTDOOR	TEMP DIFF	Front of Building is Facing	East	Sq.Ft
WINTER	68	30	38			
SUMMER	73	95	22			
				Total Conditioned Area	1040	

## 2. Summer Humidity

Very Humid



60

Grains  
Difference

## 3. How Tight is Structure

Average-under 1500 Sq. Ft.



Winter

Summer

Air/Changes/Hr.

1

0.5

## 4. Fireplace Evaluation

Number

Evaluation

CFM

none



Tight




0

## 5. Number of Occupants

generally equals number of bedrooms + 1

3

## Overhang Characteristics



Enter all measurements decimally

1" = .1      7" = .6  
2" = .2      8" = .7  
3" = .3      9" = .8  
4" = .4      10" = .9  
5" = .5      11" = .9  
6" = .5

Example- 2 ft. 8 in. = 2.7 ft.

	EAST	WEST	S/SE/SW	N/NE/NW
Distance of OH from top of window (A)	1.5	1.5	3.5	3.5
Length of overhang (B)	2	2	1	1
Total linear ft. across top of windows located below overhang	10.5	12	3	5.7

## Solar Gain Through Glass

☐ Check this box if using manufacturer specifications and enter the latitude, U-value and SHGC

Latitude

U-  
Value

SHGC

Facing	Area(sq ft)	Type Glass	HTM	Unshaded	Shaded	BTUH
North or Shaded	17.5	Tripl or l ▼	20.00	0	20	404
NE/NW	0	▼	0.00	0	0	0
South	7.5	Tripl or l ▼	33.00	8	0	248
SE/SW	0	▼	0.00	0	0	0
East	54	Tripl or l ▼	65.00	53	1	3,428
West	32.8	Tripl or l ▼	65.00	31	1	2,038

Does glass have reflective coating?

No



1

6,118

Skylight

0



0

0

**Total  
Solar  
Gain**

**6,118**

## DUCTS OR PIPES

Location(Heating)

Trunk and branch



Duct Loss 0.11

Location(Cooling)

Trunk and branch



Duct Gain 0.23

Duct/Pipe Insulation

R-6



Duct Leakage

sealed



Area of Attic or Floor Where Duct is Located

1040

Attic Temperature(If ducts located in attic)

120



## Load Calculation

Elements of Load

Area or Lin. Ft

Insulation/R-value

U-Value

Heat Loss Btuh

Heat Gain Btuh

Latent Btuh

Solar Gain from Glass

6,118

Gross Wall	1056				
Glass 1	112	Triple/L	0.42	1,784	
Skylight	0		0.00	0	
Doors	2	Insulate	0.40	30	18
Net Wall	942	R-15	0.09	3,079	1,783
Ceiling	1040	R-30	0.03	1,265	1,498

### Floor

Over Crawl or Unheated Basement	1040	R-19	0.05	968	0
Open-Beach House Above Carport	0		0.00	0	0
Slab On Grade - enter-linear ft	0		0.00	0	0
Infiltration-Enter cubic-ft of building	8372			5,832	1,688

People 690 600

Appliances ☐ Enter Value 400

Sub Total 12,959 12,194

Duct Loss/Gain 1,475 2,770 571

Total Sensible Load 14,434 14,964

Latent Load	2,846
Total Latent Load	4,018

## SUMMARY

Heating Load	Sensible Cooling	Latent Cooling	Total Cooling Load	*Nominal Tons
14,434	14,964	4,018	18,982	1.66

OUTDOOR AIR FLOW RATE

**\* CAUTION - The cooling capacity of the air conditioner must meet both, sensible and latent loads. It is recommended a Manual S calculation be performed. Using manufacturer's specs. The nominal tons assume .75 S/T ratio at the chosen outdoor design temperature.**

## Summary Including Basement

Heating Load	Sensible Cooling	Latent Cooling	Total Cooling Load	Nominal Tons
14,434	14,964	4,018	18,982	1.66

Whole House (Block Load) Completed  
 Scroll to top For Additional Options ➔

## Solar Gain Through Glass



☐ Check if Using Manufacturer specs

Latitude  U-Value  SHGC

14,434

Sensible Heat  
Gain

14,964

 Add-Room Check-Calculations-When-Completed

<div><div></div><div></div></div>	great room	5,140	5,953	285	318
<div><div></div><div></div></div>	office	1,448	1,890	80	101
<div><div></div><div></div></div>	bath2	441	277	24	15
<div><div></div><div></div></div>	bed 1	3,096	2,959	172	158
<div><div></div><div></div></div>	bed 2	1,791	2,498	99	134
<div><div></div><div></div></div>	laundry	1,970	1,340	109	72
Totals:		13,885	14,916	770	797
Percent Of Original:		96%	99%		

**Round to Rectangle Conversion Calculator(Optional)**Enter Round  
Diameter

Side A (Inches)

Side B (Inches)

0

0

**Duct Sizing**Use heating or cooling  
cfm

Type of duct material



Use Cooling CFM ▼

Flex Duct ▼

### Determine Friction Rate (see instructions)

Total measured length of duct

0

Total equivalent length of fittings

0

Available static pressure for duct

0

Enter Friction Rate:

.2

☐ Calculate Friction Rate

### Supply Trunk or branch

cfm

duct  
diaair  
vel

First section off AH

800

12

980

1st reduction or branch

150

6

652

2nd reduction or branch

50

4

499

3rd reduction or branch

98

6

588

4th reduction or branch

200

7

699

5th reduction or branch

520

10

882

### Return Trunk or branch

cfm

duct  
diaair  
vel

First section off AH

800

12

980

1st reduction or branch

0

0

2nd reduction or branch

0

0

3rd reduction or branch

0

0

4th reduction or branch

0

0



5th reduction or branch

0

0

Basement supply and  
return trunk

0

Room Runs

cfm

no of outlets

outlet  
cfm

duct  
dia

air  
vel

great room

318

0

∞

∞

office

101

0

∞

∞

bath2

15

0

∞

∞

bed 1

158

0

∞

∞

bed 2

134

0

∞

∞

laundry

72

0

∞

∞

Duct Sizing Completed

Scroll to top For Additional Options ➡

### Equipment selection as per Manual S

Instructions: enter load, weather and manufacture's data in white cells

☐ Auto Complete

BTUH

Total Heat Loss

14434

Design  
Conditions

Outdoor

Indoor

Total Heat Gain

18982

30

68

Sensible Heat  
Gain

14964

95

73

Latent Heat  
Gain

4,018

ID Design RH

50%, 63F WB