



LIFE SAFETY PLAN

SCALE: 1/4" = 1'-0"

OCCUPANCY LOAD - BUSINESS

USAGE/AREA	AREA	OCCUPANTS
WAITING ROOM	651.4 SF	44 OCCUPANTS
PASSAGEWAY	519.2 SF	6 OCCUPANTS
LAB / EXAM RM'S	959.9 SF	16 OCCUPANTS
RESTROOM	203.5 SF	4 OCCUPANTS
OFFICE/BUSINESS	452.1 SF	5 OCCUPANTS
CHECK-IN/RECEPTION	233.6 SF	2 OCCUPANTS
UN-OCCD LEASE AREA	293.0 SF	0 OCCUPANTS
BUILDING WALLS	1043.4 SF	2 OCCUPANTS
BUILDING TOTALS	1500.0 SF	79 OCCUPANTS

EXIT ACCESS TRAVEL DISTANCE PER FCC 10B, TABLE 10B.1

OCCUPANCY - BUSINESS
150 FT. (DUO SPRINKLER SYSTEM)
250 FT. (W/SPRINKLER SYSTEM)

LEGEND

- EXIT LIGHT - ARROW REPRESENTS DIRECTION OF EXIT PER 2010 FCC 1006.3.1, 1006.3.1.1, 1006.3.2.1
- WALL HANG "ABC" FIRE EXTINGUISHER
- DOOR CLOSER FOR EXITING OR RATING RELAYING
- PANIC DEVICE
- DUAL HEAD EMERGENCY LIGHTING W/ BAT. P.K. PER 2010 FCC 1006.1
- AREA SQUARE FOOTAGE
- AREA OCCUPANCY LOAD
- PRIMARY EGRESS W/EXIT CAPACITY
- ALTERNATE EGRESS W/EXIT CAPACITY

NOTE:
EMERGENCY LIGHTING AND EXIT SIGNS SHALL BE PROVIDED AS DIRECTED BY THE FIRE MARSHAL, AND SHALL BE MAINTAINED PER 1006.1.

NOTE:

EMERGENCY LIGHTING SHALL BE MOUNTED NOT LESS THAN 8'0" ABOVE FINISHED FLOOR AND SHALL BE THE IONIZATION TYPE INTERLOCKED TOGETHER POWERED FROM EACH STONE PANEL (BATTERY BACKUP)

NOTE:

MAXIMUM COMMON PATH OF EGRESS IS LESS THAN 12'-0" FROM ALL LOCATIONS PER 2011 FCC 1014.3

NOTE:

TRAVEL DISTANCES SHOWN ARE MAXIMUM FOR EMERGENCY EGRESS, SECONDARY EN EGRESS AND NON-EMERGENCY EGRESS - ALL OTHER TRAVEL DISTANCES ARE LESS THAN THAT SHOWN

8" SQ. MALTESE CROSS w/ "F/R" IDENTIFIER SIGNAGE, MOUNTED 8' 60" ABV. WALKWAY LOCATE AS DIRECTED BY THE FIRE MARSHAL