



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

05/04/2023

L-29457

Permit # 000043872

Re: Lots 10 Block A Old Wire Farms

Wayne Green

To Whom It May Concern:

The finished floor elevation on Lot 10 is found to be 90.56 feet. The building permit shows a Minimum floor elevation of 82.9 feet. The floor elevation shown hereon is in NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757

